

**MONTHLY PROGRESS REPORT #138  
FOR SEPTEMBER 2008**

**EPA REGION I ADMINISTRATIVE ORDERS SDWA 1-97-1019 and 1-2000-0014**

**MASSACHUSETTS MILITARY RESERVATION  
TRAINING RANGE AND IMPACT AREA**

The following summary of progress is for the period from 01 September to 30 September 2008.

**1. SUMMARY OF REMEDIATION ACTIONS**

The following is a description of Remediation Actions (RA) underway at Camp Edwards as of September 2008. Remediation actions may include Rapid Response Actions (RRA). An RRA is an interim action that may be conducted prior to risk assessments or remedial investigations to address a known, ongoing threat of contamination to groundwater and/or soil.

Demo Area 1 Comprehensive Groundwater RA

The Demo Area 1 Comprehensive Groundwater RA consists of the removal and treatment of contaminated groundwater to control further migration of explosives and perchlorate. Extraction, treatment, and recharge (ETR) systems at Frank Perkins Road and Pew Road include extraction wells, ex-situ treatment processes to remove explosives and perchlorate from the groundwater, and injection wells to return treated water to the aquifer.

The Pew Road ETR continues operation at a flow rate of 103 gallons per minute (gpm). The Pew Road ETR system went down at 2337 on 2 September 2008 due to a power interruption; it was restarted at 0745 on 3 September 2008 resulting in approx 7.6 hrs of down time. As of 26 September 2008 over 68 million gallons of water were treated and re-injected at the Pew Road System.

The Frank Perkins Road ETR continues to operate at a flow rate of 808 gpm. As of 26 September 2008, over 427 million gallons of water have been treated and re-injected at the Frank Perkins Road Treatment System.

J-1 Range South Groundwater RRA

The J-1 Range South Groundwater RRA consists of removal and treatment of contaminated groundwater to control further migration of explosives. The ETR system includes a single extraction well, ex-situ treatment process to remove explosives from the groundwater, and an infiltration trench to return treated water to the aquifer.

The J-1 Range South system continues to operate at a flow rate of 75 gpm. The J-1 Range South System shutdown at 0715 on 23 September 2008 due to a power outage possibly caused by a tree limb across a phase wire at Rt. 130. The system was restarted at 1145 on 24 September 2008 in by-pass mode due to some problems with the VFD. The VFD was repaired on 26 September 2008. As of 26 September 2008, over 37.5 million gallons of water were treated and re-injected.

J-2 Range North Groundwater RRA

The J-2 Range North Groundwater RRA consists of removal and treatment of contaminated groundwater to control further migration of explosives and perchlorate. ETR systems include

single extraction wells, ex-situ treatment processes to remove explosives and perchlorate from the groundwater, and infiltration basins to return treated water to the aquifer.

The J-2 Range North treatment plant continues to operate at 125 gpm. The J-2 Range North system shut down at 0605 on 7 September 2008 due to a power outage; the system was restarted on 7 September 2008 resulting in 5.6 hrs of downtime. As of 26 September 2008, over 136 million gallons of water treated and re-injected.

The J-2 Range North Mobile Treatment Units (MTU) E & F continue to operate at a flow rate of 250 gpm. J-2 North MTU F was shut down at 1430 on 22 September 2008 in preparation of a ion exchange media (IX) change-out. The IX change-out occurred at 0800 on 23 September 2008; the system was restarted at 1730 on 23 September 2008. As of 29 September 2008, over 264 million gallons of water were treated and re-injected.

#### J-3 Range Groundwater RRA

The J-3 Range Groundwater RRA consists of removal and treatment of contaminated groundwater to control further migration of explosives and perchlorate. ETR systems include single extraction wells, ex-situ treatment processes to remove explosives and perchlorate from the groundwater and use of the existing Fuel Spill-12 (FS-12) infiltration gallery to return treated water to the aquifer.

The J-3 Range system continues to operate at a flow rate of 195 gpm. The J-3 System went down at 0407 on 31 August 2008 due to a high level in the storage tank in the FS-12 system; the system was restarted at 0818 on 2 September 2008 resulting in 52 hrs of down time. The system went down at 0218 on 7 September 2008 due to a power outage at the FS-12 plant; the system was restarted at 0832 on 8 September 2008 resulting in 30 hrs of down time. The system shut down again at 1850 on 12 September 2008 due to a power outage at the FS-12 plant; the system was restarted at 0755 on 15 September 2008 resulting in 61 hrs of down time. As of 26 September 2008, over 180 million gallons of water were treated and re-injected.

#### J-2 Range East Groundwater RRA

The J-2 Range East Groundwater RRA consists of removal and treatment of groundwater to minimize down gradient migration of explosives and perchlorate. The J-2 Range East Extraction, Treatment and Injection (ETI) system includes the following components: three extraction wells in an axial array, an ex-situ treatment process consisting of an IX resin and GAC media to treat perchlorate and explosives and three infiltration trenches located along the lateral boundaries of the plume where treated water will enter the vadose zone and infiltrate into the aquifer. J-2 Range East system start up continued through the month of September and as of 11 September 2008, is up and running at a combined total flow rate of 425 gpm.

The J-2 East MTUs H and I (treating water from EW 5) continue to operate at a flow rate of 210 gpm. MTUs H and I shutdown at 0715 on 23 September 2008 due to a power outage possibly caused by a tree limb across a phase wire at Rt. 130. The VFD was repaired on 26 September 2008 and the system was restarted at 1005 on 26 September 2008. As of 26 September 2008, over 3 million gallons of water were treated and re-injected

The J-2 East MTU K (treating water from EW 4) continues to operate at a flow rate of 90 gpm. MTU K shutdown at 0715 on 23 September 2008 due to a power outage possibly caused by a tree limb across a phase wire at Rt. 130. The system was restarted at 1536 on 23 September 2008. As of 26 September 2008, over 2 million gallons of water were treated and re-injected.

The J-2 East MTU J (treating water from EW 6) continues to operate at a flow rate of 125 gpm. MTU J shutdown at 0715 on 23 September 2008 due to a power outage possibly caused by a tree limb across a phase wire at Rt. 130. The system was restarted at 1538 on 23 September 2008. As of 26 September 2008, over 2.5 million gallons of water were treated and re-injected.

## 2. SUMMARY OF ACTIONS TAKEN

Samples collected during the reporting period are summarized in Table 2.

Process water samples were collected at Frank Perkins Road, Pew Road, J-2 Range North, J-3 Range and J-1 Range South treatment plants. Startup samples were collected from J-2 Range East treatment system in accordance with the *Final J-2 Range East System Performance Monitoring Plan* (13 February 2008).

The Fall 2008 system performance monitoring was completed for the Demo 1 study area and continued through September 2008 for the J-2 Range North study area. Surface water samples were collected from Snake Pond. Groundwater samples were collected from the Bourne Water District pumping stations.

Groundwater samples were collected from six drive point (DP) locations in the J-1 Range South study area and one location in the J-2 extension study area.

Multi Incremental soil samples were collected from the Juliet, Kilo and J-3 Range study areas. Post excavation BIP samples were collected from the J-2 North and CIA study areas.

There were 2 BIP items discovered during the field investigations at the J-2 Extension study area. One 30mm mortar and one 120mm practice mortar were detonated on 10 September 2008. Pre- and post-BIP samples were collected in accordance with the BIP sampling protocol.

---

### **MMR IAGWSP Tech Meeting Minutes 09-11-2008**

The following are notes from the 11 September 2008 Technical Team Meeting of the Impact Area Groundwater Study Program office at Camp Edwards:

#### **SE Ranges Update**

##### **J-1 Range South Drive Point Data – Dave Hill**

Drive points were installed at location C (DP-498) on Lady Slipper Lane. There was a single detection at DP-498 of 1.7 ppb at 155-160 feet below ground surface (bgs); there were three ND intervals below that detection which was expected at this location. At location B (DP-499) on Lady Slipper Lane, there were three intervals of detections with 5.3 ppb at 160-165 which indicates the mass in the plume is distributed a bit differently than expected. Location A (DP-500) was completed with ND in all intervals. IAGWSP is awaiting data on the very bottom sample.

IAGWSP suggests installing another drive point between MW-400 and MW-402 and, depending on the data, adding one somewhere in the south. Additional locations are being considered, including one each on Lichen Lane, Windsong Road, Little Acorn Lane and Grand Oak.

The next step is to go to location between MW-400 and MW-402 on Little Acorn Lane and, once all profiles are available, determine if additional monitoring wells are needed.

#### **Robotics Update – Bill Gallagher**

L Range - Continue clearing UXO using the Charrington Beach Cleaner attachment. Work is estimated to be 75% complete with five additional working days until completion (weather dependent).

Central Impact Area – Continue clearing vegetation, working eastward along Tank Alley Road. The EM-61 survey on the one acre ASTCP test plot is complete. ***Bill Gallagher (IAGWSP) will distribute an email summarizing the UXO found.***

#### **Kilo and Juliet – Comment Review and Resolution**

The Kilo Range Report has been revised in redline/strike out, addressing comments made by EPA and MassDEP, in preparation for this discussion and to facilitate quick turn around from Draft version to Final version.

A list of the Comment Response Actions (indicating comment identification, page, and action taken) was distributed. The Action Taken column listed where text was removed, and where it was changed.

The General Comments dealt with the issue of not making conclusions without the nitroglycerin sorption/desorption bench studies being done. Any reference to the studies or modeling the potential for nitroglycerin in surface soil to migrate to groundwater will be deleted, since soil containing nitroglycerin is presently being removed by MANG.

- Specific Comments
- In the text on Page 3-2, Section 3.1.1 there is a sentence inserted. . .identify which data results relate to discrete samples and which relate to composite samples and why. For example, averaging data is not acceptable to EPA; if using data together, the bootstrap technique to calculate the right number should be used. The alternative to that is not to combine the data, to show the data in a table and compare it to the action levels to be used.  
***Larry Cain (USACE) and TetraTech will review the risk assessment to confirm this was done and will document it in the report.***
- Page 3-3 relating to source of background. EPA's comment was to run all the compounds and discuss background, without screening anything out. The action taken: the reference was added per EPA request and EPA will review further.
- IAGWSP noted that anything related to CRREL, Kd, and leaching has been removed from entire document.
- Human Health Risk Assessment –***Data groupings – IAGWSP will include a step- by-step explanation or table that demonstrates how discrete and composite samples were used.***
- EPA questioned why the four sub areas (firing line range floor, another range floor, another firing line, and behind the target and berm face) were divided into 12 areas to be sampled.
- EPA asked if averages or maximums were compared to the backgrounds. IAGWSP noted the added text, EPA reviewed and agreed.
- The soil sampling effort included replicates to determine if the sampling approach is sound. If results are vastly different, the sampling and analytical process would be questioned. EPA suggests referring back to what percent RSD was agreed on in the project note and then determine how many samples fell within the percent RSD and how many didn't. The text should reference the project note.

- Changes for Specific Comments 22, 23 and 24 are in the Tables 3-1 and 3-2.

Additional Comments 1-16: EPA agreed with the comments.

MassDEP Comments:

- MassDEP noted this is an MCP site; and IAGWSP is using CERCLA guidance, as opposed to MCP risk assessment guidance. MassDEP requests a discussion in the text that states why the MCP is not being used.
- SC#3 and #9 – MassDEP agrees with revised text, and will have it reviewed by Henry Ciu.
- SC#10 - MassDEP noted the construction worker should be considered a current exposure (being considered future exposure right now). If there is disagreement, please explain.
- SC#13 – Regarding lead and the eco risk. MassDEP recommends removal of soil containing lead from behind the berm. IAGWSP noted this is a management decision to be made outside of the document and doesn't need to be included. MassDEP noted that a risk to the American Robin was identified; therefore, a resolution to eliminate this ecological risk has to be stated.
- SC#15 – Text change is fine; however, it doesn't discuss the next step.
- SC#16 – Requires answers for DEP risk assessor. If it is determined not applicable, explain why.
- SC#17 - MassDEP needs an explanation why no action was taken.
- SC#18 – RE: Unresolved comments MassDEP made on Tango on the frequency duration exposure of hunters - Please explain why the number MassDEP recommended is not being used.
- SC#19 – IAGWSP needs to justify the number used and it should be based on a realistic construction model (13 days a year up to 130 days per year – suggest going through the Base records to determine what is ideal).
- IAGWSP will provide responses via email on comments 16-19.

### IART Meeting for September 2008

The MMR Clean up Team (MMRCT), formerly the Impact Area Review Team (IART) and the Plume Cleanup Team (PCT) held a meeting on 10 September 2008. Discussion items included: Installation Restoration Program (IRP) updates, Impact Area Groundwater Study Program (IAGWSP) Remediation and Investigation updates, Massachusetts Army National Guard (MAARNG) Small Arms Range update and IAGWSP CIA briefing.

The next meeting will be held 10 October 2008. The agenda will include late breaking news and responses to action items, as well as updates from the IAGWSP, MAARNG and IRP. The MMRCT meetings provide a forum for community input regarding issues related to both the IRP and the IAGWSP.

### 3. SUMMARY OF DATA RECEIVED

Table 4 summarizes the detections in groundwater, since 1997, that equaled or exceeded an EPA Maximum Contaminant Level (MCL), MassDEP MCL (MMCL) or Health Advisory (HA) for drinking water. Table 4 is updated on a monthly basis; discussions in the text are updated on the same schedule as Figures 1 through 8, which are discussed later in this section.

Table 5 summarizes the validated detections of explosives and perchlorate for all groundwater results received from 01 September through 30 September 2008. These results are compared to the MCL/HA values for respective analytes. First-time validated detections of Volatile Organic Compounds (VOC), Semi-Volatile Organic Compounds (SVOC), metals, herbicides and

pesticides are included and discussed quarterly in the March, June, September, and December Monthly Progress Reports. Metals, chloroform, and bis (2-ethylhexyl) phthalate (BEHP) are excluded from Table 5 for the following reasons: metals are a natural component of groundwater, particularly at levels below MCLs or HAs; detections of chloroform are pervasive throughout Cape Cod and are not likely the result of military training activities; and BEHP is believed to be largely an artifact of the investigation methods and may be introduced to the samples during collection or analysis.

Figures 1 through 8 depict the cumulative results of groundwater analyses for the period from the start of the Impact Area Groundwater Study (1997) to the present. There are no new groundwater data to report for metals, VOC, SVOC, metals, pesticides or herbicides. The figures for this month's report are included on CD only. Each figure depicts results for a different analyte class:

- Figure 1 shows the results of explosive analyses by EPA Method 8330. This figure is updated and included each month.
- Figure 2 shows the results of inorganic analyses (collectively referred to as "metals", though some analytes are not true metals) by methods E200.8, 300.0, 350.2M, 353M, 365.2, CYAN, IM40MB, IM40MBM, and IM40HG. This figure is included quarterly in the March, June, September, and December Monthly Progress Reports.
- Figure 3 shows the results of VOC analyses by methods OC21V, OC21VM, 504, 8021W, and SW8260 exclusive of chloroform detections. This figure is included quarterly in the March, June, September, and December Monthly Progress Reports.
- Figure 4 shows the chloroform results using the VOC analyses by method OC21V and OC21VM. This figure is included semi-annually in the September and December Monthly Progress Reports.
- Figure 5 shows the results of SVOC analyses by methods OC21B and SW8270, exclusive of detections of BEHP. This figure is included quarterly in the March, June, September, and December Monthly Progress Reports.
- Figure 6 shows the BEHP results using the SVOC analyses by methods OC21B and SW8270. This figure is included semi-annually in the September and December Monthly Progress Reports.
- Figure 7 shows the results of Pesticide (method OL21P) and Herbicide (method 8151) analyses. This figure is included quarterly in the March, June, September, and December Monthly Progress Reports.
- Figure 8 shows the results of Perchlorate analysis by method E314.0. This figure is updated and included each month.

The concentrations from these analyses are depicted in Figures 1 through 8 compared to Maximum Contaminant Levels (MCLs) or Health Advisories (HAs) published by EPA for drinking water. The color coded legends are defined on each figure.

There are multiple labels listed for some wells in Figures 1 through 8, which indicate multiple well screens at different depths throughout the aquifer. The aquifer is approximately 200 to 300 feet thick in the study area. Well screens are positioned throughout this thickness based on various factors, including the results of groundwater profile samples, the geology, and projected locations of contaminants estimated by groundwater modeling. Generally, groundwater entering the top of the aquifer will move deeper into the aquifer as it moves radially outward from the top of the water table mound. Light blue dashed lines in Figures 1 through 8 depict water table contours. Groundwater generally moves perpendicular to these contours, starting at the center

of the 70-foot contour (the top of the mound) and moving radially outward. The rate of vertical groundwater flow deeper into the aquifer slows as groundwater moves away from the mound.

The results presented in Figures 1 through 8 are cumulative, which provides a historical perspective on the data rather than a depiction of current conditions. Any detection at a well that equals or exceeds the MCL/DWEL/HA results in the well having a red symbol, regardless of later detections at lower concentrations, or later non-detects. The difference between historical and current conditions is generally contributed to the effectiveness of remedial actions. ETR systems are in operation at Demo1, J-1 South, J-2 North, J-2 East and J-3 Ranges to treat contaminated groundwater in order to control further migration of explosives compounds and/or perchlorate.

Figure 1: Explosives Compounds in Groundwater Compared to MCLs/HAs

Changes in detection trends in groundwater samples collected during the fall 2008 system performance and long term monitoring sampling events at respective study areas are discussed in biweekly data updates (*Summary of Explosives and Perchlorate Results*).

Exceedances of drinking water criteria for explosives compounds have been indicated in seven general areas:

- Demo Area 1 (wells 19, 31, 34, 73, 76, 77, 114, 129, 139, 165, 210, and 211);
- Demo Area 2 (wells 16, 160, 259, 262, and 404);
- Former A Range (well 206);
- The Impact Area and CS-19 (wells 58MW0001, 58MW0002, 58MW0009E, 58MW0011D, 58MW0016B, 58MW0016C, 58MW0018B; and wells 1, 2, 23, 25, 37, 38, 40, 43, 85, 86, 87, 88, 89, 90, 91, 93, 95, 98, 99, 100, 101, 102, 105, 107, 111, 112, 113, 176, 178, 184, 201, 203, 204, 207, 209, 212, 223, 235, OW-1, OW-2, and OW-6);
- J Ranges and southeast of the J Ranges (wells 45, 58, 130, 132, 147, 153, 163, 164, 166, 171, 191, 193, 196, 198, 215, 218, 227, 232, 234, 247, 265, 289, 303, 306, 324, 326, 343, 360, 368, 369, 398, 477, 481, 485, 486, 487, and wells 90MW0022, 90MW0041, 90MW0054 and 90WT0013); and
- Northwest Corner of Base Boundary (well 323).

Exceedances of drinking water criteria were measured for TNT at Demo Area 1 (MW-19S, MW-31S, MW-31M, and MW-31D) and Southeast of the Ranges (MW-196S). Exceedances of the HA for RDX were noted at all of the locations listed above except at MW-45. An exceedance of drinking water criterion was measured for 2,6-dinitrotoluene (2,6-DNT) in one sample collected from MW-45S.

Demo Area 1 has a single well-defined source area and extent of contamination. As noted in Section 1 above, ETR systems at Frank Perkins Road and Pew Road in the Demo 1 study area include extraction wells, ex-situ treatment processes to remove explosives and perchlorate from the groundwater, and injection wells to return treated water to the aquifer.

Demo Area 2 has had groundwater exceedances of the RDX HA at MW-16S, MW-160S, MW-259, MW-262M1, and MW-404M2. The extent of the contamination is currently under investigation.

The Former A Range has had exceedances of the RDX HA at MW-206M1. The S screen in this location is non-detect for all explosives.

The Impact Area has a plume defined by RDX concentrations above the HA of 2 ppb. The plume originates primarily along Turpentine Road and extends downgradient to the west-northwest. Another source of RDX in the Impact Area is CS-19. Portions of CS-19 are currently under investigation by the Air Force Center for Environmental Excellence (AFCEE) under the Superfund program.

The Southeast Ranges have several groundwater plumes defined by concentrations of RDX and/or perchlorate above the HA of 2 ppb. Identified RDX plumes include:, J-2 Range North, J-3 Range, J-1 Range South, J-2 Range East, J-1 Range North and L Range. Groundwater treatment systems are currently in place and operational at J-1 Range South, J-2 Range North, J-3 Range and J-2 Range East.

The Northwest Corner of the base boundary has validated detections of RDX in groundwater above the HA of 2 ppb at MW-323M2. The M1 screen in this location has validated detections of RDX in groundwater below 2 ppb. The S screen at this location is non-detect for explosives.

Figure 2: Metals in Groundwater Compared to MCLs/HAs

Exceedances of drinking water criteria for metals are scattered throughout the study area. Where two or more rounds of sampling data are available, the exceedances generally have not been replicated in consecutive sampling rounds. The exceedances have been measured for antimony, arsenic, cadmium, chromium, lead, molybdenum, sodium, thallium and zinc. Exceedances of the arsenic drinking water criteria were repeated at three (wells 58MW0010A, MW-7M1 and MW-45S) of the six locations with arsenic exceedances. At the remaining three locations (wells MW-3D, MW-52M2 and MW-152M1), arsenic exceedances were not repeated in subsequent results. Cadmium (well MW-52M3) and chromium (well MW-7M1) were each detected above drinking water criteria in a single sampling round in September-September 1999. Exceedances of the drinking water criteria for lead were repeated at two of four locations (wells ASP and MW-45S). At the remaining two locations (wells MW-2S and MW-7M1) lead exceedances were not repeated in subsequent results. Exceedances of the drinking water criteria for molybdenum were repeated at two of eight locations (wells MW-53M1 and MW-54S) with molybdenum exceedances. All of the molybdenum exceedances were observed in year 1998 and 1999 results. Exceedances of the drinking water criteria for sodium were repeated at 12 of the 21 locations with sodium exceedances (wells MW-2S, MW-21S, MW-46S, MW-57M3, MW-57M2, MW-57M1, MW-144S, MW-145S, MW-148S, MW-187D, ASP and SDW261160). Seven wells (MW-21S, MW-57M1, MW-57M3, MW-187D, BHW215083B, BHW215083D and ASP) had sodium exceedances in year 2004, 2005, and/or 2006 results. Zinc exceeded the HA in seven wells, all of which are constructed of galvanized (zinc-coated) steel.

Groundwater samples sent for target analyte metals analysis are analyzed by Inductively Coupled Plasma (ICP) in accordance with EPA method SW846/6010 with the exception of thallium and antimony. Groundwater samples submitted for antimony and/or thallium analysis are analyzed by Inductively Coupled Plasma/Mass Spectroscopy (ICP/MS) in accordance with the EPA Method SW846/6020. The ICP/MS Method 6020 has greater sensitivity, lower detection limits and the added feature of selectivity for antimony and thallium.

There have been few exceedances of drinking water limits for antimony and thallium since the introduction of more sensitive methods. Antimony levels exceeding drinking water criteria were detected in samples from 13 locations; these levels were not detected in subsequent sampling rounds. Only two antimony exceedances (wells MW-38M2 and MW-73S) were measured since

January 2003. Twelve of the 71 locations with thallium exceedances had repeated exceedances in subsequent sampling rounds (wells MW-7M1, MW-7M2, MW-19S, MW-45S, MW-47M2, MW-47M3, MW-52S, MW-52D, MW-54S, MW-54M1, MW-58S and MW-94M2). There have been no exceedances of thallium since January 2003.

The distribution and lack of repeatability of the metals exceedances is not consistent with a contaminant source, nor do the detections appear to be correlated with the presence of explosives or other organic compounds. The IAGWSP evaluated inorganic background concentrations using the groundwater quality database of 1999, and submitted a draft report describing background groundwater quality in December 1999.

Figure 3: VOCs in Groundwater Compared to MCLs/HAs

Exceedances of drinking water criteria for VOCs are indicated in six general areas: Northeast Corner (well LRMW003), Impact Area boundary (MW-28S), CS-10 (wells 03MW0007A, 03MW0014A, and 03MW0020), FS-12 (wells MW-45S, 90MW0003, and ECMWSNP02D), and in the J-1 Range (well MW-187D). CS-10, LF-1 and FS-12 are sites located near the southern extent of the Training Ranges that are currently under investigation by AFCEE under the Superfund program. Exceedances of drinking water criteria were measured for tetrachloroethylene (PCE) at CS-10, for vinyl chloride at LF-1, and for methylene chloride, toluene, 1,2-dichloroethane, and ethylene dibromide (EDB) at FS-12. These compounds are believed to be associated with the sites under investigation by AFCEE; these sites currently have active treatment systems in place.

Figure 4: Chloroform in Groundwater Compared to MCLs

Chloroform has been widely detected in groundwater across the Upper Cape as stated in a joint press release from USEPA, MassDEP, IRP, and the Joint Programs Office. The Cape Cod Commission (2001) in their review of public water supply wells for 1999 found greater than 75% contained chloroform with an average concentration of 4.7 ug/L. The IRP has concluded chloroform is not the result of Air Force activities. A detailed discussion of the presence of chloroform is provided in the Final Central Impact Area Groundwater Report (06/01).

Figure 5: SVOCs in Groundwater Compared to MCLs/HAs

Exceedances of drinking water criteria for SVOCs are scattered throughout the study area. All exceedances of drinking water criteria for SVOCs were measured for bis (2-ethylhexyl) phthalate (BEHP), with the exception of two wells. MW-264M1 (J-3 Range) had a detection of benzo(a)pyrene at concentrations of more than twice the HA and MW-241M1 (L Range) had detections of naphthalene above the HA of 100 ppb. Detections of BEHP are presented separately in Figure 6 and discussed in the next paragraph.

Figure 6: BEHP in Groundwater Compared to MCLs

Exceedances of drinking water criteria for bis (2-ethylhexyl) phthalate (BEHP) are scattered throughout the study area. BEHP is believed to be largely an artifact of the investigation methods and may be introduced to the samples during collection or analysis. However, the potential that some of the detections of BEHP are the result of activities conducted at MMR has not been ruled out.

A detailed discussion of the presence of BEHP is provided in the Draft Completion of Work Report (7/98) and subsequent responses to comments. The theory that BEHP mostly occurs as an artifact, and is not really present in the aquifer, is supported by the results of subsequent sampling rounds that show much lower levels of the chemical after additional precautions were taken to prevent cross-contamination during sample collection and analysis. Only four locations (out of 93) showed BEHP exceedances in consecutive sampling rounds: 28MW0106 (located near SD-5, a site under investigation by AFCCEE), 58MW0006E (located at CS-19), 90WT0013 (located at FS-12), and MW-146M1 (located at L Range). Subsequent sampling rounds at all these locations have had results below the MCL. Eleven wells (27MW0705, 27MW2061, C2-B, C6-C, C7-B, MW-47M2, MW-164M1, MW-168M1, MW-188M1, MW-196M1, and MW-198M1) had BEHP exceedances in the year 2002 and 2003 results. There have been no exceedances of BEHP in 2004, one exceedance of BEHP, at MW-356M1 (J-3 Range), in 2005, and one exceedance of BEHP, at MW-477M2 (J-1 Range), in 2007.

Figure 7: Herbicides and Pesticides in Groundwater Compared to MCLs/HAs

There has been one exceedance of drinking water criteria for pesticides, at well PPAWSMW-1. A contractor to the United States Air Force installed this monitoring well at the PAVE PAWS radar station in accordance with the Massachusetts Contingency Plan (MCP), in order to evaluate contamination from a fuel spill. The exceedance was for the pesticide dieldrin in a sample collected in September 1999. This well was sampled again in November 1999. The results of the November sample indicate no detectable pesticides although hydrocarbon interference was noted. It appears from the November sample that pesticides identified in the September sample were false positives.

There has been one exceedance of drinking water criteria for herbicides, at well MW-41M1 (Impact Area). This response well was installed downgradient of the Impact Area. The exceedance was for the herbicide pentachlorophenol in a sample collected in September 2000. There were no detections above the MCL of this compound in the three previous sampling rounds in 1999, nor in the subsequent sampling rounds in 2000, 2001, 2002, and 2003.

Figure 8: Perchlorate in Groundwater Compared to a 2 ppb Concentration

Changes in detection trends in groundwater samples collected during the fall 2008 system performance and long term monitoring sampling events at respective study areas are discussed in biweekly data updates (*Summary of Explosives and Perchlorate Results*).

Sampling and analysis of groundwater for perchlorate was initiated at the end of the year 2000 as part of the IAGWSP. Cumulative exceedances of the 2 ppb concentration of perchlorate have been indicated in seven general areas:

- Demo Area 1 (wells 19, 31, 32, 33, 34, 35, 36, 73, 75, 76, 77, 78, 114, 129, 139, 162, 165, 172, 210, 211, 225, 255, 258 and 341);
- Impact Area and CS-19 (wells 58MW0009C, 58MW0015; and wells 38, 89, 91, 93, 101, and OW-1);
- J Ranges and southeast of the J Ranges (wells 93, 125, 127, 128, 130, 132, 142, 143, 158, 163, 166, 193, 197, 198, 215, 232, 234, 237, 243, 247, 250, 263, 265, 286, 289, 293, 295, 300, 302, 303, 305, 307, 310, 313, 319, 321, 324, 326, 329, 335, 339, 343, 346, 348, 366, 368, 370, 393, and wells 90PZ0211, 90MW0022 and 90MW0054, 90WT0013, J2EW3-MW-2-B, and RS003P);

- Northwest Corner of Base Boundary (wells 4036009DC, 66, 270, 277, 278, 279, 283, 284, 287, 297, 301, 309, 323, and RSN0W3); and
- Western Boundary (wells 80, 233, and 267).

Demo Area 1 has a single well-defined source area and extent of contamination. As noted in Section 1 above; ETR systems at Frank Perkins Road and Pew Road in the Demo 1 study area include extraction wells, ex-situ treatment processes to remove explosives and perchlorate from the groundwater, and injection wells to return treated water to the aquifer.

The Impact Area has had eight locations with exceedances of the 2 ppb concentration of perchlorate. The perchlorate plume extends from near the center of the Impact Area to the northwest, in the vicinity of Burgoyne Road.

The Southeast Ranges have several groundwater plumes defined by concentrations of RDX and/or perchlorate above the HA of 2 ppb. Perchlorate plumes have been identified in four areas in the Southeast Ranges. Identified perchlorate plumes include: J-2 Range North, J-3 Range and J-2 Range East. Groundwater treatment systems are currently in place and operational at J-2 Range North, J-3 Range and J-2 Range East.

The Northwest Corner has a perchlorate plume extending from Canal View Road at the base boundary to the Cape Cod Canal. This area is under investigation and the plume will be updated and refined as new data is received.

The Western Boundary has had three locations (MW-80M1, MW-233M3, and MW-267M1) which have exceeded the 2 ppb perchlorate MMCL in one or more sampling rounds. Only MW-233M3 has perchlorate detected above the 2ppb MMCL in the most recent sampling round (3/28/08). The perchlorate results for other Western Boundary wells are all below the MMCL.

#### 4. DELIVERABLES SUBMITTED

Deliverables submitted during the reporting period include the following:

Monthly Progress Report No. 137 August 2008	09/10/2008
Responses to EPA Comments on the J-3 Range GW RRA 2007 Annual <i>SPEIM Report</i>	09/04/2008
Final J-2 Extension Follow-on Soil Investigation Project Note	09/17/2008
Response to Comments (RCL) on the J-2 Range North GW RRA 2007 Annual <i>Report</i>	09/26/2008

#### 5. SCHEDULED ACTIONS

Figure 9 provides a Gantt chart updated as of 02 February 2008, to reflect progress and proposed work. This figure has not changed since the last report and is included on CD only.

The following documents are being prepared or revised during September:

- J-1 Range South Soil/Groundwater Final Remedial Investigation/Feasibility Study Report
- J-2 Range Groundwater Interim Remedial Investigation/Feasibility Study Report
- J-3 Range Groundwater Interim Remedial Investigation/Feasibility Study Report
- L Range South Soil/Groundwater Draft Remedial Investigation/Feasibility Study Report

**TABLE 2**  
**Sampling Progress**  
**1 September 2008- 30 September 2008**

Area of Concern	Location	Fld Sampid	Logdate	Logtime	Sample Type	Matrix	SBD	SED
Demo 1	MW-225M2	MW-225M2_FAL08	9/2/2008	1255	N1	Groundwater	145	155
Demo 1	MW-225M3	MW-225M3_FAL08	9/2/2008	1345	N1	Groundwater	125	135
Demo 1	MW-225M3	MW-225M3_FAL08D	9/2/2008	1345	FD1	Groundwater	125	135
Demo 1	MW-252M1	MW-252M1_FAL08	9/2/2008	1505	N1	Groundwater	174	184
Demo 1	MW-252M2	MW-252M2_FAL08	9/2/2008	1550	N1	Groundwater	145	155
Juliet Range	SSJRMFBF	JRMBF_AF	9/2/2008	1514	N1	Multi Increment Sample	2.75	3
Demo 1	MW-248M3	MW-248M3_FAL08	9/3/2008	1240	N1	Groundwater	143	153
Demo 1	MW-252M3	MW-252M3_FAL08	9/3/2008	850	N1	Groundwater	115	125
Demo 1	MW-258M1	MW-258M1_FAL08	9/3/2008	940	N1	Groundwater	109	119
Demo 1	MW-258M1	MW-258M1_FAL08D	9/3/2008	940	FD1	Groundwater	109	119
Demo 1	MW-258M2	MW-258M2_FAL08	9/3/2008	1030	N1	Groundwater	87	92
Demo 1	MW-258M3	MW-258M3_FAL08	9/3/2008	1125	N1	Groundwater	77	82
Demo 1	MW-352M1	MW-352M1_FAL08	9/3/2008	1330	N1	Groundwater	115	125
Demo 1	MW-352M2	MW-352M2_FAL08	9/3/2008	1415	N1	Groundwater	65	75
Demo 1	MW-352M3	MW-352M3_FAL08	9/3/2008	1155	N1	Groundwater	43	53
Demo 1	MW-353M1	MW-353M1_FAL08	9/4/2008	1245	N1	Groundwater	107	117
Demo 1	MW-353M2	MW-353M2_FAL08	9/4/2008	1320	N1	Groundwater	57	67
Demo 1	MW-353M3	MW-353M3_FAL08	9/4/2008	1400	N1	Groundwater	35	45
J-2 North	SSJ2N3902	J2N39T09_PO	9/4/2008	855	N1	Soil Grab	2.5	3
Snake Pond	LKSNK0005	LKSNK0005_0908A	9/4/2008	905	N1	Surface Water	0	0.25
Snake Pond	LKSNK0006	LKSNK0006_0908A	9/4/2008	918	N1	Surface Water	0	0.25
Snake Pond	LKSNK0007	LKSNK0007_0908A	9/4/2008	840	N1	Surface Water	0	0.25
CIA	SSCIADP007	CIADP007_PE7	9/5/2008	840	N1	Soil Grab	3	3.25
CIA	SSCIADP007	CIADP007_PE8	9/5/2008	842	N1	Soil Grab	3	3.25
J-2 North	SSJ2B2004	J2B2004_PE4	9/5/2008	930	N1	Soil Grab	2	2.25
J-2 North	SSJ2B2004	J2B2004_PE5	9/5/2008	932	N1	Soil Grab	2	2.25
J-2 North	SSJ2B2004	J2B2004_PE6	9/5/2008	934	N1	Soil Grab	2	2.25
J-2 North	SSJ2O32006	J2O32006_PE4	9/5/2008	908	N1	Soil Grab	2	2.25
J-2 North	SSJ2O32006	J2O32006_PE5	9/5/2008	911	N1	Soil Grab	2	2.25
Juliet Range	SSJ2FL1	JRFL1_CA	9/5/2008	1252	N1	Multi Increment Sample	1	1.25
Juliet Range	SSJ2FL2	JRFL2_CA	9/5/2008	1256	N1	Multi Increment Sample	1	1.25
Juliet Range	SSJ2FL3	JRFL3_CA	9/5/2008	1226	N1	Multi Increment Sample	1	1.25
Juliet Range	SSJRRF1	JRRF1_CA	9/5/2008	1322	N1	Multi Increment Sample	1	1.25
Juliet Range	SSJRRF2	JRRF2_CA	9/5/2008	1320	N1	Multi Increment Sample	1	1.25
Juliet Range	SSJRRF3	JRRF3_CA	9/5/2008	1344	N1	Multi Increment Sample	1	1.25
Kilo Range	TTSARKRFL1	KRFL1_CA	9/5/2008	1415	N1	Multi Increment Sample	1	1.25
Demo 1	FPR-2-EFF	FPR2-EFF-29A	9/8/2008	11:45	N1	Process Water	0	0
Demo 1	FPR-2-GAC-MID1A	FPR2-GAC-MID-1A-29A	9/8/2008	11:35	N1	Process Water	0	0
Demo 1	FPR-2-GAC-MID1B	FPR2-GAC-MID-1B-29A	9/8/2008	11:40	N1	Process Water	0	0
Demo 1	FPR-2-INF	FPR2-INF-29A	9/8/2008	11:20	N1	Process Water	0	0
Demo 1	FPR-2-IX-MID-A	FPR2-IX-MID-A-29A	9/8/2008	11:25	N1	Process Water	0	0
Demo 1	FPR-2-IX-MID-B	FPR2-IX-MID-B-29A	9/8/2008	11:30	N1	Process Water	0	0
J-1 South	J1S-EFF	J1S-EFF-10A	9/8/2008	14:10	N1	Process Water	0	0
J-1 South	J1S-INF	J1S-INF-10A	9/8/2008	14:00	N1	Process Water	0	0
J-1 South	J1S-MID	J1S-MID-10A	9/8/2008	14:05	N1	Process Water	0	0
J-2 North	J2N-EFF-EF	J2N-EFF-EF-24A	9/8/2008	11:55	N1	Process Water	0	0
J-2 North	J2N-EFF-G	J2N-EFF-G-24A	9/8/2008	10:55	N1	Process Water	0	0
J-2 North	J2N-INF	J2N-INF-E-24A	9/8/2008	11:25	N1	Process Water	0	0
J-2 North	J2N-INF-G	J2N-INF-G-24A	9/8/2008	10:40	N1	Process Water	0	0
J-2 North	J2N-MID-1E	J2N-MID-1E-24A	9/8/2008	11:30	N1	Process Water	0	0
J-2 North	J2N-MID-1F	J2N-MID-1F-24A	9/8/2008	11:45	N1	Process Water	0	0
J-2 North	J2N-MID-1G	J2N-MID-1G-24A	9/8/2008	10:45	N1	Process Water	0	0
J-2 North	J2N-MID-2E	J2N-MID-2E-24A	9/8/2008	11:35	N1	Process Water	0	0
J-2 North	J2N-MID-2F	J2N-MID-2F-24A	9/8/2008	11:50	N1	Process Water	0	0
J-2 North	J2N-MID-2G	J2N-MID-2G-24A	9/8/2008	10:50	N1	Process Water	0	0
J-3 Range	J3-EFF	J3-EFF-24A	9/8/2008	14:40	N1	Process Water	0	0
J-3 Range	J3-INF	J3-INF-24A	9/8/2008	14:25	N1	Process Water	0	0

**TABLE 2**  
**Sampling Progress**  
**1 September 2008- 30 September 2008**

Area of Concern	Location	Fld Sampid	Logdate	Logtime	Sample Type	Matrix	SBD	SED
J-3 Range	J3-MID-1	J3-MID-1-24A	9/8/2008	14:30	N1	Process Water	0	0
J-3 Range	J3-MID-2	J3-MID-2-24A	9/8/2008	14:35	N1	Process Water	0	0
Demo 1	PR-EFF	PR-EFF-29A	9/8/2008	10:40	N1	Process Water	0	0
Demo 1	PR-INF	PR-INF-29A	9/8/2008	10:25	N1	Process Water	0	0
Demo 1	PR-MID-1	PR-MID-1-29A	9/8/2008	10:30	N1	Process Water	0	0
Demo 1	PR-MID-2	PR-MID-2-29A	9/8/2008	10:35	N1	Process Water	0	0
J-2 North	MW-300M1	MW-300M1_F08	9/9/2008	1150	N1	Groundwater	293	303
J-2 North	MW-300M2	MW-300M2_F08	9/9/2008	1235	N1	Groundwater	197.23	207.23
J-2 North	MW-300M2	MW-300M2_F08D	9/9/2008	1235	FD1	Groundwater	197.23	207.23
J-2 North	MW-300M3	MW-300M3_F08	9/9/2008	1450	N1	Groundwater	135.31	145.31
J-2 North	MW-302M1	MW-302M1_F08	9/9/2008	925	N1	Groundwater	300	310
J-2 North	MW-302M2	MW-302M2_F08	9/9/2008	1005	N1	Groundwater	194	204
J-2 North	J2EW0001	J2EW0001_F08	9/10/2008	1438	N1	Groundwater	179	234
J-2 North	J2EW0001	J2EW0001_F08FD	9/10/2008	1438	FD1	Groundwater	179	234
J-2 North	J2EW0002	J2EW0002_F08	9/10/2008	1420	N1	Groundwater	198	233
J-2 North	J2EW0003	J2EW0003_F08	9/10/2008	1350	N1	Groundwater	202	232
J-2 North	SSJ2N3602	J2N3602_PO	9/10/2008	959	N1	Soil Crater	0	0.25
J-2 North	SSJ2N3602	J2N3602_PR	9/10/2008	816	N1	Soil Grid	0	0.25
J-2 North	SSJ2O4402	J2O4402_PO	9/10/2008	1010	N1	Soil Crater	0	0.25
J-2 North	SSJ2O4402	J2O4402_PR	9/10/2008	818	N1	Soil Grid	0	0.25
J-2 North	MW-322M1	MW-322M1_F08	9/11/2008	1050	N1	Groundwater	245	255
J-2 North	MW-337M1	MW-337M1_F08	9/11/2008	1350	N1	Groundwater	244	254
J-2 North	MW-381M1	MW-381M1_F08	9/11/2008	1140	N1	Groundwater	233	243
J-2 North	MW-381M2	MW-381M2_F08	9/11/2008	1220	N1	Groundwater	197	207
J-2 East	J2E-EFF-IH	J2E-EFF-IH-D1-1A	9/11/2008	13:45	N1	Process Water	0	0
J-2 East	J2E-EFF-J	J2E-EFF-J-D1-1A	9/11/2008	15:05	N1	Process Water	0	0
J-2 East	J2E-EFF-K	J2E-EFF-K-D1-1A	9/11/2008	14:35	N1	Process Water	0	0
J-2 East	J2E-INF-I	J2E-INF-I-D1-1A	9/11/2008	13:30	N1	Process Water	0	0
J-2 East	J2E-INF-J	J2E-INF-J-D1-1A	9/11/2008	14:50	N1	Process Water	0	0
J-2 East	J2E-INF-K	J2E-INF-K-D1-1A	9/11/2008	14:20	N1	Process Water	0	0
J-2 East	J2E-MID-1H	J2E-MID-1H-D1-1A	9/11/2008	13:50	N1	Process Water	0	0
J-2 East	J2E-MID-1I	J2E-MID-1I-D1-1A	9/11/2008	13:35	N1	Process Water	0	0
J-2 East	J2E-MID-1J	J2E-MID-1J-D1-1A	9/11/2008	14:55	N1	Process Water	0	0
J-2 East	J2E-MID-1K	J2E-MID-1K-D1-1A	9/11/2008	14:25	N1	Process Water	0	0
J-2 East	J2E-MID-2H	J2E-MID-2H-D1-1A	9/11/2008	14:00	N1	Process Water	0	0
J-2 East	J2E-MID-2I	J2E-MID-2I-D1-1A	9/11/2008	13:40	N1	Process Water	0	0
J-2 East	J2E-MID-2J	J2E-MID-2J-D1-1A	9/11/2008	15:00	N1	Process Water	0	0
J-2 East	J2E-MID-2K	J2E-MID-2K-D1-1A	9/11/2008	14:30	N1	Process Water	0	0
J-2 North	MW-313M1	MW-313M1_F08	9/12/2008	1015	N1	Groundwater	255	265
J-2 North	MW-313M2	MW-313M2_F08	9/12/2008	1050	N1	Groundwater	215	225
J-2 North	MW-313M3	MW-313M3_F08	9/12/2008	1150	N1	Groundwater	195	205
J-2 East	J2E-EFF-IH	J2E-EFF-IH-D2-1A	9/12/2008	9:15	N1	Process Water	0	0
J-2 East	J2E-EFF-J	J2E-EFF-J-D2-1A	9/12/2008	10:45	N1	Process Water	0	0
J-2 East	J2E-EFF-K	J2E-EFF-K-D2-1A	9/12/2008	10:05	N1	Process Water	0	0
J-2 East	J2E-INF-I	J2E-INF-I-D2-1A	9/12/2008	9:00	N1	Process Water	0	0
J-2 East	J2E-INF-J	J2E-INF-J-D2-1A	9/12/2008	10:30	N1	Process Water	0	0
J-2 East	J2E-INF-K	J2E-INF-K-D2-1A	9/12/2008	9:50	N1	Process Water	0	0
J-2 East	J2E-MID-1H	J2E-MID-1H-D2-1A	9/12/2008	9:20	N1	Process Water	0	0
J-2 East	J2E-MID-1I	J2E-MID-1I-D2-1A	9/12/2008	9:05	N1	Process Water	0	0
J-2 East	J2E-MID-1J	J2E-MID-1J-D2-1A	9/12/2008	10:35	N1	Process Water	0	0
J-2 East	J2E-MID-1K	J2E-MID-1K-D2-1A	9/12/2008	9:55	N1	Process Water	0	0
J-2 East	J2E-MID-2H	J2E-MID-2H-D2-1A	9/12/2008	9:25	N1	Process Water	0	0
J-2 East	J2E-MID-2I	J2E-MID-2I-D2-1A	9/12/2008	9:10	N1	Process Water	0	0
J-2 East	J2E-MID-2J	J2E-MID-2J-D2-1A	9/12/2008	10:40	N1	Process Water	0	0
J-2 East	J2E-MID-2K	J2E-MID-2K-D2-1A	9/12/2008	10:00	N1	Process Water	0	0
J-2 East	J2E-EFF-IH	J2E-EFF-IH-D3-1A	9/13/2008	11:00	N1	Process Water	0	0
J-2 East	J2E-EFF-J	J2E-EFF-J-D3-1A	9/13/2008	12:40	N1	Process Water	0	0

**TABLE 2**  
**Sampling Progress**  
**1 September 2008- 30 September 2008**

Area of Concern	Location	Fld Sampid	Logdate	Logtime	Sample Type	Matrix	SBD	SED
J-2 East	J2E-EFF-K	J2E-EFF-K-D3-1A	9/13/2008	13:50	N1	Process Water	0	0
J-2 East	J2E-INF-I	J2E-INF-I-D3-1A	9/13/2008	10:45	N1	Process Water	0	0
J-2 East	J2E-INF-J	J2E-INF-J-D3-1A	9/13/2008	12:25	N1	Process Water	0	0
J-2 East	J2E-INF-K	J2E-INF-K-D3-1A	9/13/2008	13:35	N1	Process Water	0	0
J-2 East	J2E-MID-1H	J2E-MID-1H-D3-1A	9/13/2008	11:20	N1	Process Water	0	0
J-2 East	J2E-MID-1I	J2E-MID-1I-D3-1A	9/13/2008	10:50	N1	Process Water	0	0
J-2 East	J2E-MID-1J	J2E-MID-1J-D3-1A	9/13/2008	12:30	N1	Process Water	0	0
J-2 East	J2E-MID-1K	J2E-MID-1K-D3-1A	9/13/2008	13:40	N1	Process Water	0	0
J-2 East	J2E-MID-2H	J2E-MID-2H-D3-1A	9/13/2008	11:25	N1	Process Water	0	0
J-2 East	J2E-MID-2I	J2E-MID-2I-D3-1A	9/13/2008	10:55	N1	Process Water	0	0
J-2 East	J2E-MID-2J	J2E-MID-2J-D3-1A	9/13/2008	12:35	N1	Process Water	0	0
J-2 East	J2E-MID-2K	J2E-MID-2K-D3-1A	9/13/2008	13:45	N1	Process Water	0	0
J-2 East	J2E-EFF-IH	J2E-EFF-IH-D4-1A	9/14/2008	11:25	N1	Process Water	0	0
J-2 East	J2E-EFF-J	J2E-EFF-J-D4-1A	9/14/2008	12:55	N1	Process Water	0	0
J-2 East	J2E-EFF-K	J2E-EFF-K-D4-1A	9/14/2008	12:15	N1	Process Water	0	0
J-2 East	J2E-INF-I	J2E-INF-I-D4-1A	9/14/2008	11:10	N1	Process Water	0	0
J-2 East	J2E-INF-J	J2E-INF-J-D4-1A	9/14/2008	12:40	N1	Process Water	0	0
J-2 East	J2E-INF-K	J2E-INF-K-D4-1A	9/14/2008	12:00	N1	Process Water	0	0
J-2 East	J2E-MID-1H	J2E-MID-1H-D4-1A	9/14/2008	11:30	N1	Process Water	0	0
J-2 East	J2E-MID-1I	J2E-MID-1I-D4-1A	9/14/2008	11:15	N1	Process Water	0	0
J-2 East	J2E-MID-1J	J2E-MID-1J-D4-1A	9/14/2008	12:45	N1	Process Water	0	0
J-2 East	J2E-MID-1K	J2E-MID-1K-D4-1A	9/14/2008	12:05	N1	Process Water	0	0
J-2 East	J2E-MID-2H	J2E-MID-2H-D4-1A	9/14/2008	11:35	N1	Process Water	0	0
J-2 East	J2E-MID-2I	J2E-MID-2I-D4-1A	9/14/2008	11:20	N1	Process Water	0	0
J-2 East	J2E-MID-2J	J2E-MID-2J-D4-1A	9/14/2008	12:50	N1	Process Water	0	0
J-2 East	J2E-MID-2K	J2E-MID-2K-D4-1A	9/14/2008	12:10	N1	Process Water	0	0
J-3 Range	SSJ3DA01	J3DA01_100A	9/15/2008	1115	N1	Multi Increment Sample	0	0.25
J-3 Range	SSJ3DA01	J3DA01_100B	9/15/2008	1330	N1	Multi Increment Sample	0.75	1
J-3 Range	SSJ3DA02	J3DA02_030A	9/15/2008	1520	N1	Multi Increment Sample	0	0.25
J-3 Range	SSJ3GPTA01	J3GPTA01_030A	9/15/2008	1350	N1	Multi Increment Sample	0	0.25
J-3 Range	SSJ3GPTA01	J3GPTA01_030AR1	9/15/2008	1355	N1	Multi Increment Sample	0	0.25
J-3 Range	SSJ3GPTA01	J3GPTA01_030AR2	9/15/2008	1405	N1	Multi Increment Sample	0	0.25
J-3 Range	SSJ3GPTA01	J3GPTA01_030B	9/15/2008	1410	N1	Multi Increment Sample	0.75	1
J-3 Range	SSJ3RCTDU1	J3RCTDU1_030A	9/15/2008	1435	N1	Multi Increment Sample	0	0.25
J-3 Range	SSJ3RCTDU1	J3RCTDU1_030B	9/15/2008	1450	N1	Multi Increment Sample	0.75	1
J-3 Range	SSJ3RCTDU2	J3RCTDU2_030A	9/15/2008	1500	N1	Multi Increment Sample	0	0.25
J-3 Range	SSJ3RCTDU2	J3RCTDU2_030B	9/15/2008	1532	N1	Multi Increment Sample	0.75	1
Kilo Range	TTSARKRRF4	KRRF4_CA	9/15/2008	1410	N1	Multi Increment Sample	0.5	0.75
J-2 East	J2E-EFF-IH	J2E-EFF-IH-D5-1A	9/15/2008	9:35	N1	Process Water	0	0
J-2 East	J2E-EFF-J	J2E-EFF-J-D5-1A	9/15/2008	11:25	N1	Process Water	0	0
J-2 East	J2E-EFF-K	J2E-EFF-K-D5-1A	9/15/2008	10:45	N1	Process Water	0	0
J-2 East	J2E-INF-I	J2E-INF-I-D5-1A	9/15/2008	9:20	N1	Process Water	0	0
J-2 East	J2E-INF-J	J2E-INF-J-D5-1A	9/15/2008	11:10	N1	Process Water	0	0
J-2 East	J2E-INF-K	J2E-INF-K-D5-1A	9/15/2008	10:30	N1	Process Water	0	0
J-2 East	J2E-MID-1H	J2E-MID-1H-D5-1A	9/15/2008	9:40	N1	Process Water	0	0
J-2 East	J2E-MID-1I	J2E-MID-1I-D5-1A	9/15/2008	9:25	N1	Process Water	0	0
J-2 East	J2E-MID-1J	J2E-MID-1J-D5-1A	9/15/2008	11:15	N1	Process Water	0	0
J-2 East	J2E-MID-1K	J2E-MID-1K-D5-1A	9/15/2008	10:35	N1	Process Water	0	0
J-2 East	J2E-MID-2H	J2E-MID-2H-D5-1A	9/15/2008	9:45	N1	Process Water	0	0
J-2 East	J2E-MID-2I	J2E-MID-2I-D5-1A	9/15/2008	9:30	N1	Process Water	0	0
J-2 East	J2E-MID-2J	J2E-MID-2J-D5-1A	9/15/2008	11:20	N1	Process Water	0	0
J-2 East	J2E-MID-2K	J2E-MID-2K-D5-1A	9/15/2008	10:40	N1	Process Water	0	0
J-2 North	MW-318M1	MW-318M1_F08	9/17/2008	1255	N1	Groundwater	305	315
J-2 North	MW-318M2	MW-318M2_F08	9/17/2008	1335	N1	Groundwater	205	215
J-2 North	MW-331M1	MW-331M2_F08	9/17/2008	1120	N1	Groundwater	235	245
J-2 North	MW-331M2	MW-331M2_F08	9/17/2008	1200	N1	Groundwater	195	205
J-2 North	MW-130D	MW-130D_F08	9/18/2008	1030	N1	Groundwater	320	330

**TABLE 2**  
**Sampling Progress**  
**1 September 2008- 30 September 2008**

Area of Concern	Location	Fld Sampid	Logdate	Logtime	Sample Type	Matrix	SBD	SED
J-2 North	MW-130D	MW-130D_F08D	9/18/2008	1030	FD1	Groundwater	320	330
J-2 North	MW-130M1	MW-130M1_F08	9/18/2008	1105	N1	Groundwater	160	170
J-2 North	MW-130S	MW-130S_F08	9/18/2008	1145	N1	Groundwater	103	113
J-2 North	MW-130S	MW-130S_F08D	9/18/2008	1145	FD1	Groundwater	103	113
J-2 North	MW-230M1	MW-230M1_F08	9/18/2008	1245	N1	Groundwater	130	140
J-2 North	MW-230M2	MW-230M2_F08	9/18/2008	1340	N1	Groundwater	110	120
Snake Pond	LKSNK0005	LKSNK0005_0908B	9/19/2008	955	N1	Surface Water	0	0.25
Snake Pond	LKSNK0006	LKSNK0006_0908B	9/19/2008	1010	N1	Surface Water	0	0.25
Snake Pond	LKSNK0006	LKSNK0006_0908BD	9/19/2008	1010	FD1	Surface Water	0	0.25
Snake Pond	LKSNK0007	LKSNK0007_0908B	9/19/2008	925	N1	Surface Water	0	0.25
J-2 North	MW-234M1	MW-234M1_F08	9/22/2008	1425	N1	Groundwater	130	140
J-2 North	MW-234M1	MW-234M1_F08D	9/22/2008	1425	FD1	Groundwater	130	140
J-2 East	J2E-EFF-IH	J2E-EFF-IH-W1-1A	9/22/2008	12:00	N1	Process Water	0	0
J-2 East	J2E-EFF-J	J2E-EFF-J-W1-1A	9/22/2008	10:45	N1	Process Water	0	0
J-2 East	J2E-EFF-K	J2E-EFF-K-W1-1A	9/22/2008	11:25	N1	Process Water	0	0
J-2 East	J2E-INF-I	J2E-INF-I-W1-1A	9/22/2008	11:45	N1	Process Water	0	0
J-2 East	J2E-INF-J	J2E-INF-J-W1-1A	9/22/2008	10:30	N1	Process Water	0	0
J-2 East	J2E-INF-K	J2E-INF-K-W1-1A	9/22/2008	11:10	N1	Process Water	0	0
J-2 East	J2E-MID-1H	J2E-MID-1H-W1-1A	9/22/2008	12:05	N1	Process Water	0	0
J-2 East	J2E-MID-1I	J2E-MID-1I-W1-1A	9/22/2008	11:50	N1	Process Water	0	0
J-2 East	J2E-MID-1J	J2E-MID-1J-W1-1A	9/22/2008	10:35	N1	Process Water	0	0
J-2 East	J2E-MID-1K	J2E-MID-1K-W1-1A	9/22/2008	11:15	N1	Process Water	0	0
J-2 East	J2E-MID-2H	J2E-MID-2H-W1-1A	9/22/2008	12:10	N1	Process Water	0	0
J-2 East	J2E-MID-2I	J2E-MID-2I-W1-1A	9/22/2008	11:55	N1	Process Water	0	0
J-2 East	J2E-MID-2J	J2E-MID-2J-W1-1A	9/22/2008	10:40	N1	Process Water	0	0
J-2 East	J2E-MID-2K	J2E-MID-2K-W1-1A	9/22/2008	11:20	N1	Process Water	0	0
J-2 North	MW-327M1	MW-327M1_F08	9/23/2008	1230	N1	Groundwater	295	305
J-2 North	MW-327M2	MW-327M2_F08	9/23/2008	1410	N1	Groundwater	265	275
J-2 North	MW-327M3	MW-327M3_F08	9/23/2008	950	N1	Groundwater	220	230
J-2 North	MW-234M2	MW-234M2_F08	9/23/2008	1105	N1	Groundwater	110	120
J-2 North	MW-296M1	MW-296M1_F08	9/24/2008	1410	N1	Groundwater	255	265
J-2 North	MW-296M2	MW-296M2_F08	9/24/2008	1515	N1	Groundwater	215	225
J-2 North	MW-305M1	MW-305M1_F08	9/24/2008	1045	N1	Groundwater	203	213
J-2 North	MW-293M1	MW-293M1_F08	9/25/2008	915	N1	Groundwater	296	306
J-2 North	MW-293M2	MW-293M2_F08	9/25/2008	950	N1	Groundwater	196.42	206.42
J-2 North	MW-293S	MW-293S_F08	9/25/2008	1030	N1	Groundwater	110	120
J-2 North	MW-348M1	MW-348M1_F08	9/25/2008	1120	N1	Groundwater	289	299
J-2 North	MW-348M2	MW-348M2_F08	9/25/2008	1155	N1	Groundwater	207.5	217.5
J-2 North	MW-63M1	MW-63M1_F08	9/25/2008	1300	N1	Groundwater	244	254
J-2 North	MW-63M2	MW-63M2_F08	9/25/2008	1440	N1	Groundwater	214	224
Western Boundary	4036000-01G	4036000-01G_0908	9/26/2008	835	N1	Groundwater	38	70
Western Boundary	4036000-01G	4036000-01G_0908D	9/26/2008	835	FD1	Groundwater	38	70
Western Boundary	4036000-03G	4036000-03G_0908	9/26/2008	848	N1	Groundwater	50	60
Western Boundary	4036000-04G	4036000-04G_0908	9/26/2008	856	N1	Groundwater	54.6	64.6
Western Boundary	4036000-06G	4036000-06G_0908	9/26/2008	912	N1	Groundwater	108	128
J-2 East	J2E-EFF-IH	J2E-EFF-IH-W2-1A	9/29/2008	12:00	N1	Process Water	0	0
J-2 East	J2E-EFF-J	J2E-EFF-J-W2-1A	9/29/2008	10:45	N1	Process Water	0	0
J-2 East	J2E-EFF-K	J2E-EFF-K-W2-1A	9/29/2008	11:25	N1	Process Water	0	0
J-2 East	J2E-INF-I	J2E-INF-I-W2-1A	9/29/2008	11:45	N1	Process Water	0	0
J-2 East	J2E-INF-J	J2E-INF-J-W2-1A	9/29/2008	10:30	N1	Process Water	0	0
J-2 East	J2E-INF-K	J2E-INF-K-W2-1A	9/29/2008	11:10	N1	Process Water	0	0
J-2 East	J2E-MID-1H	J2E-MID-1H-W2-1A	9/29/2008	12:05	N1	Process Water	0	0

**TABLE 2**  
**Sampling Progress**  
**1 September 2008- 30 September 2008**

Area of Concern	Location	Fld Sampid	Logdate	Logtime	Sample Type	Matrix	SBD	SED
J-2 East	J2E-MID-1I	J2E-MID-1I-W2-1A	9/29/2008	11:50	N1	Process Water	0	0
J-2 East	J2E-MID-1J	J2E-MID-1J-W2-1A	9/29/2008	10:35	N1	Process Water	0	0
J-2 East	J2E-MID-1K	J2E-MID-1K-W2-1A	9/29/2008	11:15	N1	Process Water	0	0
J-2 East	J2E-MID-2H	J2E-MID-2H-W2-1A	9/29/2008	12:10	N1	Process Water	0	0
J-2 East	J2E-MID-2I	J2E-MID-2I-W2-1A	9/29/2008	11:55	N1	Process Water	0	0
J-2 East	J2E-MID-2J	J2E-MID-2J-W2-1A	9/29/2008	10:40	N1	Process Water	0	0
J-2 East	J2E-MID-2K	J2E-MID-2K-W2-1A	9/29/2008	11:20	N1	Process Water	0	0
J-2 North	MW-330M3	MW-330M2_F08	9/29/2008	1410	N1	Groundwater	238	248
J-2 North	MW-345M2	MW-345M2_F08	9/29/2008	1310	N1	Groundwater	237	247
J-2 North	MW-366M1	MW-366M1_F08	9/29/2008	1030	N1	Groundwater	215	225
J-2 North	MW-366M2	MW-366M2_F08	9/29/2008	1120	N1	Groundwater	175	185
J-2 North	MW-366M3	MW-366M3_F08	9/29/2008	1210	N1	Groundwater	145	155
J-2 North	J2EW3-MW2-A	J2EW3-MW2-A_F08	9/30/2008	1050	N1	Groundwater	151.16	161.16
J-2 North	J2EW3-MW2-B	J2EW3-MW2-B_F08	9/30/2008	1210	N1	Groundwater	216.2	226.16
J-2 North	J2EW3-MW2-C	J2EW3-MW2-C_F08	9/30/2008	1335	N1	Groundwater	251.16	261.16

TABLE 4

## VALIDATED DETECTS EXCEEDING MCLs or HEALTH ADVISORY LIMITS 1997 THROUGH September 2008

LOCID/WELL ID	SAMPLE_ID	SAMPLED	AOC	METHOD	ANALYTE	CONC	FLAG	UNITS	BWTS	BWTE	DW LIMIT
03MW0006	03MW0006	4/15/1999	CS-10	IM40MB	THALLIUM	2.6	J	UG/L	0	10	2
03MW0007A	03MW0007A	4/13/1999	CS-10	OC21V	TETRACHLOROETHYLENE(PCE)	6		UG/L	21	26	5
03MW0014A	03MW0014A	4/13/1999	CS-10	OC21V	TETRACHLOROETHYLENE(PCE)	8		UG/L	38	43	5
03MW0020	03MW0020	4/14/1999	CS-10	OC21V	TETRACHLOROETHYLENE(PCE)	12		UG/L	36	41	5
03MW0022A	03MW0022A	4/16/1999	CS-10	IM40MB	THALLIUM	3.9		UG/L	71	76	2
03MW0027A	03MW0027A	4/14/1999	CS-10	IM40MB	THALLIUM	2	J	UG/L	64	69	2
03MW0122A	WS122A	9/30/1999	CS-10	OC21B	BIS(2-ETHYLHEXYL) PHTHALATE	12		UG/L	1	11	6
11MW0003	WF143A	2/25/1998	OTHER	OC21B	BIS(2-ETHYLHEXYL) PHTHALATE	9		UG/L			6
11MW0003	WF143A	9/30/1999	OTHER	OC21B	BIS(2-ETHYLHEXYL) PHTHALATE	24		UG/L			6
11MW0004	11MW0004	4/16/1999	OTHER	IM40MB	THALLIUM	2.3	J	UG/L	0	10	2
15MW0002	15MW0002	4/8/1999	J-2 RANGE	IM40MB	SODIUM	37600		UG/L	0	10	20000
15MW0004	15MW0004	4/9/1999	J-2 RANGE	OC21B	BIS(2-ETHYLHEXYL) PHTHALATE	6		UG/L	0	10	6
15MW0008	15MW0008D	4/12/1999	J-2 RANGE	OC21B	BIS(2-ETHYLHEXYL) PHTHALATE	25	J	UG/L	0	10	6
16MW0001	16MW0001-	5/13/2002	CS-18	E314.0	PERCHLORATE	2.7		UG/L			2
16MW0001	16MW0001-	7/12/2002	CS-18	E314.0	PERCHLORATE	4.3		UG/L			2
27MW0017B	27MW0017B	4/30/1999	LF-1	OC21V	VINYL CHLORIDE	2		UG/L	21	26	2
27MW0018A	CHPI0006-A0103	4/23/2003	LF-1	SW8330	1,3-DINITROBENZENE	1.7		UG/L			1
27MW0020A	CHPI10007-A0103	4/23/2003	LF-1	SW8330	1,3-DINITROBENZENE	1		UG/L			1
27MW0020B	CHPI0008-A0103	4/23/2003	LF-1	SW8330	1,3-DINITROBENZENE	1.1		UG/L			1
27MW0020Z	27MW0020Z	4/16/1999	LF-1	IM40MB	THALLIUM	2.7	J	UG/L	98	103	2
27MW0031B	27MW0031B-	4/20/2001	LF-1	E314.0	PERCHLORATE	17.7		UG/L			2
27MW0031B	27MW0031B-	7/5/2001	LF-1	E314.0	PERCHLORATE	15.1		UG/L			2
27MW0031B	27MW0031B-	1/3/2002	LF-1	E314.0	PERCHLORATE	9.3		UG/L			2
27MW0031B	27MW0031B-FD	1/3/2002	LF-1	E314.0	PERCHLORATE	8.8		UG/L			2
27MW0031B	27MW0031B-	3/29/2002	LF-1	E314.0	PERCHLORATE	8.3		UG/L			2
27MW0031B	27MW0031B-	7/17/2002	LF-1	E314.0	PERCHLORATE	5.3		UG/L			2
27MW0031B	27MW0031B-FD	7/17/2002	LF-1	E314.0	PERCHLORATE	5.3		UG/L			2
27MW0031B	27MW0031B-	1/6/2003	LF-1	E314.0	PERCHLORATE	3.7		UG/L			2
27MW0031B	CHPH00019-Q0403	8/27/2003	LF-1	E314.0	PERCHLORATE	2.1		UG/L			2
27MW0031B	CHPH10019-Q0403	8/27/2003	LF-1	E314.0	PERCHLORATE	2.1		UG/L			2
27MW0705	27MW0705	1/8/2002	LF-1	SW8270	BIS(2-ETHYLHEXYL) PHTHALATE	7.5	J	UG/L	0	10	6
27MW2061	27MW2061	1/9/2002	LF-1	SW8270	BIS(2-ETHYLHEXYL) PHTHALATE	12	J	UG/L	0	10	6
28MW0106	WL28XA	2/19/1998	LF-1	OC21B	BIS(2-ETHYLHEXYL) PHTHALATE	18	J	UG/L	0	10	6
28MW0106	WL28XA	3/23/1999	LF-1	OC21B	BIS(2-ETHYLHEXYL) PHTHALATE	26		UG/L	0	10	6
4036009DC	GLSKRKNK-A	12/20/2002	NW CORNER	E314.0	PERCHLORATE	5.26		UG/L			2
4036009DC	GLSKRKNK-D	12/20/2002	NW CORNER	E314.0	PERCHLORATE	5.51		UG/L			2
4036009DC	GLSKRKNK-A	1/8/2003	NW CORNER	E314.0	PERCHLORATE	6.06		UG/L			2
4036009DC	GLSKRKNK-D	1/8/2003	NW CORNER	E314.0	PERCHLORATE	5.99		UG/L			2
4036009DC	4036009DC-A	9/3/2003	NW CORNER	E314.0	PERCHLORATE	4.15		UG/L			2
4036009DC	4036009DC-A	11/24/2003	NW CORNER	E314.0	PERCHLORATE	4.88		UG/L			2
4036009DC	4036009DC-A	2/17/2004	NW CORNER	E314.0	PERCHLORATE	5.13		UG/L			2
4036009DC	4036009DC-A	5/19/2004	NW CORNER	E314.0	PERCHLORATE	5.36		UG/L			2
4036009DC	4036009DC-D	5/19/2004	NW CORNER	E314.0	PERCHLORATE	5.23		UG/L			2
4036009DC	4036009DC-A	8/18/2004	NW CORNER	E314.0	PERCHLORATE	5.63		UG/L			2
4036009DC	4036009DC-A	12/13/2004	NW CORNER	E314.0	PERCHLORATE	5.03		UG/L			2
4036009DC	4036009DC-A	4/4/2005	NW CORNER	E314.0	PERCHLORATE	4.6	J	UG/L			2
4036009DC	4036009_0805	8/23/2005	NW CORNER	E314.0	PERCHLORATE	3.9		UG/L			2

AOC = Area of Concern  
J = Estimated Result

BWTS = Depth Below Water Table Start (feet)

BWTE = Depth Below Water Table End (feet)

DW Limit = Either the MCL or Lowest Health Advisory Limit

TABLE 4

## VALIDATED DETECTS EXCEEDING MCLs or HEALTH ADVISORY LIMITS 1997 THROUGH September 2008

LOCID/WELL ID	SAMPLE_ID	SAMPLED	AOC	METHOD	ANALYTE	CONC	FLAG	UNITS	BWTS	BWTE	DW LIMIT
4036009DC	4036009_1105	11/21/2005	NW CORNER	E314.0	PERCHLORATE	3.6		UG/L			2
58MW0001	58MW001-01	11/7/1996	CS-19	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.8		UG/L	0	5	2
58MW0001	58MW0001-	2/21/2000	CS-19	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.1	J	UG/L	0	5	2
58MW0001	58MW0001-FD	2/21/2000	CS-19	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3	J	UG/L	0	5	2
58MW0001	58MW0001	5/29/2001	CS-19	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.8		UG/L	0	5	2
58MW0001	58MW0001	8/29/2001	CS-19	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.5		UG/L	0	5	2
58MW0001	58MW0001-D	8/29/2001	CS-19	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.4		UG/L	0	5	2
58MW0001	58MW0001	1/11/2002	CS-19	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.6		UG/L	0	5	2
58MW0001	58MW0001	5/31/2002	CS-19	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4		UG/L	0	5	2
58MW0001	58MW0001-A	9/13/2002	CS-19	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4		UG/L	0	5	2
58MW0001	58MW0001-A	12/6/2002	CS-19	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	6.2		UG/L	0	5	2
58MW0001	58MW0001-A	8/8/2003	CS-19	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	11		UG/L	0	5	2
58MW0001	58MW0001-A	11/18/2003	CS-19	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	7.9		UG/L	0	5	2
58MW0001	58MW0001-A	6/22/2004	CS-19	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	9.7		UG/L	0	5	2
58MW0001	58MW0001-A	11/4/2004	CS-19	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	7.5	J	UG/L	0	5	2
58MW0001	58MW0001-A	4/26/2005	CS-19	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	9.8		UG/L	0	5	2
58MW0001	58MW0001-A	9/24/2005	CS-19	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.9		UG/L	0	5	2
58MW0002	58MW002-01	11/7/1996	CS-19	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	14		UG/L	0	5	2
58MW0002	WC2XXA	2/26/1998	CS-19	OC21B	BIS(2-ETHYLHEXYL) PHTHALATE	36		UG/L	0	5	6
58MW0002	WC2XXA	2/26/1998	CS-19	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	19		UG/L	0	5	2
58MW0002	WC2XXA	1/14/1999	CS-19	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	20		UG/L	0	5	2
58MW0002	WC2XXA	10/8/1999	CS-19	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	8.8		UG/L	0	5	2
58MW0002	58MW0002-	3/22/2000	CS-19	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	12		UG/L	0	5	2
58MW0002	58MW0002	5/23/2001	CS-19	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	13		UG/L	0	5	2
58MW0002	58MW0002	9/19/2001	CS-19	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	15		UG/L	0	5	2
58MW0002	58MW0002	12/14/2001	CS-19	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	15		UG/L	0	5	2
58MW0002	58MW0002	5/31/2002	CS-19	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	16		UG/L	0	5	2
58MW0002	58MW0002-A	9/11/2002	CS-19	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	13		UG/L	0	5	2
58MW0002	58MW0002-A	12/5/2002	CS-19	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	11		UG/L	0	5	2
58MW0002	58MW0002-A	10/10/2003	CS-19	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	20		UG/L	0	5	2
58MW0002	58MW0002-A	3/2/2004	CS-19	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	21		UG/L	0	5	2
58MW0002	58MW0002-A	4/28/2004	CS-19	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	18		UG/L	0	5	2
58MW0002	58MW0002-A	11/4/2004	CS-19	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	14	J	UG/L	0	5	2
58MW0002	58MW0002-A	4/25/2005	CS-19	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	12		UG/L	0	5	2
58MW0002	58MW0002-A	8/5/2005	CS-19	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	13		UG/L	0	5	2
58MW0002	58MW0002-A	12/19/2005	CS-19	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	17		UG/L	0	5	2
58MW0005E	WC5EXA	9/27/1999	CS-19	OC21B	BIS(2-ETHYLHEXYL) PHTHALATE	8		UG/L	0	10	6
58MW0006E	WC6EXA	10/3/1997	CS-19	OC21B	BIS(2-ETHYLHEXYL) PHTHALATE	59		UG/L	0	10	6
58MW0006E	WC6EXD	10/3/1997	CS-19	OC21B	BIS(2-ETHYLHEXYL) PHTHALATE	57		UG/L	0	10	6
58MW0006E	WC6EXA	1/29/1999	CS-19	OC21B	BIS(2-ETHYLHEXYL) PHTHALATE	6		UG/L	0	10	6
58MW0007C	WC7CXA	9/28/1999	CS-19	OC21B	BIS(2-ETHYLHEXYL) PHTHALATE	13		UG/L	24	29	6
58MW0008E	17625	3/3/1997	CS-19	C200.7	THALLIUM	6.5	J	UG/L			2
58MW0009C	58MW0009C-A	3/11/2005	CS-19	E314.0	PERCHLORATE	2.2		UG/L	41	47	2
58MW0009C	58MW0009C-A	5/19/2005	CS-19	E314.0	PERCHLORATE	2.5	J	UG/L	41	47	2
58MW0009C	58MW0009C-A	1/11/2006	CS-19	E314.0	PERCHLORATE	2.1		UG/L	41	47	2
58MW0009E	58MW0009E-05	4/16/1997	CS-19	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	10		UG/L	6.5	11.5	2
58MW0009E	WC9EXA	10/2/1997	CS-19	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	7.7		UG/L	6.5	11.5	2

BWTS = Depth Below Water Table Start (feet)

BWTE = Depth Below Water Table End (feet)

DW Limit = Either the MCL or Lowest Health Advisory Limit

AOC = Area of Concern

J = Estimated Result

TABLE 4

## VALIDATED DETECTS EXCEEDING MCLs or HEALTH ADVISORY LIMITS 1997 THROUGH September 2008

LOCID/WELL ID	SAMPLE_ID	SAMPLED	AOC	METHOD	ANALYTE	CONC	FLAG	UNITS	BWTS	BWTE	DW LIMIT
58MW0009E	WC9EXA	1/26/1999	CS-19	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	17		UG/L	6.5	11.5	2
58MW0009E	WC9EXA	9/28/1999	CS-19	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	18		UG/L	6.5	11.5	2
58MW0009E	WC9EXD	9/28/1999	CS-19	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	18		UG/L	6.5	11.5	2
58MW0009E	58MW0009E-	3/6/2000	CS-19	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	13		UG/L	6.5	11.5	2
58MW0009E	58MW0009E	5/23/2001	CS-19	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	8.4		UG/L	6.5	11.5	2
58MW0009E	58MW0009E	8/29/2001	CS-19	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	12		UG/L	6.5	11.5	2
58MW0009E	58MW0009E	12/11/2001	CS-19	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	13		UG/L	6.5	11.5	2
58MW0009E	58MW0009E	6/3/2002	CS-19	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	14		UG/L	6.5	11.5	2
58MW0009E	58MW0009E-A	8/26/2002	CS-19	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	14		UG/L	6.5	11.5	2
58MW0009E	58MW0009E-A	12/9/2002	CS-19	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	10		UG/L	6.5	11.5	2
58MW0009E	58MW0009E-A	7/3/2003	CS-19	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	14		UG/L	6.5	11.5	2
58MW0009E	58MW0009E-D	7/3/2003	CS-19	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	14		UG/L	6.5	11.5	2
58MW0009E	58MW0009E-A	11/18/2003	CS-19	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	12		UG/L	6.5	11.5	2
58MW0009E	58MW0009E-A	3/5/2004	CS-19	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	9.6		UG/L	6.5	11.5	2
58MW0009E	58MW0009E-D	3/5/2004	CS-19	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	9.8		UG/L	6.5	11.5	2
58MW0009E	58MW0009E-A	5/5/2004	CS-19	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	8.1		UG/L	6.5	11.5	2
58MW0009E	58MW0009E-A	8/24/2004	CS-19	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5.5		UG/L	6.5	11.5	2
58MW0009E	58MW0009E-D	8/24/2004	CS-19	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5.6		UG/L	6.5	11.5	2
58MW0009E	58MW0009E-A	2/18/2005	CS-19	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	12		UG/L	6.5	11.5	2
58MW0009E	58MW0009E-A	5/19/2005	CS-19	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	17		UG/L	6.5	11.5	2
58MW0009E	58MW0009E-A	11/1/2005	CS-19	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	14		UG/L	6.5	11.5	2
58MW0009E	58MW0009E-A	1/11/2006	CS-19	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	14		UG/L	6.5	11.5	2
58MW0010A	58MW0010A-01	4/16/1997	CS-19	CSVOL	bis(2-ETHYLHEXYL) PHTHALATE	7.3	J	UG/L	140	145	6
58MW0010A	WC10XA	1/18/1999	CS-19	IM40MB	ARSENIC	15.3		UG/L	140	145	10
58MW0010A	WC10XL	1/18/1999	CS-19	IM40MB	ARSENIC	15.6		UG/L	140	145	10
58MW0010A	WC10XA	9/29/1999	CS-19	IM40MB	ARSENIC	14.8		UG/L	140	145	10
58MW0010A	58MW0010A-	3/6/2000	CS-19	C200.7	ARSENIC	12.4		UG/L	140	145	10
58MW0011D	22435	4/28/1997	CS-19	C200.7	THALLIUM	3.9	J	UG/L	49.5	54.5	2
58MW0011D	58MW0011D-	3/22/2000	CS-19	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	6.1		UG/L	49.5	54.5	2
58MW0011D	58MW0011D	5/24/2001	CS-19	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	7.3		UG/L	49.5	54.5	2
58MW0011D	58MW0011D	9/26/2001	CS-19	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	6.5		UG/L	49.5	54.5	2
58MW0011D	58MW0011D	12/11/2001	CS-19	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5.1		UG/L	49.5	54.5	2
58MW0011D	58MW0011D	6/3/2002	CS-19	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.5		UG/L	49.5	54.5	2
58MW0011D	58MW0011D-A	8/27/2002	CS-19	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.6		UG/L	49.5	54.5	2
58MW0011D	58MW0011D-A	12/9/2002	CS-19	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.4		UG/L	49.5	54.5	2
58MW0011D	58MW0011D-A	6/9/2003	CS-19	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.5		UG/L	49.5	54.5	2
58MW0011D	58MW0011D	5/11/2007	CS-19	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.7		UG/L	49.5	54.5	2
58MW0015	58MW0015A	4/11/2002	CS-19	E314.0	PERCHLORATE	2.09		UG/L	36	45	2
58MW0015	58MW0015A-A	8/27/2002	CS-19	E314.0	PERCHLORATE	2		UG/L	36	45	2
58MW0015	58MW0015A-A	2/5/2003	CS-19	E314.0	PERCHLORATE	2.5	J	UG/L	36	45	2
58MW0015	58MW0015A-A	5/9/2003	CS-19	E314.0	PERCHLORATE	2.2		UG/L	36	45	2
58MW0015	58MW0015A-A	10/9/2003	CS-19	E314.0	PERCHLORATE	2		UG/L	36	45	2
58MW0015	58MW0015A-A	5/6/2004	CS-19	E314.0	PERCHLORATE	2.1	J	UG/L	36	45	2
58MW0016	58MW0016B-	3/21/2000	CS-19	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5.9		UG/L	28.5	38.5	2
58MW0016	58MW0016C-	3/21/2000	CS-19	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.1		UG/L	0	10	2
58MW0016	58MW0016B	8/30/2001	CS-19	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.3		UG/L	28.5	38.5	2
58MW0016	58MW0016C	8/30/2001	CS-19	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.8		UG/L	0	10	2

AOC = Area of Concern

J = Estimated Result

BWTS = Depth Below Water Table Start (feet)

BWTE = Depth Below Water Table End (feet)

DW Limit = Either the MCL or Lowest Health Advisory Limit

TABLE 4

## VALIDATED DETECTS EXCEEDING MCLs or HEALTH ADVISORY LIMITS 1997 THROUGH September 2008

LOCID/WELL ID	SAMPLE_ID	SAMPLED	AOC	METHOD	ANALYTE	CONC	FLAG	UNITS	BWTS	BWTE	DW LIMIT
58MW0016	58MW0016C	12/11/2001	CS-19	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4		UG/L	0	10	2
58MW0016	58MW0016C	6/4/2002	CS-19	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.3		UG/L	0	10	2
58MW0016	58MW0016C-A	11/24/2003	CS-19	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.3		UG/L	0	10	2
58MW0016	58MW0016C-D	11/24/2003	CS-19	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.4		UG/L	0	10	2
58MW0016	58MW0016C-A	4/30/2004	CS-19	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4		UG/L	0	10	2
58MW0016	58MW0016C-A	11/5/2004	CS-19	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.4		UG/L	0	10	2
58MW0016	58MW0016C-D	11/5/2004	CS-19	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.5		UG/L	0	10	2
58MW0016	58MW0016C-A	4/26/2005	CS-19	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.3		UG/L	0	10	2
58MW0016	58MW0016C-D	4/26/2005	CS-19	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.4		UG/L	0	10	2
58MW0016	58MW0016C-A	9/2/2005	CS-19	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.2		UG/L	0	10	2
58MW0016	58MW0016C-A	1/24/2006	CS-19	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.5		UG/L	0	10	2
58MW0018	58MW0018B-	3/20/2000	CS-19	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3		UG/L	34.55	44.55	2
58MW0018	58MW0018B	12/13/2001	CS-19	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.2		UG/L	34.55	44.55	2
90MW0003	WF03MA	10/7/1999	L RANGE; FS-12	OC21V	1,2-DICHLOROETHANE	5		UG/L	52.11	57.11	5
90MW0022	WF22XA	1/26/1999	J-3 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.8		UG/L	72.79	77.79	2
90MW0022	WF22XA	2/16/1999	J-3 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5.4		UG/L	72.79	77.79	2
90MW0022	WF22XA	9/30/1999	J-3 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5.2		UG/L	72.79	77.79	2
90MW0022	90MW0022	5/19/2001	J-3 RANGE	E314.0	PERCHLORATE	2	J	UG/L	72.79	77.79	2
90MW0022	90MW0022	9/5/2001	J-3 RANGE	E314.0	PERCHLORATE	2	J	UG/L	72.79	77.79	2
90MW0022	90MW0022-A	5/17/2004	J-3 RANGE	E314.0	PERCHLORATE	3.4		UG/L	72.79	77.79	2
90MW0022	90MW0022-D	5/17/2004	J-3 RANGE	E314.0	PERCHLORATE	3.5		UG/L	72.79	77.79	2
90MW0022	90MW0022-A	9/21/2004	J-3 RANGE	E314.0	PERCHLORATE	4.3		UG/L	72.79	77.79	2
90MW0022	90MW0022-A	11/30/2004	J-3 RANGE	E314.0	PERCHLORATE	4	J	UG/L	72.79	77.79	2
90MW0022	90MW0022-A	6/9/2005	J-3 RANGE	E314.0	PERCHLORATE	9.8		UG/L	72.79	77.79	2
90MW0022	90MW0022-A	8/11/2005	J-3 RANGE	E314.0	PERCHLORATE	10.2		UG/L	72.79	77.79	2
90MW0022	90MW0022-A	12/2/2005	J-3 RANGE	E314.0	PERCHLORATE	15.1		UG/L	72.79	77.79	2
90MW0022	90MW0022_FAL08	8/19/2008	J-3 RANGE	E314.0	PERCHLORATE	11.1		UG/L	72.79	77.79	2
90MW0022	90MW0022_FAL08D	8/19/2008	J-3 RANGE	E314.0	PERCHLORATE	11.3		UG/L	72.79	77.79	2
90MW0038	90MW0038	4/21/1999	L RANGE	IM40MB	THALLIUM	4.4	J	UG/L	29	34	2
90MW0041	90MW0041-D	1/13/2003	L RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5.4		UG/L	31.5	36.5	2
90MW0054	WF12XA	10/4/1999	J-3 RANGE	OC21B	BIS(2-ETHYLHEXYL) PHTHALATE	13	J	UG/L	91.83	96.83	6
90MW0054	90MW0054AA	1/30/2001	J-3 RANGE	E314.0	PERCHLORATE	9		UG/L	91.83	96.83	2
90MW0054	90MW0054AD	1/30/2001	J-3 RANGE	E314.0	PERCHLORATE	10		UG/L	91.83	96.83	2
90MW0054	90MW0054	10/24/2001	J-3 RANGE	E314.0	PERCHLORATE	27.8		UG/L	91.83	96.83	2
90MW0054	90MW0054	12/8/2001	J-3 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.1		UG/L	91.83	96.83	2
90MW0054	90MW0054	12/13/2001	J-3 RANGE	E314.0	PERCHLORATE	32.1		UG/L	91.83	96.83	2
90MW0054	90MW0054	4/20/2002	J-3 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.7		UG/L	91.83	96.83	2
90MW0054	90MW0054	4/20/2002	J-3 RANGE	E314.0	PERCHLORATE	26.3	J	UG/L	91.83	96.83	2
90MW0054	90MW0054-A	9/12/2002	J-3 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.9		UG/L	91.83	96.83	2
90MW0054	90MW0054-A	9/12/2002	J-3 RANGE	E314.0	PERCHLORATE	19	J	UG/L	91.83	96.83	2
90MW0054	90MW0054-A	12/30/2002	J-3 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.5		UG/L	91.83	96.83	2
90MW0054	90MW0054-A	12/30/2002	J-3 RANGE	E314.0	PERCHLORATE	17		UG/L	91.83	96.83	2
90MW0054	90MW0054-A	5/1/2003	J-3 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.3		UG/L	91.83	96.83	2
90MW0054	90MW0054-A	5/1/2003	J-3 RANGE	E314.0	PERCHLORATE	7.5		UG/L	91.83	96.83	2
90MW0054	90MW0054-A	10/4/2003	J-3 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.2		UG/L	91.83	96.83	2
90MW0054	90MW0054-A	10/4/2003	J-3 RANGE	E314.0	PERCHLORATE	4.3	J	UG/L	91.83	96.83	2
90MW0054	90MW0054-D	10/4/2003	J-3 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.2		UG/L	91.83	96.83	2

AOC = Area of Concern  
J = Estimated Result

BWTS = Depth Below Water Table Start (feet)

BWTE = Depth Below Water Table End (feet)

DW Limit = Either the MCL or Lowest Health Advisory Limit

TABLE 4

## VALIDATED DETECTS EXCEEDING MCLs or HEALTH ADVISORY LIMITS 1997 THROUGH September 2008

LOCID/WELL ID	SAMPLE_ID	SAMPLED	AOC	METHOD	ANALYTE	CONC	FLAG	UNITS	BWTS	BWTE	DW LIMIT
90MW0054	90MW0054-D	10/4/2003	J-3 RANGE	E314.0	PERCHLORATE	4.4	J	UG/L	91.83	96.83	2
90MW0054	90MW0054-A	2/18/2004	J-3 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.1		UG/L	91.83	96.83	2
90MW0054	90MW0054-A	2/18/2004	J-3 RANGE	E314.0	PERCHLORATE	4.2		UG/L	91.83	96.83	2
90MW0054	90MW0054-A	5/17/2004	J-3 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.2		UG/L	91.83	96.83	2
90MW0054	90MW0054-A	5/17/2004	J-3 RANGE	E314.0	PERCHLORATE	2.6		UG/L	91.83	96.83	2
90PZ0211	90PZ0211A-A	9/11/2003	J-3 RANGE	E314.0	PERCHLORATE	2.99		UG/L	76.85	76.85	2
90PZ0211	90PZ0211B-A	9/11/2003	J-3 RANGE	E314.0	PERCHLORATE	2.94		UG/L	86.85	86.85	2
90PZ0211	90PZ0211B-D	9/11/2003	J-3 RANGE	E314.0	PERCHLORATE	2.97		UG/L	86.85	86.85	2
90PZ0211	90PZ0211C-A	9/11/2003	J-3 RANGE	E314.0	PERCHLORATE	3.8		UG/L	96.85	96.85	2
90PZ0211	90PZ0211A-A	5/20/2004	J-3 RANGE	E314.0	PERCHLORATE	5		UG/L	76.85	76.85	2
90PZ0211	90PZ0211B-A	5/20/2004	J-3 RANGE	E314.0	PERCHLORATE	5.3		UG/L	86.85	86.85	2
90PZ0211	90PZ0211C-A	5/20/2004	J-3 RANGE	E314.0	PERCHLORATE	5.7		UG/L	96.85	96.85	2
90PZ0211	90PZ0211A-A	9/23/2004	J-3 RANGE	E314.0	PERCHLORATE	7.4		UG/L	76.85	76.85	2
90PZ0211	90PZ0211B-A	9/23/2004	J-3 RANGE	E314.0	PERCHLORATE	8.1		UG/L	86.85	86.85	2
90PZ0211	90PZ0211C-A	9/23/2004	J-3 RANGE	E314.0	PERCHLORATE	9.4		UG/L	96.85	96.85	2
90PZ0211	90PZ0211B-A	6/2/2005	J-3 RANGE	E314.0	PERCHLORATE	2.8		UG/L	86.85	86.85	2
90PZ0211	90PZ0211A-A	10/21/2005	J-3 RANGE	E314.0	PERCHLORATE	3.1		UG/L	76.85	76.85	2
90PZ0211	90PZ0211B-A	10/21/2005	J-3 RANGE	E314.0	PERCHLORATE	2.3		UG/L	86.85	86.85	2
90PZ0211	90PZ0211	9/19/2007	J-3 RANGE	E314.0	PERCHLORATE	2.7		UG/L	76.85	76.85	2
90WT0003	WF03XA	9/30/1999	L RANGE	OC21B	BIS(2-ETHYLHEXYL) PHTHALATE	58		UG/L	0	10	6
90WT0005	WF05XA	1/13/1998	FS-12	OC21B	BIS(2-ETHYLHEXYL) PHTHALATE	47		UG/L	0	10	6
90WT0010	WF10XA	1/16/1998	FS-12	IM40MB	THALLIUM	6.5	J	UG/L	2	12	2
90WT0010	90WT0010	6/5/2000	FS-12	IM40MB	SODIUM	23600		UG/L	2	12	20000
90WT0010	90WT0010-L	6/5/2000	FS-12	IM40MB	SODIUM	24200		UG/L	2	12	20000
90WT0013	WF13XA	1/16/1998	L RANGE	OC21B	BIS(2-ETHYLHEXYL) PHTHALATE	34		UG/L	0	10	6
90WT0013	WF13XA	1/16/1998	L RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5.2	J	UG/L	0	10	2
90WT0013	WF13XA	1/14/1999	L RANGE	OC21B	BIS(2-ETHYLHEXYL) PHTHALATE	16		UG/L	0	10	6
90WT0013	90WT0013-A	9/8/2003	L RANGE	E314.0	PERCHLORATE	2.8	J	UG/L	0	10	2
90WT0015	90WT0015	4/23/1999	FS-12	IM40MB	SODIUM	34300		UG/L	0	10	20000
95-15A	W9515A	10/17/1997	NW CORNER	IM40	ZINC	7210		UG/L	74.71	84.71	2000
95-15A	W9515L	10/17/1997	NW CORNER	IM40	ZINC	4620		UG/L	74.71	84.71	2000
97-1	W9701A	11/19/1997	WESTERN BOUNDARY	OC21B	BIS(2-ETHYLHEXYL) PHTHALATE	54	J	UG/L	62	72	6
97-1	W9701D	11/19/1997	WESTERN BOUNDARY	OC21B	BIS(2-ETHYLHEXYL) PHTHALATE	28	J	UG/L	62	72	6
97-2	W9702A	11/20/1997	WESTERN BOUNDARY	OC21B	BIS(2-ETHYLHEXYL) PHTHALATE	7		UG/L	53	63	6
97-3	W9703A	11/21/1997	WESTERN BOUNDARY	OC21B	BIS(2-ETHYLHEXYL) PHTHALATE	73	J	UG/L	36	46	6
97-5	W9705A	11/20/1997	WESTERN BOUNDARY	OC21B	BIS(2-ETHYLHEXYL) PHTHALATE	15		UG/L	76	86	6
ASPWELL	ASPWELL	7/20/1999	OTHER	E200.8	LEAD	53		UG/L			15
ASPWELL	ASPWELL	7/20/1999	OTHER	A3111B	SODIUM	33000	J	UG/L			20000
ASPWELL	ASPWELL	10/13/1999	OTHER	A3111B	SODIUM	38000		UG/L			20000
ASPWELL	ASPWELL	12/12/2000	OTHER	IM40PB	LEAD	20.9		UG/L			15
ASPWELL	ASPWELL	5/24/2001	OTHER	IM40MB	LEAD	30.4		UG/L			15
ASPWELL	ASPWELL	5/24/2001	OTHER	IM40MB	SODIUM	24900		UG/L			20000
ASPWELL	ASPWELL	9/27/2001	OTHER	A3111B	SODIUM	21000		UG/L			20000
ASPWELL	ASPWELL	9/27/2001	OTHER	IM40MB	SODIUM	22600		UG/L			20000
ASPWELL	ASPWELL	12/19/2001	OTHER	IM40MB	SODIUM	28500		UG/L			20000
ASPWELL	ASPWELL-A	10/13/2004	OTHER	E200.7	SODIUM	29000		UG/L			20000
ASPWELL	ASPWELL-A	10/13/2004	OTHER	IM40MBM	SODIUM	29700		UG/L			20000

AOC = Area of Concern

J = Estimated Result

BWTS = Depth Below Water Table Start (feet)

BWTE = Depth Below Water Table End (feet)

DW Limit = Either the MCL or Lowest Health Advisory Limit

TABLE 4

## VALIDATED DETECTS EXCEEDING MCLs or HEALTH ADVISORY LIMITS 1997 THROUGH September 2008

LOCID/WELL ID	SAMPLE_ID	SAMPLED	AOC	METHOD	ANALYTE	CONC	FLAG	UNITS	BWTS	BWTE	DW LIMIT
BHW215083	WG083A	11/26/1997	OTHER	OC21B	BIS(2-ETHYLHEXYL) PHTHALATE	13		UG/L	16.95	26.95	6
BHW215083	BHW215083B-A	11/16/2005	OTHER	IM40MBM	SODIUM	371000		UG/L	16.95	26.95	20000
BHW215083	BHW215083D-A	11/17/2005	OTHER	IM40MBM	SODIUM	63800		UG/L	80.05	90.05	20000
C2-B	C-2I	3/7/2002	OTHER	SVOC_FW	BIS(2-ETHYLHEXYL) PHTHALATE	10		UG/L	39.31	79.31	6
C6-C	C-6D	3/12/2002	OTHER	SVOC_FW	BIS(2-ETHYLHEXYL) PHTHALATE	7.1		UG/L	100.04	140.04	6
C7-B	C-7I	3/8/2002	J-2 RANGE	SVOC_FW	BIS(2-ETHYLHEXYL) PHTHALATE	14		UG/L	93.89	133.89	6
C7-B	C-7ID	3/8/2002	J-2 RANGE	SVOC_FW	BIS(2-ETHYLHEXYL) PHTHALATE	17		UG/L	93.89	133.89	6
DP-499	DP-499-08	8/28/2008	J1S [189]	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.5		UG/L	150	155	2
DP-499	DP-499-09	8/29/2008	J1S [189]	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5.3		UG/L	160	165	2
DP-499	DP-499-09D	8/29/2008	J1S [189]	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5.3		UG/L	160	165	2
DP-499	DP-499-10	8/29/2008	J1S [189]	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.4		UG/L	170	175	2
ECMWSNP02	ECMWSNP02D	9/13/1999	J-3 RANGE: FS-12	504	1,2-DIBROMOETHANE (ETHYLENE DIBROMIDE)	0.11		UG/L	75.08	80.08	0.05
J2EW0001	J2EW0001_3S	3/5/2008	J-3 RANGE	E314.0	PERCHLORATE	13.6		UG/L	179	234	2
J2EW0001	J2EW0001_F08	9/10/2008	J2N [149]	E314.0	PERCHLORATE	16.7		UG/L	179	234	2
J2EW0001	J2EW0001_F08D	9/10/2008	J2N [149]	E314.0	PERCHLORATE	15.1		UG/L	179	234	2
J2EW0002	J2EW0002_3S	3/5/2008	J-3 RANGE	E314.0	PERCHLORATE	4.25		UG/L	198	233	2
J2EW0002	J2EW0002_F08	9/10/2008	J2N [149]	E314.0	PERCHLORATE	3.07		UG/L	198	233	2
J3EWIP1	J3EWIP1_3S	2/20/2008	J-3 RANGE	E314.0	PERCHLORATE	3.1		UG/L	153	193	2
LRMW0003	WL31XA	10/21/1997	OTHER	IM40	ZINC	2480		UG/L	69.68	94.68	2000
LRMW0003	WL31XL	10/21/1997	OTHER	IM40	ZINC	2410		UG/L	69.68	94.68	2000
LRMW0003	LRMW0003-A	5/17/2004	OTHER	OC21VM	CHLOROMETHANE	33	J	UG/L	69.68	94.68	30
LRWS1-4	WL14XA	1/6/1999	OTHER	IM40MB	THALLIUM	5.2	J	UG/L	107	117	2
LRWS1-4	WL14XA	10/6/1999	OTHER	OC21B	BIS(2-ETHYLHEXYL) PHTHALATE	78	J	UG/L	107	117	6
LRWS2-3	WL23XA	11/21/1997	WESTERN BOUNDARY	OC21B	BIS(2-ETHYLHEXYL) PHTHALATE	20	J	UG/L	68	83	6
LRWS2-6	WL26XA	10/20/1997	WESTERN BOUNDARY	OC21B	BIS(2-ETHYLHEXYL) PHTHALATE	21		UG/L	75	90	6
LRWS2-6	WL26XA	10/4/1999	WESTERN BOUNDARY	OC21B	BIS(2-ETHYLHEXYL) PHTHALATE	9	J	UG/L	75	90	6
LRWS4-1	WL41XA	11/24/1997	J-2 RANGE	OC21B	BIS(2-ETHYLHEXYL) PHTHALATE	100		UG/L	66	91	6
LRWS4-1	WL41XA	11/24/1997	J-2 RANGE	IM40	ZINC	3220		UG/L	66	91	2000
LRWS4-1	WL41XL	11/24/1997	J-2 RANGE	IM40	ZINC	3060		UG/L	66	91	2000
LRWS5-1	WL51DL	11/25/1997	PHASE 2b	IM40	ZINC	4410		UG/L	66	91	2000
LRWS5-1	WL51XA	11/25/1997	PHASE 2b	OC21B	BIS(2-ETHYLHEXYL) PHTHALATE	7		UG/L	66	91	6
LRWS5-1	WL51XA	11/25/1997	PHASE 2b	IM40	ZINC	4510		UG/L	66	91	2000
LRWS5-1	WL51XD	11/25/1997	PHASE 2b	IM40	ZINC	4390		UG/L	66	91	2000
LRWS5-1	WL51XL	11/25/1997	PHASE 2b	IM40	ZINC	3900		UG/L	66	91	2000
LRWS5-1	WL51XA	1/25/1999	PHASE 2b	IM40MB	ZINC	3980		UG/L	66	91	2000
LRWS5-1	WL51XL	1/25/1999	PHASE 2b	IM40MB	ZINC	3770		UG/L	66	91	2000
LRWS6-1	WL61XA	11/17/1997	OTHER	IM40	ZINC	3480		UG/L	184	199	2000
LRWS6-1	WL61XL	11/17/1997	OTHER	IM40	ZINC	2600		UG/L	184	199	2000
LRWS6-1	WL61XA	1/28/1999	OTHER	IM40MB	ZINC	2240		UG/L	184	199	2000
LRWS6-1	WL61XL	1/28/1999	OTHER	IM40MB	ZINC	2200		UG/L	184	199	2000
LRWS7-1	WL71XA	11/21/1997	J-2 RANGE	IM40	ZINC	4320		UG/L	186	201	2000
LRWS7-1	WL71XL	11/21/1997	J-2 RANGE	IM40	ZINC	3750		UG/L	186	201	2000
LRWS7-1	WL71XA	1/22/1999	J-2 RANGE	IM40MB	ZINC	4160		UG/L	186	201	2000
LRWS7-1	WL71XL	1/22/1999	J-2 RANGE	IM40MB	ZINC	4100		UG/L	186	201	2000
MW-01M2	MW-01M2	12/6/2007	CIA	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.3		ug/L	160	165	2
MW-01M2	MW-01M2	12/6/2007		SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.3		UG/L	0	0	2
MW-01M2	MW-01M2_SPR08	6/3/2008	CIA [108]	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.1		UG/L	160	165	2

AOC = Area of Concern  
J = Estimated Result

BWTS = Depth Below Water Table Start (feet)

BWTE = Depth Below Water Table End (feet)

DW Limit = Either the MCL or Lowest Health Advisory Limit

TABLE 4

## VALIDATED DETECTS EXCEEDING MCLs or HEALTH ADVISORY LIMITS 1997 THROUGH September 2008

LOCID/WELL ID	SAMPLE_ID	SAMPLED	AOC	METHOD	ANALYTE	CONC	FLAG	UNITS	BWTS	BWTE	DW LIMIT
MW-1	W01MMA	9/29/1997	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.6		UG/L	44	49	2
MW-1	W01SSA	9/30/1997	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.5		UG/L	0	10	2
MW-1	W01SSD	9/30/1997	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.4		UG/L	0	10	2
MW-1	W01SSA	2/22/1999	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.8		UG/L	0	10	2
MW-1	W01M2A	3/1/1999	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.2		UG/L	44	49	2
MW-1	W01SSA	9/7/1999	CIA	IM40MB	ANTIMONY	6.7	J	UG/L	0	10	6
MW-1	W01SSA	9/7/1999	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.5		UG/L	0	10	2
MW-1	W01SSA	9/7/1999	CIA	IM40MB	THALLIUM	2.9	J	UG/L	0	10	2
MW-1	71MW0001M2-	3/14/2000	CS-19	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.9		UG/L			2
MW-1	W01M2A	5/10/2000	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.9		UG/L	44	49	2
MW-1	W01SSA	5/31/2000	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.1	J	UG/L	0	10	2
MW-1	W01M2A	7/31/2000	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.4	J	UG/L	44	49	2
MW-1	W01SSA	7/31/2000	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.8	J	UG/L	0	10	2
MW-1	W01M2A	11/18/2000	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	8.1		UG/L	44	49	2
MW-1	W01M2D	11/18/2000	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	8		UG/L	44	49	2
MW-1	W01SSA	11/18/2000	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5.2		UG/L	0	10	2
MW-1	W01SSA	12/12/2000	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	6.1	J	UG/L	0	10	2
MW-1	W01SSD	12/12/2000	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5.4		UG/L	0	10	2
MW-1	W01M2A	5/1/2001	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	7.8		UG/L	44	49	2
MW-1	W01M2A	8/15/2001	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	11		UG/L	44	49	2
MW-1	W01SSA	8/16/2001	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.3		UG/L	0	10	2
MW-1	W01M2A	11/30/2001	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	8.9		UG/L	44	49	2
MW-1	W01SSA	1/10/2002	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5.2	J	UG/L	0	10	2
MW-1	W01M2A	5/22/2002	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.4		UG/L	44	49	2
MW-1	W01M2A	1/15/2003	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.2		UG/L	44	49	2
MW-1	W01M2A	5/13/2003	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5.7		UG/L	44	49	2
MW-1	W01SSA	5/14/2003	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.1		UG/L	0	10	2
MW-1	W01SSA	11/14/2003	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.1		UG/L	0	10	2
MW-1	W01M2A	11/17/2003	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	7.4		UG/L	44	49	2
MW-1	W01M2A	2/25/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	6.8		UG/L	44	49	2
MW-1	W01SSA	2/25/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.6		UG/L	0	10	2
MW-1	W01M2A	9/28/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	8.3		UG/L	44	49	2
MW-1	W01M2A	12/21/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	6.5	J	UG/L	44	49	2
MW-1	W01M2A	4/28/2005	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3		UG/L	44	49	2
MW-1	W01M2A	9/6/2005	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	6		UG/L	44	49	2
MW-1	W01M2D	9/6/2005	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	6.5		UG/L	44	49	2
MW-1	W01SSA	9/6/2005	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.6		UG/L	0	10	2
MW-1	W01M2A	12/14/2005	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	9.5		UG/L	44	49	2
MW-1	W01M2D	12/14/2005	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	10		UG/L	44	49	2
MW-1	W01SSA	12/14/2005	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.4		UG/L	0	10	2
MW-1	W01SSA	5/1/2006	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.1		UG/L	0	10	2
MW-1	W01M2A	10/3/2006	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.5		UG/L	44	49	2
MW-10	W10SSA	9/16/1999	CIA	OC21B	BIS(2-ETHYLHEXYL) PHTHALATE	39		UG/L	0	10	6
MW-100	W100M1A	6/6/2000	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.3		UG/L	45	55	2
MW-100	W100M1D	6/6/2000	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.3		UG/L	45	55	2
MW-100	W100M1A	10/2/2000	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.9		UG/L	45	55	2
MW-100	W100M1A	1/27/2001	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.9		UG/L	45	55	2

AOC = Area of Concern  
J = Estimated Result

BWTS = Depth Below Water Table Start (feet)

BWTE = Depth Below Water Table End (feet)

DW Limit = Either the MCL or Lowest Health Advisory Limit

TABLE 4

## VALIDATED DETECTS EXCEEDING MCLs or HEALTH ADVISORY LIMITS 1997 THROUGH September 2008

LOCID/WELL ID	SAMPLE_ID	SAMPLED	AOC	METHOD	ANALYTE	CONC	FLAG	UNITS	BWTS	BWTE	DW LIMIT
MW-100	W100M1A	10/23/2001	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.9		UG/L	45	55	2
MW-100	W100M1D	10/23/2001	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.9		UG/L	45	55	2
MW-100	W100M1A	11/27/2001	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3		UG/L	45	55	2
MW-100	W100M1A	5/21/2002	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.1		UG/L	45	55	2
MW-100	W100M1A	9/24/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2		UG/L	45	55	2
MW-100	W100M1A	1/11/2005	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.1		UG/L	45	55	2
MW-100	W100M1A	5/20/2005	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.1		UG/L	45	55	2
MW-100	W100M1D	5/20/2005	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2		UG/L	45	55	2
MW-100	W100M1A	8/22/2005	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.2		UG/L	45	55	2
MW-100	W100M1A	1/23/2006	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2		UG/L	45	55	2
MW-101M1	W101M1A	6/6/2000	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.5		UG/L	27	37	2
MW-101M1	W101M1A	1/20/2001	CIA	E314.0	PERCHLORATE	3	J	UG/L	27	37	2
MW-101M1	W101M1A	10/23/2001	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.3		UG/L	27	37	2
MW-101M1	W101M1A	11/27/2001	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4		UG/L	27	37	2
MW-101M1	W101M1A	5/21/2002	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.2		UG/L	27	37	2
MW-101M1	W101M1A	9/19/2002	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.8		UG/L	27	37	2
MW-101M1	W101M1A	11/21/2002	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.7		UG/L	27	37	2
MW-101M1	W101M1A	2/26/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.1		UG/L	27	37	2
MW-101M1	W101M1D	2/26/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.1		UG/L	27	37	2
MW-101M1	W101M1A	5/5/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.9		UG/L	27	37	2
MW-101M1	W101M1A	9/24/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.7		UG/L	27	37	2
MW-101M1	W101M1A	11/18/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.8		UG/L	27	37	2
MW-101M1	W101M1A	1/19/2006	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.1		UG/L	27	37	2
MW-101M1	W101M1A	11/15/2006	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4		UG/L	27	37	2
MW-101M1	MW-101M1	6/12/2007	CIA	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.6		UG/L	27	37	2
MW-101M1	MW-101M1_SPR08	5/22/2008	CIA [108]	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.6		UG/L	27	37	2
MW-102	W102M2A	10/26/2006	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.8		UG/L	93	103	2
MW-105	W105M1A	6/21/2000	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5.9		UG/L	78	88	2
MW-105	W105M1A	11/7/2000	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.9		UG/L	78	88	2
MW-105	W105M1A	1/27/2001	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.3		UG/L	78	88	2
MW-105	W105M1A	10/22/2001	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.1	J	UG/L	78	88	2
MW-105	W105M1A	11/26/2001	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.1		UG/L	78	88	2
MW-105	W105M1A	5/21/2002	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.3		UG/L	78	88	2
MW-105	W105M1A	12/21/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.6		UG/L	78	88	2
MW-105	W105M1A	5/2/2005	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.6		UG/L	78	88	2
MW-105	W105M1A	8/2/2005	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.7		UG/L	78	88	2
MW-105	W105M1A	1/23/2006	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.8		UG/L	78	88	2
MW-105	W105M1A	5/2/2006	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.3		UG/L	78	88	2
MW-105	W105M1A	10/17/2006	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.8		UG/L	78	88	2
MW-107M2	W107M2A	6/21/2000	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4		UG/L	5	15	2
MW-107M2	W107M2A	11/7/2000	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.1		UG/L	5	15	2
MW-107M2	W107M2A	10/22/2001	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.4		UG/L	5	15	2
MW-107M2	W107M2A	11/29/2001	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.2	J	UG/L	5	15	2
MW-107M2	W107M2D	11/29/2001	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.2	J	UG/L	5	15	2
MW-107M2	W107M2A	9/12/2002	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.7		UG/L	5	15	2
MW-107M2	W107M2A	11/22/2002	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.8		UG/L	5	15	2
MW-107M2	W107M2A	4/9/2003	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.2	J	UG/L	5	15	2

AOC = Area of Concern  
J = Estimated Result

BWTS = Depth Below Water Table Start (feet)

BWTE = Depth Below Water Table End (feet)

DW Limit = Either the MCL or Lowest Health Advisory Limit

TABLE 4

## VALIDATED DETECTS EXCEEDING MCLs or HEALTH ADVISORY LIMITS 1997 THROUGH September 2008

LOCID/WELL ID	SAMPLE_ID	SAMPLED	AOC	METHOD	ANALYTE	CONC	FLAG	UNITS	BWTS	BWTE	DW LIMIT
MW-107M2	W107M2A	3/2/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.4		UG/L	5	15	2
MW-107M2	W107M2A	4/26/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.4		UG/L	5	15	2
MW-107M2	W107M2A	4/27/2005	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.7		UG/L	5	15	2
MW-107M2	W107M2D	4/27/2005	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.7		UG/L	5	15	2
MW-107M2	W107M2A	9/12/2005	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.9		UG/L	5	15	2
MW-107M2	W107M2A	4/24/2006	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3		UG/L	5	15	2
MW-107M2	MW-107M2	5/31/2007	CIA	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.4		UG/L	5	15	2
MW-107M2	MW-107M2	5/31/2007	CIA	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.7		UG/L	5	15	2
MW-107M2	MW-107M2_SPR08	5/23/2008	CIA [108]	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.3		UG/L	5	15	2
MW-107M2	MW-107M2_SPR08D	5/23/2008	CIA [108]	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.3		UG/L	5	15	2
MW-11	W11SSA	11/6/1997	CIA	OC21B	BIS(2-ETHYLHEXYL) PHTHALATE	33	J	UG/L	0	10	6
MW-11	W11SSD	11/6/1997	CIA	OC21B	BIS(2-ETHYLHEXYL) PHTHALATE	23	J	UG/L	0	10	6
MW-111	W111M3A	10/10/2000	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.2		UG/L	33	43	2
MW-112M2	W112M2A	4/25/2003	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2		UG/L	26	36	2
MW-112M2	W112M2A	10/30/2003	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.1		UG/L	26	36	2
MW-112M2	W112M2A	2/19/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.4		UG/L	26	36	2
MW-112M2	W112M2A	11/9/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.3		UG/L	26	36	2
MW-112M2	W112M2A	3/28/2005	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.2		UG/L	26	36	2
MW-112M2	W112M2A	8/29/2005	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.1		UG/L	26	36	2
MW-112M2	W112M2A	4/19/2006	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.2		UG/L	26	36	2
MW-112M2	MW-112M2	5/4/2007	CIA	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.4		UG/L	26	36	2
MW-112M2	MW-112M2_SPR08	5/27/2008	CIA [108]	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.3		UG/L	26	36	2
MW-113M2	W113M2A	9/26/2000	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	9.2		UG/L	48	58	2
MW-113M2	W113M2A	1/15/2001	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	11		UG/L	48	58	2
MW-113M2	W113M2A	4/30/2001	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	15		UG/L	48	58	2
MW-113M2	W113M2A	12/3/2001	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	12		UG/L	48	58	2
MW-113M2	W113M2A	5/9/2002	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	7		UG/L	48	58	2
MW-113M2	W113M2A	9/17/2002	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5.5		UG/L	48	58	2
MW-113M2	W113M2A	11/26/2002	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.2		UG/L	48	58	2
MW-113M2	W113M2A	4/30/2003	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.9		UG/L	48	58	2
MW-113M2	W113M2D	4/30/2003	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5		UG/L	48	58	2
MW-113M2	W113M2A	11/18/2003	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	7.6		UG/L	48	58	2
MW-113M2	W113M2A	2/19/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	8.6		UG/L	48	58	2
MW-113M2	W113M2D	2/19/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	8.3		UG/L	48	58	2
MW-113M2	W113M2A	4/27/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	8.5		UG/L	48	58	2
MW-113M2	W113M2A	8/10/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	8.4		UG/L	48	58	2
MW-113M2	W113M2A	11/5/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	8		UG/L	48	58	2
MW-113M2	W113M2A	3/28/2005	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	7.6		UG/L	48	58	2
MW-113M2	W113M2A	8/8/2005	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	9.8	J	UG/L	48	58	2
MW-113M2	W113M2A	11/28/2005	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	9.8		UG/L	48	58	2
MW-113M2	W113M2A	5/2/2006	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	6		UG/L	48	58	2
MW-113M2	W113M2A	10/17/2006	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.1		UG/L	48	58	2
MW-113M2	MW-113M2	5/4/2007	CIA	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.8		UG/L	48	58	2
MW-113M2	MW-113M2_FD	5/4/2007	CIA	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.9		UG/L	48	58	2
MW-113M2	MW-113M2	10/17/2007	CIA	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5.9		ug/L	48	58	2
MW-113M2	MW-113M2_SPR08	5/27/2008	CIA [108]	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.1		UG/L	190	200	2
MW-113M2	MW-113M2_SPR08D	5/27/2008	CIA [108]	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4		UG/L	190	200	2

AOC = Area of Concern  
J = Estimated Result

BWTS = Depth Below Water Table Start (feet)  
BWTE = Depth Below Water Table End (feet)  
DW Limit = Either the MCL or Lowest Health Advisory Limit

TABLE 4

## VALIDATED DETECTS EXCEEDING MCLs or HEALTH ADVISORY LIMITS 1997 THROUGH September 2008

LOCID/WELL ID	SAMPLE_ID	SAMPLED	AOC	METHOD	ANALYTE	CONC	FLAG	UNITS	BWTS	BWTE	DW LIMIT
MW-114M1	W114M1A	12/28/2000	DEMO 1	E314.0	PERCHLORATE	11		UG/L	96	106	2
MW-114M1	W114M1A	3/14/2001	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2	J	UG/L	96	106	2
MW-114M1	W114M1A	3/14/2001	DEMO 1	E314.0	PERCHLORATE	13		UG/L	96	106	2
MW-114M1	W114M1A	6/18/2001	DEMO 1	E314.0	PERCHLORATE	10		UG/L	96	106	2
MW-114M1	W114M1A	12/21/2001	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.3		UG/L	96	106	2
MW-114M1	W114M1A	12/21/2001	DEMO 1	E314.0	PERCHLORATE	22.1		UG/L	96	106	2
MW-114M1	W114M1A	6/21/2002	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.1		UG/L	96	106	2
MW-114M1	W114M1A	6/21/2002	DEMO 1	E314.0	PERCHLORATE	12		UG/L	96	106	2
MW-114M1	W114M1A	8/9/2002	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.5		UG/L	96	106	2
MW-114M1	W114M1A	8/9/2002	DEMO 1	E314.0	PERCHLORATE	14		UG/L	96	106	2
MW-114M1	W114M1A	11/13/2002	DEMO 1	E314.0	PERCHLORATE	11		UG/L	96	106	2
MW-114M1	W114M1A	5/27/2003	DEMO 1	E314.0	PERCHLORATE	9.6		UG/L	96	106	2
MW-114M1	W114M1A	10/2/2003	DEMO 1	E314.0	PERCHLORATE	7.7	J	UG/L	96	106	2
MW-114M1	W114M1A	2/9/2004	DEMO 1	E314.0	PERCHLORATE	13.4		UG/L	96	106	2
MW-114M1	W114M1A	4/19/2004	DEMO 1	E314.0	PERCHLORATE	9.67		UG/L	96	106	2
MW-114M1	W114M1A	7/30/2004	DEMO 1	E314.0	PERCHLORATE	4.36		UG/L	96	106	2
MW-114M1	MW-114M1	4/19/2007	DEMO 1	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.02		UG/L	96	106	2
MW-114M1	MW-114M1	4/19/2007	DEMO 1	E314.0	PERCHLORATE	2.91		UG/L	96	106	2
MW-114M1	1937	4/8/2008	DEMO 1	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	10.6	J	UG/L	96	106	2
MW-114M1	1937	4/8/2008	DEMO 1	E314.0	PERCHLORATE	9.23		UG/L	96	106	2
MW-114M2	W114M2A	10/24/2000	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	140		UG/L	39	49	2
MW-114M2	W114M2D	10/24/2000	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	140		UG/L	39	49	2
MW-114M2	W114M2A	12/29/2000	DEMO 1	E314.0	PERCHLORATE	300		UG/L	39	49	2
MW-114M2	W114M2A	3/14/2001	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	120	J	UG/L	39	49	2
MW-114M2	W114M2A	3/14/2001	DEMO 1	E314.0	PERCHLORATE	260		UG/L	39	49	2
MW-114M2	W114M2A	6/19/2001	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	140		UG/L	39	49	2
MW-114M2	W114M2A	6/19/2001	DEMO 1	E314.0	PERCHLORATE	207		UG/L	39	49	2
MW-114M2	W114M2A	1/7/2002	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	170		UG/L	39	49	2
MW-114M2	W114M2A	1/10/2002	DEMO 1	E314.0	PERCHLORATE	127		UG/L	39	49	2
MW-114M2	W114M2A	5/29/2002	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	190		UG/L	39	49	2
MW-114M2	W114M2A	5/29/2002	DEMO 1	E314.0	PERCHLORATE	72		UG/L	39	49	2
MW-114M2	W114M2A	8/9/2002	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	210		UG/L	39	49	2
MW-114M2	W114M2A	8/9/2002	DEMO 1	E314.0	PERCHLORATE	64		UG/L	39	49	2
MW-114M2	W114M2A	11/13/2002	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	220		UG/L	39	49	2
MW-114M2	W114M2A	11/13/2002	DEMO 1	E314.0	PERCHLORATE	71		UG/L	39	49	2
MW-114M2	W114M2A	5/27/2003	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	200		UG/L	39	49	2
MW-114M2	W114M2A	5/27/2003	DEMO 1	E314.0	PERCHLORATE	56		UG/L	39	49	2
MW-114M2	W114M2A	10/1/2003	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	220		UG/L	39	49	2
MW-114M2	W114M2A	10/1/2003	DEMO 1	E314.0	PERCHLORATE	52	J	UG/L	39	49	2
MW-114M2	W114M2A	2/9/2004	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	210		UG/L	39	49	2
MW-114M2	W114M2A	2/9/2004	DEMO 1	E314.0	PERCHLORATE	42.3		UG/L	39	49	2
MW-114M2	W114M2A	4/19/2004	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	180		UG/L	39	49	2
MW-114M2	W114M2A	4/19/2004	DEMO 1	E314.0	PERCHLORATE	37.7		UG/L	39	49	2
MW-114M2	W114M2A	7/30/2004	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	160		UG/L	39	49	2
MW-114M2	W114M2A	7/30/2004	DEMO 1	E314.0	PERCHLORATE	40.8		UG/L	39	49	2
MW-114M2	W114M2A	4/13/2005	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	140		UG/L	39	49	2
MW-114M2	W114M2A	4/13/2005	DEMO 1	E314.0	PERCHLORATE	54		UG/L	39	49	2

AOC = Area of Concern  
J = Estimated Result

BWTS = Depth Below Water Table Start (feet)  
BWTE = Depth Below Water Table End (feet)  
DW Limit = Either the MCL or Lowest Health Advisory Limit

TABLE 4

## VALIDATED DETECTS EXCEEDING MCLs or HEALTH ADVISORY LIMITS 1997 THROUGH September 2008

LOCID/WELL ID	SAMPLE_ID	SAMPLED	AOC	METHOD	ANALYTE	CONC	FLAG	UNITS	BWTS	BWTE	DW LIMIT
MW-114M2	MW-114M2-	4/18/2006	DEMO 1	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	220	J	UG/L	39	49	2
MW-114M2	MW-114M2-	4/18/2006	DEMO 1	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	240		UG/L	39	49	2
MW-114M2	MW-114M2-	4/18/2006	DEMO 1	E314.0	PERCHLORATE	103		UG/L	39	49	2
MW-114M2	MW-114M2	4/19/2007	DEMO 1	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	86.5		UG/L	39	49	2
MW-114M2	MW-114M2	4/19/2007	DEMO 1	E314.0	PERCHLORATE	92.7		UG/L	39	49	2
MW-114M2	1918	12/6/2007	DEMO 1	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	112	J	UG/L	120	130	2
MW-114M2	1919	12/6/2007	DEMO 1	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	195	J	UG/L	120	130	2
MW-114M2	1919	12/6/2007	DEMO 1	E314.0	PERCHLORATE	38.6		UG/L	120	130	2
MW-114M2	MW-114M2	1/31/2008	Demo 1	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	102		UG/L	39	49	2
MW-114M2	1938	4/8/2008	DEMO 1	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	33.7		UG/L	120	130	2
MW-114M2	1938	4/8/2008	DEMO 1	E314.0	PERCHLORATE	13.3		UG/L	120	130	2
MW-12	W12SSA	11/6/1997	CIA	OC21B	BIS(2-ETHYLHEXYL) PHTHALATE	28		UG/L	0	10	6
MW-125	W125M1A	2/20/2001	J-3 RANGE	E314.0	PERCHLORATE	3	J	UG/L	182	192	2
MW-127	W127SSA	11/15/2000	J-1 RANGE	IM40MB	THALLIUM	2.4	J	UG/L	0	10	2
MW-127	W127SSA	2/14/2001	J-1 RANGE	E314.0	PERCHLORATE	4	J	UG/L	0	10	2
MW-128	W128SSA	2/14/2001	J-3 RANGE	E314.0	PERCHLORATE	3	J	UG/L	0	10	2
MW-129M1	W129M1A	1/2/2001	DEMO 1	E314.0	PERCHLORATE	10		UG/L	66	76	2
MW-129M1	W129M1A	3/14/2001	DEMO 1	E314.0	PERCHLORATE	9		UG/L	66	76	2
MW-129M1	W129M1A	6/19/2001	DEMO 1	E314.0	PERCHLORATE	6		UG/L	66	76	2
MW-129M1	W129M1A	12/21/2001	DEMO 1	E314.0	PERCHLORATE	5.92	J	UG/L	66	76	2
MW-129M1	W129M1A	4/12/2002	DEMO 1	E314.0	PERCHLORATE	4.63		UG/L	66	76	2
MW-129M1	W129M3A	8/19/2002	DEMO 1	E314.0	PERCHLORATE	2	J	UG/L	26	36	2
MW-129M1	W129M1A	11/13/2002	DEMO 1	E314.0	PERCHLORATE	2.2		UG/L	66	76	2
MW-129M1	W129M1A	3/21/2003	DEMO 1	E314.0	PERCHLORATE	5.9	J	UG/L	66	76	2
MW-129M1	W129M1A	10/2/2003	DEMO 1	E314.0	PERCHLORATE	8.5	J	UG/L	66	76	2
MW-129M1	W129M1A	2/10/2004	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.2		UG/L	66	76	2
MW-129M1	W129M1A	2/10/2004	DEMO 1	E314.0	PERCHLORATE	6.62		UG/L	66	76	2
MW-129M1	W129M1A	4/7/2004	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.5		UG/L	66	76	2
MW-129M1	W129M1A	4/7/2004	DEMO 1	E314.0	PERCHLORATE	6.54		UG/L	66	76	2
MW-129M1	W129M1A	8/6/2004	DEMO 1	E314.0	PERCHLORATE	3.68		UG/L	66	76	2
MW-129M1	MW-129M1-	4/19/2006	DEMO 1	E314.0	PERCHLORATE	4.34		UG/L	66	76	2
MW-129M1	MW-129M1	4/18/2007	DEMO 1	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	7.79	J	UG/L	66	76	2
MW-129M1	MW-129M1	4/18/2007	DEMO 1	E314.0	PERCHLORATE	28	J	UG/L	66	76	2
MW-129M1	1939	4/22/2008	DEMO 1	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	16.8		UG/L	66	76	2
MW-129M1	1939	4/22/2008	DEMO 1	E314.0	PERCHLORATE	21.2		UG/L	66	76	2
MW-129M2	W129M2A	3/14/2001	DEMO 1	E314.0	PERCHLORATE	6		UG/L	46	56	2
MW-129M2	W129M2A	6/20/2001	DEMO 1	E314.0	PERCHLORATE	8		UG/L	46	56	2
MW-129M2	W129M2A	12/21/2001	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	10		UG/L	46	56	2
MW-129M2	W129M2A	12/21/2001	DEMO 1	E314.0	PERCHLORATE	6.93	J	UG/L	46	56	2
MW-129M2	W129M2A	6/27/2002	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	7.6		UG/L	46	56	2
MW-129M2	W129M2D	6/27/2002	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	7.9		UG/L	46	56	2
MW-129M2	W129M2A	7/10/2002	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	7.9		UG/L	46	56	2
MW-129M2	W129M2A	8/19/2002	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	8.4		UG/L	46	56	2
MW-129M2	W129M2A	8/19/2002	DEMO 1	E314.0	PERCHLORATE	13		UG/L	46	56	2
MW-129M2	W129M2A	11/13/2002	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	13	J	UG/L	46	56	2
MW-129M2	W129M2A	11/13/2002	DEMO 1	E314.0	PERCHLORATE	16		UG/L	46	56	2
MW-129M2	W129M2D	11/13/2002	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	13		UG/L	46	56	2

AOC = Area of Concern

J = Estimated Result

BWTS = Depth Below Water Table Start (feet)

BWTE = Depth Below Water Table End (feet)

DW Limit = Either the MCL or Lowest Health Advisory Limit

TABLE 4

## VALIDATED DETECTS EXCEEDING MCLs or HEALTH ADVISORY LIMITS 1997 THROUGH September 2008

LOCID/WELL ID	SAMPLE_ID	SAMPLED	AOC	METHOD	ANALYTE	CONC	FLAG	UNITS	BWTS	BWTE	DW LIMIT
MW-129M2	W129M2D	11/13/2002	DEMO 1	E314.0	PERCHLORATE	15		UG/L	46	56	2
MW-129M2	W129M2A	3/24/2003	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	13		UG/L	46	56	2
MW-129M2	W129M2A	3/24/2003	DEMO 1	E314.0	PERCHLORATE	14	J	UG/L	46	56	2
MW-129M2	W129M2A	10/2/2003	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.8		UG/L	46	56	2
MW-129M2	W129M2A	10/2/2003	DEMO 1	E314.0	PERCHLORATE	6.7	J	UG/L	46	56	2
MW-129M2	W129M2A	2/10/2004	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.8		UG/L	46	56	2
MW-129M2	W129M2A	2/10/2004	DEMO 1	E314.0	PERCHLORATE	5.13		UG/L	46	56	2
MW-129M2	W129M2A	4/7/2004	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.1		UG/L	46	56	2
MW-129M2	W129M2A	4/7/2004	DEMO 1	E314.0	PERCHLORATE	5.27		UG/L	46	56	2
MW-129M2	W129M2A	8/6/2004	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.8		UG/L	46	56	2
MW-129M2	W129M2A	8/6/2004	DEMO 1	E314.0	PERCHLORATE	4.74		UG/L	46	56	2
MW-129M2	W129M2A	4/5/2005	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.4		UG/L	46	56	2
MW-129M2	W129M2A	4/5/2005	DEMO 1	E314.0	PERCHLORATE	4.5	J	UG/L	46	56	2
MW-129M2	MW-129M2-	4/19/2006	DEMO 1	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	14		UG/L	46	56	2
MW-129M2	MW-129M2-	4/19/2006	DEMO 1	E314.0	PERCHLORATE	60.1		UG/L	46	56	2
MW-129M2	MW-129M2	4/19/2007	DEMO 1	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	6.27		UG/L	46	56	2
MW-129M2	MW-129M2	4/19/2007	DEMO 1	E314.0	PERCHLORATE	15.5		UG/L	46	56	2
MW-129M2	1920	12/6/2007	DEMO 1	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	71.9		UG/L	116	126	2
MW-129M2	1920	12/6/2007	DEMO 1	E314.0	PERCHLORATE	35.1		UG/L	46	56	2
MW-129M2	MW-129M2	1/31/2008	Demo 1	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	68.6		UG/L	116	126	2
MW-129M2	MW-129M2	1/31/2008	Demo 1	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	68.6		UG/L	116	126	2
MW-129M2	1940	4/22/2008	DEMO 1	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	61.1		UG/L	116	126	2
MW-129M2	1940	4/22/2008	DEMO 1	E314.0	PERCHLORATE	13.9		UG/L	46	56	2
MW-130	W130SSA	2/14/2001	J-2 RANGE	E314.0	PERCHLORATE	3	J	UG/L	0	10	2
MW-130	W130SSA	6/14/2001	J-2 RANGE	E314.0	PERCHLORATE	3	J	UG/L	0	10	2
MW-130	W130SSD	6/14/2001	J-2 RANGE	E314.0	PERCHLORATE	3	J	UG/L	0	10	2
MW-130	W130SSA	12/13/2001	J-2 RANGE	E314.0	PERCHLORATE	4.21		UG/L	0	10	2
MW-130	W130SSD	12/13/2001	J-2 RANGE	E314.0	PERCHLORATE	4.1		UG/L	0	10	2
MW-130	W130SSA	8/27/2002	J-2 RANGE	E314.0	PERCHLORATE	2.7	J	UG/L	0	10	2
MW-130	W130SSA	3/27/2003	J-2 RANGE	E314.0	PERCHLORATE	3		UG/L	0	10	2
MW-130	W130SSA	11/10/2003	J-2 RANGE	E314.0	PERCHLORATE	2.4		UG/L	0	10	2
MW-130	W130SSA	3/10/2004	J-2 RANGE	E314.0	PERCHLORATE	2.2		UG/L	0	10	2
MW-130	W130SSA	8/2/2004	J-2 RANGE	E314.0	PERCHLORATE	3.6	J	UG/L	0	10	2
MW-130	W130SSA	11/17/2004	J-2 RANGE	E314.0	PERCHLORATE	2.79	J	UG/L	0	10	2
MW-130	W130SSA	3/10/2005	J-2 RANGE	E314.0	PERCHLORATE	3.3		UG/L	0	10	2
MW-130	W130SSA	5/31/2005	J-2 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.4		UG/L	0	10	2
MW-130	W130SSA	5/31/2005	J-2 RANGE	E314.0	PERCHLORATE	2.1		UG/L	0	10	2
MW-130	W130SSA	11/5/2005	J-2 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.3	J	UG/L	0	10	2
MW-130	W130SSA	11/5/2005	J-2 RANGE	E314.0	PERCHLORATE	2.6		UG/L	0	10	2
MW-130	W130SSA	2/1/2006	J-2 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.7		UG/L	0	10	2
MW-130	W130SSA	2/1/2006	J-2 RANGE	E314.0	PERCHLORATE	3.1		UG/L	0	10	2
MW-130	W130SSD	2/1/2006	J-2 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.8		UG/L	0	10	2
MW-130	W130SSD	2/1/2006	J-2 RANGE	E314.0	PERCHLORATE	3.2		UG/L	0	10	2
MW-132	W132SSA	11/9/2000	J-3 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.5	J	UG/L	0	10	2
MW-132	W132SSA	11/9/2000	J-3 RANGE	E314.0	PERCHLORATE	39	J	UG/L	0	10	2
MW-132	W132SSA	2/16/2001	J-3 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.4	J	UG/L	0	10	2
MW-132	W132SSA	2/16/2001	J-3 RANGE	E314.0	PERCHLORATE	65		UG/L	0	10	2

AOC = Area of Concern  
J = Estimated Result

BWTS = Depth Below Water Table Start (feet)

BWTE = Depth Below Water Table End (feet)

DW Limit = Either the MCL or Lowest Health Advisory Limit

TABLE 4

## VALIDATED DETECTS EXCEEDING MCLs or HEALTH ADVISORY LIMITS 1997 THROUGH September 2008

LOCID/WELL ID	SAMPLE_ID	SAMPLED	AOC	METHOD	ANALYTE	CONC	FLAG	UNITS	BWTS	BWTE	DW LIMIT
MW-132	W132SSA	2/16/2001	J-3 RANGE	IM40MB	THALLIUM	2.1	J	UG/L	0	10	2
MW-132	W132SSA	6/15/2001	J-3 RANGE	E314.0	PERCHLORATE	75		UG/L	0	10	2
MW-132	W132SSA	12/12/2001	J-3 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5.8		UG/L	0	10	2
MW-132	W132SSA	12/12/2001	J-3 RANGE	E314.0	PERCHLORATE	27.4		UG/L	0	10	2
MW-132	W132SSA	6/28/2002	J-3 RANGE	E314.0	PERCHLORATE	28		UG/L	0	10	2
MW-132	W132SSA	9/20/2002	J-3 RANGE	E314.0	PERCHLORATE	13	J	UG/L	0	10	2
MW-132	W132SSA	12/10/2002	J-3 RANGE	E314.0	PERCHLORATE	20		UG/L	0	10	2
MW-132	W132SSA	3/27/2003	J-3 RANGE	E314.0	PERCHLORATE	17		UG/L	0	10	2
MW-132	W132SSA	11/4/2003	J-3 RANGE	E314.0	PERCHLORATE	11		UG/L	0	10	2
MW-132	W132SSA	12/18/2003	J-3 RANGE	E314.0	PERCHLORATE	17	J	UG/L	0	10	2
MW-132	W132SSA	5/18/2004	J-3 RANGE	E314.0	PERCHLORATE	13		UG/L	0	10	2
MW-132	W132SSA	10/1/2004	J-3 RANGE	E314.0	PERCHLORATE	7.6		UG/L	0	10	2
MW-132	W132SSA	3/9/2005	J-3 RANGE	E314.0	PERCHLORATE	4.5		UG/L	0	10	2
MW-132	W132SSD	3/9/2005	J-3 RANGE	E314.0	PERCHLORATE	4.6		UG/L	0	10	2
MW-132	W132SSA	6/14/2005	J-3 RANGE	E314.0	PERCHLORATE	2.2		UG/L	0	10	2
MW-139	MW-139M1	4/18/2007	DEMO 1	E314.0	PERCHLORATE	2.55	J	UG/L	110	120	2
MW-139M2	W139M2A	12/29/2000	DEMO 1	E314.0	PERCHLORATE	8		UG/L	154	164	2
MW-139M2	W139M2A	3/15/2001	DEMO 1	E314.0	PERCHLORATE	11	J	UG/L	154	164	2
MW-139M2	W139M2A	6/20/2001	DEMO 1	E314.0	PERCHLORATE	3	J	UG/L	154	164	2
MW-139M2	W139M2A	4/17/2002	DEMO 1	E314.0	PERCHLORATE	2.77		UG/L	154	164	2
MW-139M2	W139M2A	10/10/2003	DEMO 1	E314.0	PERCHLORATE	13		UG/L	154	164	2
MW-139M2	W139M2A	8/4/2004	DEMO 1	E314.0	PERCHLORATE	3.5	J	UG/L	154	164	2
MW-139M2	W139M2A	4/7/2005	DEMO 1	E314.0	PERCHLORATE	2.94		UG/L	154	164	2
MW-139M2	MW-139M2-	4/13/2006	DEMO 1	E314.0	PERCHLORATE	3.86		UG/L	154	164	2
MW-139M2	MW-139M2	1/2/2007	DEMO 1	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.2		UG/L	154	164	2
MW-139M2	MW-139M2	4/18/2007	DEMO 1	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.53		UG/L	154	164	2
MW-139M2	1921	12/6/2007	DEMO 1	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.63		UG/L	154	164	2
MW-139M2	1943	4/8/2008	DEMO 1	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.02		UG/L	154	164	2
MW-139M2	1943	4/8/2008	DEMO 1	E314.0	PERCHLORATE	10.9		UG/L	154	164	2
MW-14	W14SSA	11/4/1997	OTHER	OC21B	BIS(2-ETHYLHEXYL) PHTHALATE	14		UG/L	0	10	6
MW-142M2	W142M1A	1/29/2001	J-3 RANGE	SW8270	BIS(2-ETHYLHEXYL) PHTHALATE	20		UG/L	185	195	6
MW-142M2	W142M2A	1/29/2001	J-3 RANGE	SW8270	BIS(2-ETHYLHEXYL) PHTHALATE	11		UG/L	100	110	6
MW-142M2	W142M2A	12/18/2003	J-3 RANGE	E314.0	PERCHLORATE	2.2	J	UG/L	100	110	2
MW-142M2	W142M2A	9/3/2004	J-3 RANGE	E314.0	PERCHLORATE	2	J	UG/L	100	110	2
MW-142M2	W142M2A	11/17/2004	J-3 RANGE	E314.0	PERCHLORATE	2.22	J	UG/L	100	110	2
MW-142M2	W142M2A	6/3/2005	J-3 RANGE	E314.0	PERCHLORATE	3		UG/L	100	110	2
MW-142M2	W142M2A	7/21/2005	J-3 RANGE	E314.0	PERCHLORATE	2.1		UG/L	100	110	2
MW-142M2	W142M2A	12/13/2005	J-3 RANGE	E314.0	PERCHLORATE	2.8		UG/L	100	110	2
MW-142M2	MW-142M2	9/5/2007	J-3 RANGE	E314.0	PERCHLORATE	37.3	J	UG/L	100	110	2
MW-142M2	MW-142M2_FAL08	8/8/2008	J-3 RANGE	E314.0	PERCHLORATE	12.5		UG/L	10	110	2
MW-143	W143M3A	9/6/2002	J-3 RANGE	E314.0	PERCHLORATE	2.3		UG/L	77	82	2
MW-143	W143M3A	11/25/2002	J-3 RANGE	E314.0	PERCHLORATE	2.4		UG/L	77	82	2
MW-143	W143M2A	6/2/2003	J-3 RANGE	E314.0	PERCHLORATE	3.6		UG/L	87	92	2
MW-143	W143M3A	6/4/2003	J-3 RANGE	E314.0	PERCHLORATE	2.5		UG/L	77	82	2
MW-143	W143M2A	8/28/2003	J-3 RANGE	E314.0	PERCHLORATE	3.02		UG/L	87	92	2
MW-143	W143M3A	8/28/2003	J-3 RANGE	E314.0	PERCHLORATE	2.4		UG/L	77	82	2
MW-143	W143M3D	8/28/2003	J-3 RANGE	E314.0	PERCHLORATE	2.3		UG/L	77	82	2

AOC = Area of Concern  
J = Estimated Result

BWTS = Depth Below Water Table Start (feet)

BWTE = Depth Below Water Table End (feet)

DW Limit = Either the MCL or Lowest Health Advisory Limit

TABLE 4

## VALIDATED DETECTS EXCEEDING MCLs or HEALTH ADVISORY LIMITS 1997 THROUGH September 2008

LOCID/WELL ID	SAMPLE_ID	SAMPLED	AOC	METHOD	ANALYTE	CONC	FLAG	UNITS	BWTS	BWTE	DW LIMIT
MW-143	W143M1A	12/18/2003	J-3 RANGE	E314.0	PERCHLORATE	2.6	J	UG/L	114	124	2
MW-143	W143M2A	12/18/2003	J-3 RANGE	E314.0	PERCHLORATE	4.4	J	UG/L	87	92	2
MW-143	W143M3A	12/18/2003	J-3 RANGE	E314.0	PERCHLORATE	3.1	J	UG/L	77	82	2
MW-143	W143M3D	12/18/2003	J-3 RANGE	E314.0	PERCHLORATE	3	J	UG/L	77	82	2
MW-143	W143M1A	5/7/2004	J-3 RANGE	E314.0	PERCHLORATE	5	J	UG/L	114	124	2
MW-143	W143M2A	5/7/2004	J-3 RANGE	E314.0	PERCHLORATE	5.7	J	UG/L	87	92	2
MW-143	W143M3A	5/7/2004	J-3 RANGE	E314.0	PERCHLORATE	12	J	UG/L	77	82	2
MW-143	W143M3D	5/7/2004	J-3 RANGE	E314.0	PERCHLORATE	12	J	UG/L	77	82	2
MW-143	W143M1A	9/20/2004	J-3 RANGE	E314.0	PERCHLORATE	5.5	UG/L	114	124	2	
MW-143	W143M2A	9/20/2004	J-3 RANGE	E314.0	PERCHLORATE	7.3	UG/L	87	92	2	
MW-143	W143M3A	9/20/2004	J-3 RANGE	E314.0	PERCHLORATE	12	UG/L	77	82	2	
MW-143	W143M2A	1/6/2005	J-3 RANGE	E314.0	PERCHLORATE	7.5	UG/L	87	92	2	
MW-143	W143M3A	1/11/2005	J-3 RANGE	E314.0	PERCHLORATE	10	UG/L	77	82	2	
MW-143	W143M1A	1/12/2005	J-3 RANGE	E314.0	PERCHLORATE	4	UG/L	114	124	2	
MW-143	W143M1A	6/13/2005	J-3 RANGE	E314.0	PERCHLORATE	4.9	UG/L	114	124	2	
MW-143	W143M2A	6/13/2005	J-3 RANGE	E314.0	PERCHLORATE	7	UG/L	87	92	2	
MW-143	W143M3A	6/13/2005	J-3 RANGE	E314.0	PERCHLORATE	13	UG/L	77	82	2	
MW-143	W143M2A	7/28/2005	J-3 RANGE	E314.0	PERCHLORATE	5.8	UG/L	87	92	2	
MW-143	W143M3A	7/28/2005	J-3 RANGE	E314.0	PERCHLORATE	11.3	UG/L	77	82	2	
MW-143	W143M1A	8/19/2005	J-3 RANGE	E314.0	PERCHLORATE	5.2	UG/L	114	124	2	
MW-143	W143M1A	12/12/2005	J-3 RANGE	E314.0	PERCHLORATE	5.5	UG/L	114	124	2	
MW-143	W143M2A	12/12/2005	J-3 RANGE	E314.0	PERCHLORATE	9.5	UG/L	87	92	2	
MW-143	W143M2D	12/12/2005	J-3 RANGE	E314.0	PERCHLORATE	9.5	UG/L	87	92	2	
MW-143	W143M3A	12/13/2005	J-3 RANGE	E314.0	PERCHLORATE	15.8	UG/L	77	82	2	
MW-143	MW-143M2	9/5/2007	J-3 RANGE	E314.0	PERCHLORATE	5.9	J	UG/L	87	92	2
MW-143	MW-143M3	9/5/2007	J-3 RANGE	E314.0	PERCHLORATE	8.15	J	UG/L	77	82	2
MW-143M3	MW-143M3_FAL08	8/13/2008	J-3 RANGE	E314.0	PERCHLORATE	15.7	UG/L	77	82	2	
MW-144	W144SSA	6/18/2001	J-3 RANGE	IM40MB	SODIUM	77200	UG/L	5	15	20000	
MW-144	W144SSA	9/6/2002	J-3 RANGE	IM40MB	SODIUM	43000	UG/L	5	15	20000	
MW-144	W144SSA	11/25/2002	J-3 RANGE	IM40MB	SODIUM	28100	UG/L	5	15	20000	
MW-144	W144SSA	10/16/2003	J-3 RANGE	IM40MB	SODIUM	31400	UG/L	5	15	20000	
MW-144	W144SSA	12/18/2003	J-3 RANGE	IM40MB	SODIUM	27800	UG/L	5	15	20000	
MW-145	W145SSA	2/12/2001	J-3 RANGE	IM40MB	SODIUM	37000	UG/L	0	10	20000	
MW-145	W145SSA	6/20/2001	J-3 RANGE	IM40MB	SODIUM	73600	UG/L	0	10	20000	
MW-145	W145SSA	10/18/2001	J-3 RANGE	IM40MB	THALLIUM	4.8	J	UG/L	0	10	2
MW-145	W145SSA	6/28/2002	J-3 RANGE	IM40MB	SODIUM	53300	UG/L	0	10	20000	
MW-145	W145SSA	12/2/2002	J-3 RANGE	IM40MB	SODIUM	24100	UG/L	0	10	20000	
MW-145	W145SSA	11/4/2003	J-3 RANGE	IM40MB	SODIUM	77200	UG/L	0	10	20000	
MW-146	W146M1A	2/23/2001	L RANGE	SW8270	BIS(2-ETHYLHEXYL) PHTHALATE	8.4	UG/L	75	80	6	
MW-146	W146M1A	6/19/2001	L RANGE	SW8270	BIS(2-ETHYLHEXYL) PHTHALATE	8.2	UG/L	75	80	6	
MW-147	W147M1A	2/23/2001	L RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.7	UG/L	94	104	2	
MW-147	W147M2A	2/23/2001	L RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3	UG/L	77	87	2	
MW-147	W147M1A	6/19/2001	L RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.2	UG/L	94	104	2	
MW-147	W147M2A	10/24/2001	L RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.9	UG/L	77	87	2	
MW-147	W147M1A	4/29/2002	L RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.1	UG/L	94	104	2	
MW-147	W147M2A	4/29/2002	L RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.3	UG/L	77	87	2	
MW-147	W147M2D	4/29/2002	L RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.3	UG/L	77	87	2	

AOC = Area of Concern  
J = Estimated Result

BWTS = Depth Below Water Table Start (feet)

BWTE = Depth Below Water Table End (feet)

DW Limit = Either the MCL or Lowest Health Advisory Limit

TABLE 4

## VALIDATED DETECTS EXCEEDING MCLs or HEALTH ADVISORY LIMITS 1997 THROUGH September 2008

LOCID/WELL ID	SAMPLE_ID	SAMPLED	AOC	METHOD	ANALYTE	CONC	FLAG	UNITS	BWTS	BWTE	DW LIMIT
MW-147	W147M1A	9/5/2002	L RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.4		UG/L	94	104	2
MW-148	W148SSA	10/18/2001	L RANGE	IM40MB	SODIUM	23500		UG/L	0	10	20000
MW-148	W148SSA	12/2/2002	L RANGE	IM40MB	THALLIUM	3.8	J	UG/L	0	10	2
MW-148	W148SSA	12/18/2003	L RANGE	IM40MB	SODIUM	27800		UG/L	0	10	20000
MW-150	W150SSA	3/7/2001	PHASE 2b	IM40MB	THALLIUM	2.2	J	UG/L	1	11	2
MW-152	W152M1A	10/16/2001	J-3 RANGE; OTHER	IM40MB	ARSENIC	10.9		UG/L	144	154	10
MW-153M1	W153M1A	3/23/2001	L RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	9.2		UG/L	199	209	2
MW-153M1	W153M1A	7/24/2001	L RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	8.8		UG/L	199	209	2
MW-153M1	W153M1A	10/24/2001	L RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	7.8		UG/L	199	209	2
MW-153M1	W153M1A	4/26/2002	L RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	6.7	J	UG/L	199	209	2
MW-153M1	W153M1A	9/30/2002	L RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	6.5		UG/L	199	209	2
MW-153M1	W153M1A	12/2/2002	L RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	6.8		UG/L	199	209	2
MW-153M1	W153M1A	6/24/2003	L RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3		UG/L	199	209	2
MW-153M1	W153M1A	10/30/2003	L RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.4		UG/L	199	209	2
MW-153M1	W153M1A	12/19/2003	L RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5.3		UG/L	199	209	2
MW-153M1	W153M1A	6/14/2004	L RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.6		UG/L	199	209	2
MW-153M1	W153M1A	9/23/2004	L RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.5		UG/L	199	209	2
MW-153M1	W153M1A	12/3/2004	L RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5.4		UG/L	199	209	2
MW-153M1	W153M1A	5/24/2005	L RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.2		UG/L	199	209	2
MW-153M1	W153M1A	9/7/2005	L RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.2	J	UG/L	199	209	2
MW-153M1	W153M1A	11/29/2005	L RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.7	J	UG/L	199	209	2
MW-153M1	W153M1D	11/29/2005	L RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.9	J	UG/L	199	209	2
MW-153M1	W153M1A	6/13/2006	L RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.9		UG/L	199	209	2
MW-153M1	MW-153M1-	4/30/2007	L RANGE	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.6		UG/L	199	209	2
MW-153M1	MW-153M1_0308	3/14/2008	L RANGE	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.6		UG/L	199	209	2
MW-153M1	MW-153M1_0308D	3/14/2008	L RANGE	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.8		UG/L	199	209	2
MW-157	W157DDA	5/3/2001	J-3 RANGE	SW8270	BIS(2-ETHYLHEXYL) PHTHALATE	8.1		UG/L	199	209	6
MW-158	W158SSA	6/12/2001	J-2 RANGE	E314.0	PERCHLORATE	2	J	UG/L	2	12	2
MW-158	W158M2A	10/15/2001	J-2 RANGE	SW8270	BIS(2-ETHYLHEXYL) PHTHALATE	34	J	UG/L	37	47	6
MW-16	W16DDA	11/17/1997	DEMO 2	OC21B	BIS(2-ETHYLHEXYL) PHTHALATE	43		UG/L	223	228	6
MW-16	W16SSA	11/17/1997	DEMO 2	OC21B	BIS(2-ETHYLHEXYL) PHTHALATE	28		UG/L	0	10	6
MW-16	W16SSA	11/17/1997	DEMO 2	IM40	SODIUM	20900		UG/L	0	10	20000
MW-16	W16SSL	11/17/1997	DEMO 2	IM40	SODIUM	20400		UG/L	0	10	20000
MW-16	W16SSA	10/3/2003	DEMO 2	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.8		UG/L	0	10	2
MW-160	W160SSA	1/23/2002	DEMO 2	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.2	J	UG/L	5	15	2
MW-162	W162M2A	4/18/2002	DEMO 1	E314.0	PERCHLORATE	2.03		UG/L	49.28	59.28	2
MW-162	W162M2A	8/8/2002	DEMO 1	E314.0	PERCHLORATE	2.4	J	UG/L	49.28	59.28	2
MW-162	W162M2D	8/8/2002	DEMO 1	E314.0	PERCHLORATE	2	J	UG/L	49.28	59.28	2
MW-162	W162M2A	3/27/2003	DEMO 1	E314.0	PERCHLORATE	3.5	J	UG/L	49.28	59.28	2
MW-162	W162M2D	3/27/2003	DEMO 1	E314.0	PERCHLORATE	3.4	J	UG/L	49.28	59.28	2
MW-162	W162M2A	10/10/2003	DEMO 1	E314.0	PERCHLORATE	4.4		UG/L	49.28	59.28	2
MW-162	W162M2A	3/1/2004	DEMO 1	E314.0	PERCHLORATE	3.91	J	UG/L	49.28	59.28	2
MW-162	W162M2A	4/16/2004	DEMO 1	E314.0	PERCHLORATE	4.11		UG/L	49.28	59.28	2
MW-162	W162M2A	7/28/2004	DEMO 1	E314.0	PERCHLORATE	6.2		UG/L	49.28	59.28	2
MW-162	W162M2A	12/7/2004	DEMO 1	E314.0	PERCHLORATE	10	J	UG/L	49.28	59.28	2
MW-162	W162M2A	6/21/2005	DEMO 1	E314.0	PERCHLORATE	5.1	J	UG/L	49.28	59.28	2
MW-162	MW-162M2-	12/12/2005	DEMO 1	E314.0	PERCHLORATE	4.6		UG/L	49.28	59.28	2

AOC = Area of Concern  
J = Estimated Result

BWTS = Depth Below Water Table Start (feet)

BWTE = Depth Below Water Table End (feet)

DW Limit = Either the MCL or Lowest Health Advisory Limit

TABLE 4

## VALIDATED DETECTS EXCEEDING MCLs or HEALTH ADVISORY LIMITS 1997 THROUGH September 2008

LOCID/WELL ID	SAMPLE_ID	SAMPLED	AOC	METHOD	ANALYTE	CONC	FLAG	UNITS	BWTS	BWTE	DW LIMIT
MW-162	MW-162M2-	4/18/2006	DEMO 1	E314.0	PERCHLORATE	4.33		UG/L	49.28	59.28	2
MW-163S	W163SSA	6/14/2001	J-3 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5.7		UG/L	0	10	2
MW-163S	W163SSA	6/14/2001	J-3 RANGE	E314.0	PERCHLORATE	67		UG/L	0	10	2
MW-163S	W163SSA	10/10/2001	J-3 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.8		UG/L	0	10	2
MW-163S	W163SSA	10/10/2001	J-3 RANGE	E314.0	PERCHLORATE	39.6		UG/L	0	10	2
MW-163S	W163SSA	2/5/2002	J-3 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	6.1		UG/L	0	10	2
MW-163S	W163SSA	2/5/2002	J-3 RANGE	E314.0	PERCHLORATE	17.9		UG/L	0	10	2
MW-163S	W163SSA	3/7/2002	J-3 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	6.2		UG/L	0	10	2
MW-163S	W163SSA	3/7/2002	J-3 RANGE	E314.0	PERCHLORATE	33.1		UG/L	0	10	2
MW-163S	W163SSA	7/2/2002	J-3 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	13		UG/L	0	10	2
MW-163S	W163SSA	7/2/2002	J-3 RANGE	E314.0	PERCHLORATE	46		UG/L	0	10	2
MW-163S	W163SSA	1/8/2003	J-3 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.4		UG/L	0	10	2
MW-163S	W163SSA	1/8/2003	J-3 RANGE	E314.0	PERCHLORATE	62		UG/L	0	10	2
MW-163S	W163SSA	3/27/2003	J-3 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.6	J	UG/L	0	10	2
MW-163S	W163SSA	3/27/2003	J-3 RANGE	E314.0	PERCHLORATE	44		UG/L	0	10	2
MW-163S	W163SSA	11/4/2003	J-3 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	6.1		UG/L	0	10	2
MW-163S	W163SSA	11/4/2003	J-3 RANGE	E314.0	PERCHLORATE	31		UG/L	0	10	2
MW-163S	W163SSA	2/13/2004	J-3 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.4		UG/L	0	10	2
MW-163S	W163SSA	2/13/2004	J-3 RANGE	E314.0	PERCHLORATE	41		UG/L	0	10	2
MW-163S	W163SSA	5/11/2004	J-3 RANGE	E314.0	PERCHLORATE	58	J	UG/L	0	10	2
MW-163S	W163SSA	10/1/2004	J-3 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	8.7	J	UG/L	0	10	2
MW-163S	W163SSA	10/1/2004	J-3 RANGE	E314.0	PERCHLORATE	28		UG/L	0	10	2
MW-163S	W163SSA	3/10/2005	J-3 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	33		UG/L	0	10	2
MW-163S	W163SSA	3/10/2005	J-3 RANGE	E314.0	PERCHLORATE	120		UG/L	0	10	2
MW-163S	W163SSA	6/8/2005	J-3 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	26		UG/L	0	10	2
MW-163S	W163SSA	6/8/2005	J-3 RANGE	E314.0	PERCHLORATE	85	J	UG/L	0	10	2
MW-163S	W163SSA	11/9/2005	J-3 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	15		UG/L	0	10	2
MW-163S	W163SSA	11/9/2005	J-3 RANGE	E314.0	PERCHLORATE	28.7		UG/L	0	10	2
MW-163S	W163SSA	3/13/2006	J-3 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	11		UG/L	0	10	2
MW-163S	W163SSA	3/13/2006	J-3 RANGE	E314.0	PERCHLORATE	33.2		UG/L	0	10	2
MW-163S	MW-163S_FAL08	8/11/2008	J-3 RANGE	E314.0	PERCHLORATE	2.73		UG/L	0	10	2
MW-163S	MW-163S_FAL08	8/11/2008	J-3 RANGE	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.57		UG/L	0	10	2
MW-163S	MW-163S_FAL08D	8/11/2008	J-3 RANGE	E314.0	PERCHLORATE	2.74		UG/L	0	10	2
MW-163S	MW-163S_FAL08D	8/11/2008	J-3 RANGE	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.79		UG/L	0	10	2
MW-164	W164M2A	5/25/2001	J-1 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	12		UG/L	49	59	2
MW-164	W164M2A	8/21/2001	J-1 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	8		UG/L	49	59	2
MW-164	W164M2A	1/17/2002	J-1 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.6		UG/L	49	59	2
MW-164	W164M2A	6/20/2002	J-1 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	7.1		UG/L	49	59	2
MW-164	W164M1A	9/5/2002	J-1 RANGE	SW8270	BIS(2-ETHYLHEXYL) PHTHALATE	8.6		UG/L	119	129	6
MW-164	W164M2A	9/5/2002	J-1 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	6.9		UG/L	49	59	2
MW-164	W164M2D	9/5/2002	J-1 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	7		UG/L	49	59	2
MW-164	W164M2A	1/8/2003	J-1 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	6.8	J	UG/L	49	59	2
MW-164	W164M2A	6/6/2003	J-1 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5.9		UG/L	49	59	2
MW-164	W164M2A	5/25/2005	J-1 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.3		UG/L	49	59	2
MW-164	W164M2A	9/22/2005	J-1 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.9		UG/L	49	59	2
MW-164	W164M2A	12/21/2005	J-1 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5		UG/L	49	59	2
MW-164	W164M2A	3/14/2006	J-1 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5	J	UG/L	49	59	2

AOC = Area of Concern  
J = Estimated Result

BWTS = Depth Below Water Table Start (feet)

BWTE = Depth Below Water Table End (feet)

DW Limit = Either the MCL or Lowest Health Advisory Limit

TABLE 4

## VALIDATED DETECTS EXCEEDING MCLs or HEALTH ADVISORY LIMITS 1997 THROUGH September 2008

LOCID/WELL ID	SAMPLE_ID	SAMPLED	AOC	METHOD	ANALYTE	CONC	FLAG	UNITS	BWTS	BWTE	DW LIMIT
MW-164	MW-164M2-	4/19/2007	J-1 RANGE	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.4		UG/L	49	59	2
MW-165	W165M1A	3/27/2003	DEMO 1	E314.0	PERCHLORATE	4	J	UG/L	106	116	2
MW-165	W165M1A	9/10/2003	DEMO 1	E314.0	PERCHLORATE	2.5		UG/L	106	116	2
MW-165	W165M1A	3/1/2004	DEMO 1	E314.0	PERCHLORATE	3.15	J	UG/L	106	116	2
MW-165	W165M1A	4/9/2004	DEMO 1	E314.0	PERCHLORATE	3.05		UG/L	106	116	2
MW-165	W165M1A	8/5/2004	DEMO 1	E314.0	PERCHLORATE	3.54	J	UG/L	106	116	2
MW-165M2	W165M2A	5/8/2001	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	60		UG/L	46	56	2
MW-165M2	W165M2A	5/8/2001	DEMO 1	E314.0	PERCHLORATE	122	J	UG/L	46	56	2
MW-165M2	W165M2A	8/16/2001	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	50		UG/L	46	56	2
MW-165M2	W165M2A	8/16/2001	DEMO 1	E314.0	PERCHLORATE	102		UG/L	46	56	2
MW-165M2	W165M2A	1/7/2002	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	27	J	UG/L	46	56	2
MW-165M2	W165M2A	1/10/2002	DEMO 1	E314.0	PERCHLORATE	81.2		UG/L	46	56	2
MW-165M2	W165M2A	4/18/2002	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	26		UG/L	46	56	2
MW-165M2	W165M2A	4/18/2002	DEMO 1	E314.0	PERCHLORATE	83.5		UG/L	46	56	2
MW-165M2	W165M2A	8/10/2002	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	23		UG/L	46	56	2
MW-165M2	W165M2A	8/10/2002	DEMO 1	E314.0	PERCHLORATE	64		UG/L	46	56	2
MW-165M2	W165M2A	11/26/2002	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	19		UG/L	46	56	2
MW-165M2	W165M2A	11/26/2002	DEMO 1	E314.0	PERCHLORATE	78		UG/L	46	56	2
MW-165M2	W165M2A	3/27/2003	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	35		UG/L	46	56	2
MW-165M2	W165M2A	3/27/2003	DEMO 1	E314.0	PERCHLORATE	110	J	UG/L	46	56	2
MW-165M2	W165M2A	9/11/2003	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	12		UG/L	46	56	2
MW-165M2	W165M2A	9/11/2003	DEMO 1	E314.0	PERCHLORATE	57	J	UG/L	46	56	2
MW-165M2	W165M2D	9/11/2003	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	12		UG/L	46	56	2
MW-165M2	W165M2D	9/11/2003	DEMO 1	E314.0	PERCHLORATE	58	J	UG/L	46	56	2
MW-165M2	W165M2A	3/1/2004	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	13		UG/L	46	56	2
MW-165M2	W165M2A	3/1/2004	DEMO 1	E314.0	PERCHLORATE	50.9	J	UG/L	46	56	2
MW-165M2	W165M2D	3/1/2004	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	13		UG/L	46	56	2
MW-165M2	W165M2D	3/1/2004	DEMO 1	E314.0	PERCHLORATE	50.9	J	UG/L	46	56	2
MW-165M2	W165M2A	4/9/2004	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	10		UG/L	46	56	2
MW-165M2	W165M2A	4/9/2004	DEMO 1	E314.0	PERCHLORATE	39		UG/L	46	56	2
MW-165M2	W165M2A	8/6/2004	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	10		UG/L	46	56	2
MW-165M2	W165M2A	8/6/2004	DEMO 1	E314.0	PERCHLORATE	41.3		UG/L	46	56	2
MW-165M2	W165M2A	12/7/2004	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	130		UG/L	46	56	2
MW-165M2	W165M2A	12/7/2004	DEMO 1	E314.0	PERCHLORATE	94	J	UG/L	46	56	2
MW-165M2	W165M2A	4/14/2005	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	23		UG/L	46	56	2
MW-165M2	W165M2A	4/14/2005	DEMO 1	E314.0	PERCHLORATE	9.8		UG/L	46	56	2
MW-165M2	MW-165M2-	12/15/2005	DEMO 1	E314.0	PERCHLORATE	5.92		UG/L	46	56	2
MW-165M2	MW-165M2-FD	12/15/2005	DEMO 1	E314.0	PERCHLORATE	6.14		UG/L	46	56	2
MW-165M2	MW-165M2-	4/14/2006	DEMO 1	E314.0	PERCHLORATE	3.89		UG/L	46	56	2
MW-165M2	MW-165M2	12/28/2006	DEMO 1	E314.0	PERCHLORATE	6.57		UG/L	46	56	2
MW-165M2	MW-165M2	4/16/2007	DEMO 1	E314.0	PERCHLORATE	5.05		UG/L	46	56	2
MW-165M2	1922	12/6/2007		SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	171		UG/L	46	56	2
MW-165M2	1922	12/6/2007		E314.0	PERCHLORATE	26.2		UG/L	46	56	2
MW-165M2	MW-165M2	2/1/2008	Demo 1	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	26.9		UG/L	46	56	2
MW-165M2	MW-165M2	2/1/2008	Demo 1	E314.0	PERCHLORATE	6.55		UG/L	46	56	2
MW-165M2	1948	4/18/2008	DEMO 1	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	11.6		UG/L	46	56	2
MW-165M2	1948	4/18/2008	DEMO 1	E314.0	PERCHLORATE	5.41		UG/L	46	56	2

AOC = Area of Concern  
J = Estimated Result

BWTS = Depth Below Water Table Start (feet)

BWTE = Depth Below Water Table End (feet)

DW Limit = Either the MCL or Lowest Health Advisory Limit

TABLE 4

## VALIDATED DETECTS EXCEEDING MCLs or HEALTH ADVISORY LIMITS 1997 THROUGH September 2008

LOCID/WELL ID	SAMPLE_ID	SAMPLED	AOC	METHOD	ANALYTE	CONC	FLAG	UNITS	BWTS	BWTE	DW LIMIT
MW-166M1	W166M1A	5/31/2001	J-1 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.7		UG/L	112	117	2
MW-166M1	W166M1A	10/4/2001	J-1 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.4		UG/L	112	117	2
MW-166M1	W166M1A	1/16/2002	J-1 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.4		UG/L	112	117	2
MW-166M1	W166M1A	7/1/2003	J-1 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.1		UG/L	112	117	2
MW-166M1	W166M1A	11/11/2003	J-1 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.8		UG/L	112	117	2
MW-166M1	W166M1A	2/20/2004	J-1 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.6		UG/L	112	117	2
MW-166M1	W166M1A	6/29/2004	J-1 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.2		UG/L	112	117	2
MW-166M1	W166M1A	9/30/2004	J-1 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.7		UG/L	112	117	2
MW-166M1	W166M1A	1/5/2005	J-1 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.7		UG/L	112	117	2
MW-166M1	W166M1A	6/9/2005	J-1 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.4		UG/L	112	117	2
MW-166M1	W166M1A	8/13/2005	J-1 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.1	J	UG/L	112	117	2
MW-166M1	MW-166M1_0508	6/20/2008	J1N [148]	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2		UG/L	112	117	2
MW-166M3	W166M3A	6/1/2001	J-1 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.3		UG/L	19	29	2
MW-166M3	W166M3A	10/4/2001	J-1 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.9		UG/L	19	29	2
MW-166M3	W166M3A	1/17/2002	J-1 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.1		UG/L	19	29	2
MW-166M3	W166M3A	7/1/2002	J-1 RANGE	E314.0	PERCHLORATE			UG/L	19	29	2
MW-166M3	W166M3A	7/2/2003	J-1 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.2		UG/L	19	29	2
MW-166M3	W166M3A	8/13/2005	J-1 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.7		UG/L	19	29	2
MW-166M3	W166M3A	12/20/2005	J-1 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	12		UG/L	19	29	2
MW-166M3	W166M3A	3/23/2006	J-1 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.4		UG/L	19	29	2
MW-168	W168M1A	6/4/2001	J-1 RANGE	SW8270	BIS(2-ETHYLHEXYL) PHTHALATE	6.7		UG/L	174	184	6
MW-168	W168M2A	6/5/2001	J-1 RANGE	SW8270	BIS(2-ETHYLHEXYL) PHTHALATE	9		UG/L	116	126	6
MW-168	W168M1A	6/6/2003	J-1 RANGE	SW8270	BIS(2-ETHYLHEXYL) PHTHALATE	6.8	J	UG/L	174	184	6
MW-17	W17SSD	11/10/1997	OTHER	OC21B	BIS(2-ETHYLHEXYL) PHTHALATE	120	J	UG/L	0	10	6
MW-17	W17DDA	11/11/1997	OTHER	OC21B	BIS(2-ETHYLHEXYL) PHTHALATE	42		UG/L	196	206	6
MW-171	W171M2A	5/31/2001	J-3 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.1		UG/L	83	88	2
MW-171	W171M2A	12/21/2001	J-3 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.6		UG/L	83	88	2
MW-172	W172M2A	6/21/2001	DEMO 1	E314.0	PERCHLORATE	3	J	UG/L	104	114	2
MW-172	W172M2A	9/21/2001	DEMO 1	E314.0	PERCHLORATE	3.94	J	UG/L	104	114	2
MW-172	W172M2A	2/8/2002	DEMO 1	E314.0	PERCHLORATE	5.45		UG/L	104	114	2
MW-172	W172M2A	9/18/2002	DEMO 1	E314.0	PERCHLORATE	7.1		UG/L	104	114	2
MW-172	W172M2A	11/26/2002	DEMO 1	E314.0	PERCHLORATE	6.8		UG/L	104	114	2
MW-172	W172M2A	3/28/2003	DEMO 1	E314.0	PERCHLORATE	6.8	J	UG/L	104	114	2
MW-172	W172M2A	10/15/2003	DEMO 1	E314.0	PERCHLORATE	6.8		UG/L	104	114	2
MW-172	W172M2A	2/10/2004	DEMO 1	E314.0	PERCHLORATE	4.45		UG/L	104	114	2
MW-172	W172M2D	2/10/2004	DEMO 1	E314.0	PERCHLORATE	4.44		UG/L	104	114	2
MW-172	W172M2A	4/19/2004	DEMO 1	E314.0	PERCHLORATE	4.39		UG/L	104	114	2
MW-172	W172M2A	7/28/2004	DEMO 1	E314.0	PERCHLORATE	4.1		UG/L	104	114	2
MW-172	W172M2A	4/5/2005	DEMO 1	E314.0	PERCHLORATE	2.1	J	UG/L	104	114	2
MW-176M1	W176M1A	10/8/2003	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.6		UG/L	158.55	168.55	2
MW-176M1	W176M1A	1/9/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3		UG/L	158.55	168.55	2
MW-176M1	W176M1A	7/12/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5		UG/L	158.55	168.55	2
MW-176M1	W176M1A	8/10/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5.3		UG/L	158.55	168.55	2
MW-176M1	W176M1D	8/10/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5.4		UG/L	158.55	168.55	2
MW-176M1	W176M1A	11/23/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	7.1		UG/L	158.55	168.55	2
MW-176M1	W176M1A	4/4/2005	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	7.9		UG/L	158.55	168.55	2
MW-176M1	W176M1A	9/29/2005	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	8	J	UG/L	158.55	168.55	2

AOC = Area of Concern  
J = Estimated Result

BWTS = Depth Below Water Table Start (feet)  
BWTE = Depth Below Water Table End (feet)  
DW Limit = Either the MCL or Lowest Health Advisory Limit

TABLE 4

## VALIDATED DETECTS EXCEEDING MCLs or HEALTH ADVISORY LIMITS 1997 THROUGH September 2008

LOCID/WELL ID	SAMPLE_ID	SAMPLED	AOC	METHOD	ANALYTE	CONC	FLAG	UNITS	BWTS	BWTE	DW LIMIT
MW-176M1	W176M1A	12/29/2005	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	8.2		UG/L	158.55	168.55	2
MW-176M1	W176M1A	4/17/2006	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	7.4		UG/L	158.55	168.55	2
MW-176M1	W176M1A	10/30/2006	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	7.8		UG/L	158.55	168.55	2
MW-176M1	MW-176M1	5/16/2007	CIA	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	6.1		UG/L	158.55	168.55	2
MW-176M1	MW-176M1	11/7/2007	CIA	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	6		ug/L	158.6	168.6	2
MW-176M1	MW-176M1_FD	11/7/2007	CIA	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	6.2		ug/L	158.6	168.6	2
MW-176M1	MW-176M1_SPR08	6/11/2008	CIA [108]	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	6.4		UG/L	270	280	2
MW-178	W178M1A	10/31/2001	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.8		UG/L	117	127	2
MW-178	W178M1A	3/8/2002	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.6	J	UG/L	117	127	2
MW-178	W178M1A	7/26/2002	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.3		UG/L	117	127	2
MW-178	W178M1A	1/13/2003	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.1		UG/L	117	127	2
MW-178	W178M1A	6/10/2003	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.4		UG/L	117	127	2
MW-178	W178M1A	11/17/2003	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.6		UG/L	117	127	2
MW-178	W178M1A	12/24/2003	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.8		UG/L	117	127	2
MW-178	W178M1A	5/19/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.6		UG/L	117	127	2
MW-178	W178M1D	5/19/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.5		UG/L	117	127	2
MW-178	W178M1A	8/12/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4		UG/L	117	127	2
MW-178	W178M1A	12/29/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.5		UG/L	117	127	2
MW-178	W178M1A	5/2/2005	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5		UG/L	117	127	2
MW-178	W178M1A	9/6/2005	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.4		UG/L	117	127	2
MW-178	W178M1A	12/8/2005	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.2		UG/L	117	127	2
MW-178	W178M1A	4/13/2006	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3		UG/L	117	127	2
MW-178	W178M1A	10/19/2006	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.5		UG/L	117	127	2
MW-178	MW-178M1	5/16/2007	CIA	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2		UG/L	117	127	2
MW-18	W18SSA	10/10/1997	J-2 RANGE	OC21B	BIS(2-ETHYLHEXYL) PHTHALATE	36		UG/L	0	10	6
MW-18	W18SSA	3/12/1999	J-2 RANGE	IM40MB	THALLIUM	2.3	J	UG/L	0	10	2
MW-18	W18DDA	9/10/1999	J-2 RANGE	OC21B	BIS(2-ETHYLHEXYL) PHTHALATE	11		UG/L	222	232	6
MW-184M1	W184M1A	1/24/2002	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	23		UG/L	58.2	68.2	2
MW-184M1	W184M1A	6/21/2002	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	24		UG/L	58.2	68.2	2
MW-184M1	W184M1A	9/18/2002	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	24		UG/L	58.2	68.2	2
MW-184M1	W184M1D	9/18/2002	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	24		UG/L	58.2	68.2	2
MW-184M1	W184M1A	5/21/2003	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	24		UG/L	58.2	68.2	2
MW-184M1	W184M1D	5/21/2003	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	24		UG/L	58.2	68.2	2
MW-184M1	W184M1A	10/30/2003	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	22		UG/L	58.2	68.2	2
MW-184M1	W184M1A	2/9/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	21		UG/L	58.2	68.2	2
MW-184M1	W184M1A	5/18/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	19		UG/L	58.2	68.2	2
MW-184M1	W184M1A	8/10/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	19		UG/L	58.2	68.2	2
MW-184M1	W184M1A	2/9/2005	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	17		UG/L	58.2	68.2	2
MW-184M1	W184M1A	5/12/2005	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	17		UG/L	58.2	68.2	2
MW-184M1	W184M1A	11/1/2005	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	15		UG/L	58.2	68.2	2
MW-184M1	W184M1A	1/23/2006	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	10		UG/L	58.2	68.2	2
MW-184M1	W184M1D	1/23/2006	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	11		UG/L	58.2	68.2	2
MW-184M1	W184M1A	4/26/2006	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	13		UG/L	58.2	68.2	2
MW-184M1	W184M1D	4/26/2006	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	13		UG/L	58.2	68.2	2
MW-184M1	W184M1A	11/29/2006	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5.7		UG/L	58.2	68.2	2
MW-184M1	MW-184M1	5/11/2007	CIA	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	6.7		UG/L	58.2	68.2	2
MW-184M1	MW-184M1	5/11/2007	CIA	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	7.2		UG/L	58.2	68.2	2

AOC = Area of Concern  
J = Estimated Result

BWTS = Depth Below Water Table Start (feet)

BWTE = Depth Below Water Table End (feet)

DW Limit = Either the MCL or Lowest Health Advisory Limit

TABLE 4

## VALIDATED DETECTS EXCEEDING MCLs or HEALTH ADVISORY LIMITS 1997 THROUGH September 2008

LOCID/WELL ID	SAMPLE_ID	SAMPLED	AOC	METHOD	ANALYTE	CONC	FLAG	UNITS	BWTS	BWTE	DW LIMIT
MW-184M1	MW-184M1	11/26/2007	CIA	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	8.1		ug/L	58.2	68.2	2
MW-184M1	MW-184M1_SPR08	5/30/2008	CIA [108]	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	6.9		UG/L	58.2	68.2	2
MW-184M1	MW-184M1_SPR08D	5/30/2008	CIA [108]	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	7		UG/L	58.2	68.2	2
MW-187	W187DDA	1/23/2002	J-1 RANGE	OC21V	BENZENE	1000		UG/L	199.5	209.5	5
MW-187	W187DDA	1/23/2002	J-1 RANGE	OC21V	CHLOROMETHANE	75	J	UG/L	199.5	209.5	30
MW-187	W187DDA	1/23/2002	J-1 RANGE	IM40MB	SODIUM	25300		UG/L	199.5	209.5	20000
MW-187	W187DDX	1/23/2002	J-1 RANGE	IM40MB	ANTIMONY	6	J	UG/L	199.5	209.5	6
MW-187	W187DDX	1/23/2002	J-1 RANGE	IM40MB	SODIUM	25200		UG/L	199.5	209.5	20000
MW-187	W187DDA	2/11/2002	J-1 RANGE	OC21V	BENZENE	1300		UG/L	199.5	209.5	5
MW-187	W187DDA	2/11/2002	J-1 RANGE	OC21V	CHLOROMETHANE	47	J	UG/L	199.5	209.5	30
MW-187	W187DDA	7/11/2002	J-1 RANGE	OC21V	BENZENE	530	J	UG/L	199.5	209.5	5
MW-187	W187DDA	7/11/2002	J-1 RANGE	IM40MB	SODIUM	27100		UG/L	199.5	209.5	20000
MW-187	W187DDA	10/17/2002	J-1 RANGE	OC21V	BENZENE	340		UG/L	199.5	209.5	5
MW-187	W187DDA	10/17/2002	J-1 RANGE	IM40MB	SODIUM	25300		UG/L	199.5	209.5	20000
MW-187	W187DDA	7/7/2003	J-1 RANGE	OC21V	BENZENE	150		UG/L	199.5	209.5	5
MW-187	W187DDA	7/7/2003	J-1 RANGE	IM40MB	SODIUM	22700		UG/L	199.5	209.5	20000
MW-187	W187DDA	11/21/2003	J-1 RANGE	OC21V	BENZENE	140		UG/L	199.5	209.5	5
MW-187	W187DDA	11/21/2003	J-1 RANGE	IM40MB	SODIUM	24200		UG/L	199.5	209.5	20000
MW-187	W187DDA	3/5/2004	J-1 RANGE	OC21VM	BENZENE	120		UG/L	199.5	209.5	5
MW-187	W187DDA	3/5/2004	J-1 RANGE	IM40MB	SODIUM	24100		UG/L	199.5	209.5	20000
MW-187	W187DDA	7/13/2004	J-1 RANGE	OC21VM	BENZENE	120		UG/L	199.5	209.5	5
MW-187	W187DDA	9/1/2004	J-1 RANGE	OC21VM	BENZENE	110		UG/L	199.5	209.5	5
MW-187	W187DDA	2/1/2005	J-1 RANGE	OC21VM	BENZENE	91		UG/L	199.5	209.5	5
MW-187	W187DDA	5/24/2005	J-1 RANGE	OC21VM	BENZENE	67		UG/L	199.5	209.5	5
MW-187	W187DDA	9/16/2005	J-1 RANGE	OC21VM	BENZENE	64		UG/L	199.5	209.5	5
MW-187	W187DDD	9/16/2005	J-1 RANGE	OC21VM	BENZENE	64		UG/L	199.5	209.5	5
MW-187	W187DDA	1/26/2006	J-1 RANGE	OC21VM	BENZENE	52		UG/L	199.5	209.5	5
MW-187	W187DDA	11/1/2006	J-1 RANGE	OC21VM	BENZENE	53		UG/L	199.5	209.5	5
MW-187	MW-187D-	4/19/2007	J-1 RANGE	SW8260B	BENZENE	42		UG/L	199.5	209.5	5
MW-188	W188M1A	1/30/2002	J-1 RANGE	SW8270	BIS(2-ETHYLHEXYL) PHTHALATE	9.4		UG/L	41.1	51.1	6
MW-19	W19DDA	3/4/1998	DEMO 1	OC21B	BIS(2-ETHYLHEXYL) PHTHALATE	7		UG/L	254	259	6
MW-19	W19SSA	3/5/1998	DEMO 1	8330	2,4,6-TRINITROTOLUENE	10	J	UG/L	0	10	2
MW-19	W19SSA	3/5/1998	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	190		UG/L	0	10	2
MW-19	W19S2A	7/20/1998	DEMO 1	8330	2,4,6-TRINITROTOLUENE	16		UG/L	0	10	2
MW-19	W19S2A	7/20/1998	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	260		UG/L	0	10	2
MW-19	W19S2D	7/20/1998	DEMO 1	8330	2,4,6-TRINITROTOLUENE	16		UG/L	0	10	2
MW-19	W19S2D	7/20/1998	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	260		UG/L	0	10	2
MW-19	W19DDL	2/11/1999	DEMO 1	IM40MB	THALLIUM	3.1	J	UG/L	254	259	2
MW-19	W19SSA	2/12/1999	DEMO 1	8330	2,4,6-TRINITROTOLUENE	7.2	J	UG/L	0	10	2
MW-19	W19SSA	2/12/1999	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	250		UG/L	0	10	2
MW-19	W19SSA	9/10/1999	DEMO 1	8330	2,4,6-TRINITROTOLUENE	2.6	J	UG/L	0	10	2
MW-19	W19SSA	9/10/1999	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	240		UG/L	0	10	2
MW-19	W19SSA	9/10/1999	DEMO 1	IM40MB	THALLIUM	3.8	J	UG/L	0	10	2
MW-19	W19SSA	5/12/2000	DEMO 1	8330	2,4,6-TRINITROTOLUENE	3.7	J	UG/L	0	10	2
MW-19	W19SSA	5/12/2000	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	150	J	UG/L	0	10	2
MW-19	W19SSA	5/23/2000	DEMO 1	8330	2,4,6-TRINITROTOLUENE	3.9	J	UG/L	0	10	2
MW-19	W19SSA	5/23/2000	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	160		UG/L	0	10	2

AOC = Area of Concern  
J = Estimated Result

BWTS = Depth Below Water Table Start (feet)

BWTE = Depth Below Water Table End (feet)

DW Limit = Either the MCL or Lowest Health Advisory Limit

TABLE 4

## VALIDATED DETECTS EXCEEDING MCLs or HEALTH ADVISORY LIMITS 1997 THROUGH September 2008

LOCID/WELL ID	SAMPLE_ID	SAMPLED	AOC	METHOD	ANALYTE	CONC	FLAG	UNITS	BWTS	BWTE	DW LIMIT
MW-19	W19SSA	8/8/2000	DEMO 1	8330	2,4,6-TRINITROTOLUENE	2	J	UG/L	0	10	2
MW-19	W19SSA	8/8/2000	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	290	UG/L	0	10	2	
MW-19	W19SSA	8/8/2000	DEMO 1	E314.0	PERCHLORATE	104	J	UG/L	0	10	2
MW-19	W19SSA	12/8/2000	DEMO 1	8330	2,4,6-TRINITROTOLUENE	2.3	J	UG/L	0	10	2
MW-19	W19SSA	12/8/2000	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	200	UG/L	0	10	2	
MW-19	W19SSA	12/8/2000	DEMO 1	E314.0	PERCHLORATE	12	UG/L	0	10	2	
MW-19	W19SSA	6/18/2001	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	200	UG/L	0	10	2	
MW-19	W19SSA	6/18/2001	DEMO 1	E314.0	PERCHLORATE	41	UG/L	0	10	2	
MW-19	W19SSD	6/18/2001	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	210	UG/L	0	10	2	
MW-19	W19SSA	8/24/2001	DEMO 1	8330	2,4,6-TRINITROTOLUENE	2.4	UG/L	0	10	2	
MW-19	W19SSA	8/24/2001	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	120	UG/L	0	10	2	
MW-19	W19SSA	8/24/2001	DEMO 1	E314.0	PERCHLORATE	8.49	UG/L	0	10	2	
MW-19	W19SSA	8/24/2001	DEMO 1	IM40MB	THALLIUM	4.2	J	UG/L	0	10	2
MW-19	W19SSA	12/27/2001	DEMO 1	8330	2,4,6-TRINITROTOLUENE	2.2	J	UG/L	0	10	2
MW-19	W19SSA	12/27/2001	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	120	UG/L	0	10	2	
MW-19	W19SSA	12/27/2001	DEMO 1	E314.0	PERCHLORATE	18.6	J	UG/L	0	10	2
MW-19	W19SSA	5/29/2002	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	120	UG/L	0	10	2	
MW-19	W19SSA	5/29/2002	DEMO 1	E314.0	PERCHLORATE	5.2	UG/L	0	10	2	
MW-19	W19SSA	8/7/2002	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	99	UG/L	0	10	2	
MW-19	W19SSA	8/7/2002	DEMO 1	E314.0	PERCHLORATE	4.1	J	UG/L	0	10	2
MW-19	W19SSA	9/27/2003	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	80	UG/L	0	10	2	
MW-19	W19SSA	9/27/2003	DEMO 1	E314.0	PERCHLORATE	7.8	J	UG/L	0	10	2
MW-19	W19SSA	2/28/2004	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	65	UG/L	0	10	2	
MW-19	W19SSA	2/28/2004	DEMO 1	E314.0	PERCHLORATE	2.71	J	UG/L	0	10	2
MW-19	W19SSA	6/1/2004	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	73	UG/L	0	10	2	
MW-19	W19SSA	8/8/2005	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	14	UG/L	0	10	2	
MW-19	MW-19S-	2/8/2006	DEMO 1	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	9.8	UG/L	0	10	2	
MW-19	MW-19S-	4/12/2006	DEMO 1	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	19	UG/L	0	10	2	
MW-19	MW-19S	1/3/2007	DEMO 1	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	34	UG/L	0	10	2	
MW-19	MW-19S	4/30/2007	DEMO 1	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	24.7	UG/L	0	10	2	
MW-191	W191M2A	1/25/2002	J-1 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.1	J	UG/L	8.4	18.4	2
MW-191	W191M1A	7/25/2002	J-1 RANGE	IM40MB	THALLIUM	6.3	UG/L	25.2	30.2	2	
MW-193	W193M1A	2/20/2002	J-3 RANGE	E314.0	PERCHLORATE	7.02	UG/L	23.8	28.8	2	
MW-193	W193M1D	2/20/2002	J-3 RANGE	E314.0	PERCHLORATE	7.3	UG/L	23.8	28.8	2	
MW-193	W193M1A	7/11/2002	J-3 RANGE	E314.0	PERCHLORATE	3.5	UG/L	23.8	28.8	2	
MW-193	W193SSA	3/8/2006	J-3 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	8.3	J	UG/L	0	5	2
MW-196	W196M1A	2/6/2002	J-3 RANGE	SW8270	BIS(2-ETHYLHEXYL) PHTHALATE	10	J	UG/L	12	17	6
MW-196	W196SSA	2/7/2002	J-3 RANGE	8330	2,4,6-TRINITROTOLUENE	12	UG/L	0	5	2	
MW-196	W196SSA	7/12/2002	J-3 RANGE	8330	2,4,6-TRINITROTOLUENE	10	UG/L	0	5	2	
MW-196	W196SSA	7/12/2002	J-3 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	6.6	J	UG/L	0	5	2
MW-196	W196SSA	10/24/2002	J-3 RANGE	8330	2,4,6-TRINITROTOLUENE	9.3	UG/L	0	5	2	
MW-196	W196SSA	10/24/2002	J-3 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4	J	UG/L	0	5	2
MW-196	W196SSA	8/12/2003	J-3 RANGE	8330	2,4,6-TRINITROTOLUENE	5.5	UG/L	0	5	2	
MW-196	W196SSA	8/12/2003	J-3 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.6	J	UG/L	0	5	2
MW-196	W196SSA	11/7/2003	J-3 RANGE	8330	2,4,6-TRINITROTOLUENE	12	UG/L	0	5	2	
MW-196	W196SSA	2/10/2004	J-3 RANGE	8330	2,4,6-TRINITROTOLUENE	14	UG/L	0	5	2	
MW-196	W196SSA	10/28/2004	J-3 RANGE	8330	2,4,6-TRINITROTOLUENE	29	UG/L	0	5	2	

AOC = Area of Concern  
J = Estimated Result

BWTS = Depth Below Water Table Start (feet)  
BWTE = Depth Below Water Table End (feet)  
DW Limit = Either the MCL or Lowest Health Advisory Limit

TABLE 4

## VALIDATED DETECTS EXCEEDING MCLs or HEALTH ADVISORY LIMITS 1997 THROUGH September 2008

LOCID/WELL ID	SAMPLE_ID	SAMPLED	AOC	METHOD	ANALYTE	CONC	FLAG	UNITS	BWTS	BWTE	DW LIMIT
MW-196	W196SSA	6/16/2005	J-3 RANGE	8330	2,4,6-TRINITROTOLUENE	17		UG/L	0	5	2
MW-196	W196SSA	11/17/2005	J-3 RANGE	8330	2,4,6-TRINITROTOLUENE	14		UG/L	0	5	2
MW-197	W197M3A	2/12/2002	J-3 RANGE	E314.0	PERCHLORATE	34.1		UG/L	39.4	44.4	2
MW-197	W197M3A	7/18/2002	J-3 RANGE	E314.0	PERCHLORATE	54	J	UG/L	39.4	44.4	2
MW-197	W197M3A	10/30/2002	J-3 RANGE	E314.0	PERCHLORATE	41		UG/L	39.4	44.4	2
MW-197	W197M2A	2/4/2004	J-3 RANGE	E314.0	PERCHLORATE	19		UG/L	59.3	64.3	2
MW-197	W197M2A	4/13/2004	J-3 RANGE	E314.0	PERCHLORATE	23.3		UG/L	59.3	64.3	2
MW-197	W197M2A	5/26/2004	J-3 RANGE	E314.0	PERCHLORATE	20		UG/L	59.3	64.3	2
MW-197	W197M2A	10/5/2004	J-3 RANGE	E314.0	PERCHLORATE	22		UG/L	59.3	64.3	2
MW-197	W197M2A	3/17/2005	J-3 RANGE	E314.0	PERCHLORATE	14		UG/L	59.3	64.3	2
MW-197	W197M2A	6/7/2005	J-3 RANGE	E314.0	PERCHLORATE	11		UG/L	59.3	64.3	2
MW-198M1	W198M1A	10/31/2002	J-3 RANGE	SW8270	BIS(2-ETHYLHEXYL) PHTHALATE	14		UG/L	127.8	132.8	6
MW-198M2	W198M2A	6/4/2003	J-3 RANGE	E314.0	PERCHLORATE	23		UG/L	98.4	103.4	2
MW-198M2	W198M2A	11/4/2003	J-3 RANGE	E314.0	PERCHLORATE	54		UG/L	98.4	103.4	2
MW-198M2	W198M2A	2/5/2004	J-3 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.6		UG/L	98.4	103.4	2
MW-198M2	W198M2A	2/5/2004	J-3 RANGE	E314.0	PERCHLORATE	280		UG/L	98.4	103.4	2
MW-198M2	W198M2A	5/27/2004	J-3 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	12		UG/L	98.4	103.4	2
MW-198M2	W198M2A	5/27/2004	J-3 RANGE	E314.0	PERCHLORATE	494		UG/L	98.4	103.4	2
MW-198M2	W198M2A	10/4/2004	J-3 RANGE	E314.0	PERCHLORATE	120		UG/L	98.4	103.4	2
MW-198M2	W198M2A	3/15/2005	J-3 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.9		UG/L	98.4	103.4	2
MW-198M2	W198M2A	3/15/2005	J-3 RANGE	E314.0	PERCHLORATE	110		UG/L	98.4	103.4	2
MW-198M2	W198M2A	6/14/2005	J-3 RANGE	E314.0	PERCHLORATE	31		UG/L	98.4	103.4	2
MW-198M2	W198M2A	11/2/2005	J-3 RANGE	E314.0	PERCHLORATE	413		UG/L	98.4	103.4	2
MW-198M2	W198M2A	2/27/2006	J-3 RANGE	E314.0	PERCHLORATE	431		UG/L	98.4	103.4	2
MW-198M2	MW-198M2_FAL08	8/19/2008	J-3 RANGE	E314.0	PERCHLORATE	194		UG/L	98.4	103.4	2
MW-198M2	MW-198M2_FAL08	8/19/2008	J-3 RANGE	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.03		UG/L	98.4	103.4	2
MW-198M2	MW-198M2_FAL08D	8/19/2008	J-3 RANGE	E314.0	PERCHLORATE	197		UG/L	98.4	103.4	2
MW-198M2	MW-198M2_FAL08D	8/19/2008	J-3 RANGE	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.3		UG/L	98.4	103.4	2
MW-198M3	W198M3A	2/15/2002	J-3 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	15		UG/L	78.5	83.5	2
MW-198M3	W198M3A	2/15/2002	J-3 RANGE	E314.0	PERCHLORATE	40.9		UG/L	78.5	83.5	2
MW-198M3	W198M3A	7/22/2002	J-3 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	10		UG/L	78.5	83.5	2
MW-198M3	W198M3A	7/22/2002	J-3 RANGE	E314.0	PERCHLORATE	65	J	UG/L	78.5	83.5	2
MW-198M3	W198M3A	11/6/2002	J-3 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.8		UG/L	78.5	83.5	2
MW-198M3	W198M3A	11/6/2002	J-3 RANGE	E314.0	PERCHLORATE	170		UG/L	78.5	83.5	2
MW-198M3	W198M3A	12/5/2002	J-3 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.8		UG/L	78.5	83.5	2
MW-198M3	W198M3A	12/5/2002	J-3 RANGE	E314.0	PERCHLORATE	200	J	UG/L	78.5	83.5	2
MW-198M3	W198M3A	6/4/2003	J-3 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	15		UG/L	78.5	83.5	2
MW-198M3	W198M3A	6/4/2003	J-3 RANGE	E314.0	PERCHLORATE	310		UG/L	78.5	83.5	2
MW-198M3	W198M3A	11/5/2003	J-3 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	20		UG/L	78.5	83.5	2
MW-198M3	W198M3A	11/5/2003	J-3 RANGE	E314.0	PERCHLORATE	310		UG/L	78.5	83.5	2
MW-198M3	W198M3D	11/5/2003	J-3 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	20		UG/L	78.5	83.5	2
MW-198M3	W198M3D	11/5/2003	J-3 RANGE	E314.0	PERCHLORATE	320		UG/L	78.5	83.5	2
MW-198M3	W198M3A	2/5/2004	J-3 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	14		UG/L	78.5	83.5	2
MW-198M3	W198M3A	2/5/2004	J-3 RANGE	E314.0	PERCHLORATE	260		UG/L	78.5	83.5	2
MW-198M3	W198M3A	5/27/2004	J-3 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.7		UG/L	78.5	83.5	2
MW-198M3	W198M3A	5/27/2004	J-3 RANGE	E314.0	PERCHLORATE	92.9		UG/L	78.5	83.5	2
MW-198M3	W198M3A	10/4/2004	J-3 RANGE	E314.0	PERCHLORATE	120		UG/L	78.5	83.5	2

AOC = Area of Concern

J = Estimated Result

BWTS = Depth Below Water Table Start (feet)

BWTE = Depth Below Water Table End (feet)

DW Limit = Either the MCL or Lowest Health Advisory Limit

TABLE 4

## VALIDATED DETECTS EXCEEDING MCLs or HEALTH ADVISORY LIMITS 1997 THROUGH September 2008

LOCID/WELL ID	SAMPLE_ID	SAMPLED	AOC	METHOD	ANALYTE	CONC	FLAG	UNITS	BWTS	BWTE	DW LIMIT
MW-198M3	W198M3A	3/15/2005	J-3 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.8		UG/L	78.5	83.5	2
MW-198M3	W198M3A	3/15/2005	J-3 RANGE	E314.0	PERCHLORATE	730	J	UG/L	78.5	83.5	2
MW-198M3	W198M3A	6/14/2005	J-3 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	9.2	J	UG/L	78.5	83.5	2
MW-198M3	W198M3A	6/14/2005	J-3 RANGE	E314.0	PERCHLORATE	770		UG/L	78.5	83.5	2
MW-198M3	W198M3A	10/20/2005	J-3 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	9.4		UG/L	78.5	83.5	2
MW-198M3	W198M3A	10/20/2005	J-3 RANGE	E314.0	PERCHLORATE	617		UG/L	78.5	83.5	2
MW-198M3	W198M3A	2/28/2006	J-3 RANGE	E314.0	PERCHLORATE	217		UG/L	78.5	83.5	2
MW-198M3	MW-198M3_FAL08	8/20/2008	J-3 RANGE	E314.0	PERCHLORATE	120		UG/L	78.5	83.5	2
MW-198M4	W198M4A	2/21/2002	J-3 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	12		UG/L	48.4	53.4	2
MW-198M4	W198M4A	2/21/2002	J-3 RANGE	E314.0	PERCHLORATE	311		UG/L	48.4	53.4	2
MW-198M4	W198M4A	7/19/2002	J-3 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	7		UG/L	48.4	53.4	2
MW-198M4	W198M4A	7/19/2002	J-3 RANGE	E314.0	PERCHLORATE	170	J	UG/L	48.4	53.4	2
MW-198M4	W198M4A	11/1/2002	J-3 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5.9		UG/L	48.4	53.4	2
MW-198M4	W198M4A	11/1/2002	J-3 RANGE	E314.0	PERCHLORATE	75.9		UG/L	48.4	53.4	2
MW-198M4	W198M4A	12/5/2002	J-3 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5.9		UG/L	48.4	53.4	2
MW-198M4	W198M4A	12/5/2002	J-3 RANGE	E314.0	PERCHLORATE	60	J	UG/L	48.4	53.4	2
MW-198M4	W198M4A	6/4/2003	J-3 RANGE	E314.0	PERCHLORATE	46		UG/L	48.4	53.4	2
MW-198M4	W198M4A	11/5/2003	J-3 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.2		UG/L	48.4	53.4	2
MW-198M4	W198M4A	11/5/2003	J-3 RANGE	E314.0	PERCHLORATE	100		UG/L	48.4	53.4	2
MW-198M4	W198M4A	2/5/2004	J-3 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.9		UG/L	48.4	53.4	2
MW-198M4	W198M4A	2/5/2004	J-3 RANGE	E314.0	PERCHLORATE	54		UG/L	48.4	53.4	2
MW-198M4	W198M4A	5/26/2004	J-3 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	8.7		UG/L	48.4	53.4	2
MW-198M4	W198M4A	5/26/2004	J-3 RANGE	E314.0	PERCHLORATE	81.6		UG/L	48.4	53.4	2
MW-198M4	W198M4A	10/4/2004	J-3 RANGE	E314.0	PERCHLORATE	120		UG/L	48.4	53.4	2
MW-198M4	W198M4A	3/15/2005	J-3 RANGE	E314.0	PERCHLORATE	160		UG/L	48.4	53.4	2
MW-198M4	W198M4A	6/14/2005	J-3 RANGE	E314.0	PERCHLORATE	110		UG/L	48.4	53.4	2
MW-198M4	W198M4A	10/20/2005	J-3 RANGE	E314.0	PERCHLORATE	88.7		UG/L	48.4	53.4	2
MW-198M4	W198M4A	2/28/2006	J-3 RANGE	E314.0	PERCHLORATE	33.5		UG/L	48.4	53.4	2
MW-198M4	MW-198M4_FAL08	8/20/2008	J-3 RANGE	E314.0	PERCHLORATE	53		UG/L	48.4	53.4	2
MW-19S	1923	12/7/2007		SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	16.4		UG/L	38	48	2
MW-19S	1953	4/24/2008	DEMO 1	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	13		UG/L	38	48	2
MW-2	W02DDA	11/19/1997	CIA	IM40	SODIUM	21500		UG/L	218	223	20000
MW-2	W02DDL	11/19/1997	CIA	IM40	SODIUM	22600		UG/L	218	223	20000
MW-2	W02M2A	1/20/1998	CIA	OC21B	BIS(2-ETHYLHEXYL) PHTHALATE	24		UG/L	33	38	6
MW-2	W02M2A	1/20/1998	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	13		UG/L	33	38	2
MW-2	W02M1A	1/21/1998	CIA	OC21B	BIS(2-ETHYLHEXYL) PHTHALATE	10	J	UG/L	75	80	6
MW-2	W02SSA	2/23/1998	CIA	IM40MB	LEAD	20.1		UG/L	0	10	15
MW-2	W02SSA	2/23/1998	CIA	IM40MB	MOLYBDENUM	72.1		UG/L	0	10	40
MW-2	W02SSA	2/23/1998	CIA	IM40MB	SODIUM	27200		UG/L	0	10	20000
MW-2	W02SSL	2/23/1998	CIA	IM40MB	MOLYBDENUM	63.3		UG/L	0	10	40
MW-2	W02SSL	2/23/1998	CIA	IM40MB	SODIUM	26300		UG/L	0	10	20000
MW-2	W02SSA	2/1/1999	CIA	IM40MB	SODIUM	20300		UG/L	0	10	20000
MW-2	W02SSL	2/1/1999	CIA	IM40MB	SODIUM	20100		UG/L	0	10	20000
MW-2	W02DDA	2/2/1999	CIA	OC21B	BIS(2-ETHYLHEXYL) PHTHALATE	9		UG/L	218	223	6
MW-2	W02M2A	2/3/1999	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	6.8		UG/L	33	38	2
MW-2	W02M2A	9/3/1999	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5.8		UG/L	33	38	2
MW-2	W02M2A	5/11/2000	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.3	J	UG/L	33	38	2

AOC = Area of Concern  
J = Estimated Result

BWTS = Depth Below Water Table Start (feet)

BWTE = Depth Below Water Table End (feet)

DW Limit = Either the MCL or Lowest Health Advisory Limit

TABLE 4

## VALIDATED DETECTS EXCEEDING MCLs or HEALTH ADVISORY LIMITS 1997 THROUGH September 2008

LOCID/WELL ID	SAMPLE_ID	SAMPLED	AOC	METHOD	ANALYTE	CONC	FLAG	UNITS	BWTS	BWTE	DW LIMIT
MW-2	W02DDD	8/2/2000	CIA	IM40MB	THALLIUM	4.9	J	UG/L	218	223	2
MW-2	W02M1A	8/2/2000	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.1		UG/L	75	80	2
MW-2	W02M2A	8/2/2000	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.1		UG/L	33	38	2
MW-2	W02M2A	11/27/2000	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.1		UG/L	33	38	2
MW-2	W02M2A	5/3/2001	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.1		UG/L	33	38	2
MW-2	W02M2A	8/21/2001	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.5		UG/L	33	38	2
MW-2	W02M2A	11/19/2001	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	6		UG/L	33	38	2
MW-2	W02M2A	5/1/2002	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4	J	UG/L	33	38	2
MW-2	W02M2A	9/16/2002	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.1		UG/L	33	38	2
MW-2	W02M2A	1/16/2003	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.3		UG/L	33	38	2
MW-2	W02M2D	1/16/2003	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.3		UG/L	33	38	2
MW-2	W02M2A	7/18/2003	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.6		UG/L	33	38	2
MW-2	W02M2A	11/19/2003	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.1		UG/L	33	38	2
MW-2	W02M2A	2/27/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.5	J	UG/L	33	38	2
MW-2	W02M2A	4/26/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.7		UG/L	33	38	2
MW-2	W02M2A	10/13/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.8	J	UG/L	33	38	2
MW-2	W02M2A	11/9/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.9		UG/L	33	38	2
MW-2	W02M2A	12/14/2005	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.3		UG/L	33	38	2
MW-2	W02M2A	4/24/2006	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2		UG/L	33	38	2
MW-2	W02M2A	10/25/2006	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3		UG/L	33	38	2
MW-20	W20SSA	11/7/1997	DEMO 1	OC21B	BIS(2-ETHYLHEXYL) PHTHALATE	280		UG/L	0	10	6
MW-201M2	W201M2A	3/13/2002	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.1	J	UG/L	86.9	96.9	2
MW-201M2	W201M2A	7/18/2002	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5.4		UG/L	86.9	96.9	2
MW-201M2	W201M2A	11/8/2002	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5.7		UG/L	86.9	96.9	2
MW-201M2	W201M2D	11/8/2002	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5.8		UG/L	86.9	96.9	2
MW-201M2	W201M2A	6/3/2003	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.4		UG/L	86.9	96.9	2
MW-201M2	W201M2D	6/3/2003	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.4		UG/L	86.9	96.9	2
MW-201M2	W201M2A	9/2/2003	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.7		UG/L	86.9	96.9	2
MW-201M2	W201M2A	1/20/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3		UG/L	86.9	96.9	2
MW-201M2	W201M2A	7/23/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.5		UG/L	86.9	96.9	2
MW-201M2	W201M2A	8/10/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.6		UG/L	86.9	96.9	2
MW-201M2	W201M2A	11/15/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.1		UG/L	86.9	96.9	2
MW-201M2	W201M2A	5/9/2005	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5.2		UG/L	86.9	96.9	2
MW-201M2	W201M2A	9/8/2005	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.4		UG/L	86.9	96.9	2
MW-201M2	W201M2D	9/8/2005	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.3		UG/L	86.9	96.9	2
MW-201M2	W201M2A	12/20/2005	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.5		UG/L	86.9	96.9	2
MW-201M2	W201M2A	4/18/2006	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.8		UG/L	86.9	96.9	2
MW-201M2	W201M2A	10/19/2006	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.8		UG/L	86.9	96.9	2
MW-201M2	MW-201M2	5/15/2007	CIA	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.5		UG/L	86.9	96.9	2
MW-201M2	MW-201M2	10/25/2007	CIA	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.5		ug/L	86.9	96.9	2
MW-203M2	W203M2A	2/26/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2		UG/L	32.58	42.58	2
MW-203M2	W203M2A	1/14/2005	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.3		UG/L	32.58	42.58	2
MW-203M2	MW-203M2	5/8/2007	CIA	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2		UG/L			2
MW-203M2	MW-203M2	10/18/2007	CIA	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.9		ug/L	32.6	42.6	2
MW-204M1	W204M1A	4/10/2002	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5.6		UG/L	81	91	2
MW-204M1	W204M1A	7/29/2002	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	6.3		UG/L	81	91	2
MW-204M1	W204M1D	7/29/2002	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	6		UG/L	81	91	2

AOC = Area of Concern  
J = Estimated Result

BWTS = Depth Below Water Table Start (feet)

BWTE = Depth Below Water Table End (feet)

DW Limit = Either the MCL or Lowest Health Advisory Limit

TABLE 4

## VALIDATED DETECTS EXCEEDING MCLs or HEALTH ADVISORY LIMITS 1997 THROUGH September 2008

LOCID/WELL ID	SAMPLE_ID	SAMPLED	AOC	METHOD	ANALYTE	CONC	FLAG	UNITS	BWTS	BWTE	DW LIMIT
MW-204M1	W204M2A	7/29/2002	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	6.6		UG/L	81	91	2
MW-204M1	W204M1A	10/31/2002	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	8		UG/L	81	91	2
MW-204M1	W204M2A	10/31/2002	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	6.4		UG/L	81	91	2
MW-204M1	W204M1A	6/26/2003	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5.1		UG/L	81	91	2
MW-204M1	W204M1A	9/2/2003	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	8.5		UG/L	81	91	2
MW-204M1	W204M1A	1/21/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	8.7		UG/L	81	91	2
MW-204M1	W204M1A	4/27/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	7.7		UG/L	81	91	2
MW-204M1	W204M1A	9/7/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	9.8		UG/L	81	91	2
MW-204M1	W204M1A	12/22/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	9.9	J	UG/L	81	91	2
MW-204M1	W204M1A	5/2/2005	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.5		UG/L	81	91	2
MW-204M1	W204M1A	8/18/2005	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	7.1		UG/L	81	91	2
MW-204M1	W204M1A	11/30/2005	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.5		UG/L	81	91	2
MW-204M1	W204M1A	10/30/2006	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.3		UG/L	81	91	2
MW-204M1	MW-204M1	5/7/2007	CIA	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.6		UG/L	81	91	2
MW-204M1	MW-204M1	11/16/2007	CIA	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5		ug/L	81	91	2
MW-204M1	MW-204M1_SPR08	5/19/2008	CIA [108]	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.2		UG/L	141	151	2
MW-204M2	MW-204M2_SPR08	5/19/2008	CIA [108]	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.8		UG/L	76	86	2
MW-206	W206M1A	7/18/2002	FORMER A	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.6		UG/L	19.57	29.57	2
MW-206	W206M1A	10/15/2002	FORMER A	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.3		UG/L	19.57	29.57	2
MW-206	W206M1A	2/5/2003	FORMER A	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.3		UG/L	19.57	29.57	2
MW-206	W206M1A	2/3/2004	FORMER A	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5.4		UG/L	19.57	29.57	2
MW-206	W206M1A	3/9/2004	FORMER A	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5		UG/L	19.57	29.57	2
MW-206	W206M1A	5/19/2004	FORMER A	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.2		UG/L	19.57	29.57	2
MW-206	W206M1D	5/19/2004	FORMER A	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.1		UG/L	19.57	29.57	2
MW-206	W206M1A	9/29/2004	FORMER A	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.6		UG/L	19.57	29.57	2
MW-206	W206M1A	2/28/2005	FORMER A	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.7		UG/L	19.57	29.57	2
MW-206	W206M1A	5/24/2005	FORMER A	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.5		UG/L	19.57	29.57	2
MW-206	W206M1A	10/5/2005	FORMER A	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.2		UG/L	19.57	29.57	2
MW-206	W206M1D	10/5/2005	FORMER A	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.2		UG/L	19.57	29.57	2
MW-206	W206M1A	1/9/2006	FORMER A	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.2		UG/L	19.57	29.57	2
MW-207M1	W207M1A	4/16/2002	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	18		UG/L	100.52	110.52	2
MW-207M1	W207M1A	7/26/2002	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	18		UG/L	100.52	110.52	2
MW-207M1	W207M1D	7/26/2002	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	18		UG/L	100.52	110.52	2
MW-207M1	W207M1A	10/18/2002	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	18		UG/L	100.52	110.52	2
MW-207M1	W207M1A	6/5/2003	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	12		UG/L	100.52	110.52	2
MW-207M1	W207M1A	10/15/2003	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	10		UG/L	100.52	110.52	2
MW-207M1	W207M1A	2/12/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	12		UG/L	100.52	110.52	2
MW-207M1	W207M1A	5/3/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	13		UG/L	100.52	110.52	2
MW-207M1	W207M1A	8/13/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	11		UG/L	100.52	110.52	2
MW-207M1	W207M1A	12/14/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	14		UG/L	100.52	110.52	2
MW-207M1	W207M1A	5/9/2005	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	15		UG/L	100.52	110.52	2
MW-207M1	W207M1A	8/16/2005	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	8.6		UG/L	100.52	110.52	2
MW-207M1	W207M2A	8/18/2005	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.4		UG/L	100.52	110.52	2
MW-207M1	W207M1A	12/5/2005	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	14		UG/L	100.52	110.52	2
MW-207M1	W207M1A	4/17/2006	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	9		UG/L	100.52	110.52	2
MW-207M1	W207M1A	10/16/2006	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	10		UG/L	100.52	110.52	2
MW-207M1	MW-207M1	11/9/2007	CIA	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	13		ug/L	100.5	110.5	2

AOC = Area of Concern  
J = Estimated Result

BWTS = Depth Below Water Table Start (feet)  
BWTE = Depth Below Water Table End (feet)  
DW Limit = Either the MCL or Lowest Health Advisory Limit

## VALIDATED DETECTS EXCEEDING MCLs or HEALTH ADVISORY LIMITS 1997 THROUGH September 2008

LOCID/WELL ID	SAMPLE_ID	SAMPLED	AOC	METHOD	ANALYTE	CONC	FLAG	UNITS	BWTS	BWTE	DW LIMIT
MW-207M1	MW-207M1_SPR08	6/11/2008	CIA [108]	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	9		UG/L	254	264	2
MW-209M1	W209M1A	4/30/2002	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.4		UG/L	121	131	2
MW-209M1	W209M1A	7/26/2002	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.5		UG/L	121	131	2
MW-209M1	W209M1A	10/17/2002	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.9		UG/L	121	131	2
MW-209M1	W209M1A	6/12/2003	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.8		UG/L	121	131	2
MW-209M1	W209M1A	10/29/2003	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.5		UG/L	121	131	2
MW-209M1	W209M1A	2/13/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5.1		UG/L	121	131	2
MW-209M1	W209M1A	5/3/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5.8		UG/L	121	131	2
MW-209M1	W209M1A	9/29/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	6.9		UG/L	121	131	2
MW-209M1	W209M1A	12/22/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	6.3	J	UG/L	121	131	2
MW-209M1	W209M1A	5/9/2005	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	6.6		UG/L	121	131	2
MW-209M1	W209M1A	11/8/2005	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	6.1		UG/L	121	131	2
MW-209M1	W209M1A	2/14/2006	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5.3		UG/L	121	131	2
MW-209M1	W209M1A	4/17/2006	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5		UG/L	121	131	2
MW-209M1	W209M1A	10/16/2006	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5.5		UG/L	121	131	2
MW-209M1	MW-209M1	5/15/2007	CIA	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5.7		UG/L	121	131	2
MW-209M1	MW-209M1	10/25/2007	CIA	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	6.1		ug/L	121	131	2
MW-209M1	MW-209M1_SPR08	6/3/2008	CIA [108]	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	6.9		UG/L	240	250	2
MW-209M2	MW-209M2	10/25/2007	CIA	E314.0	PERCHLORATE	2.2	J	ug/L	121	131	2
MW-21	W21SSA	10/24/1997	OTHER	IM40	SODIUM	24000		UG/L	0	10	20000
MW-21	W21SSA	10/24/1997	OTHER	IM40	THALLIUM	6.9	J	UG/L	0	10	2
MW-21	W21SSL	10/24/1997	OTHER	IM40	SODIUM	24200		UG/L	0	10	20000
MW-21	W21M2A	4/1/1999	OTHER	OC21B	BIS(2-ETHYLHEXYL) PHTHALATE	8		UG/L	58	68	6
MW-21	W21M2A	11/1/1999	OTHER	IM40MB	THALLIUM	4	J	UG/L	58	68	2
MW-21	W21SSA	11/15/2000	OTHER	IM40MB	SODIUM	22500		UG/L	0	10	20000
MW-21	W21SSA	12/20/2001	OTHER	IM40MB	SODIUM	26400		UG/L	0	10	20000
MW-21	W21SSA	10/2/2003	OTHER	IM40MB	SODIUM	20200		UG/L	0	10	20000
MW-21	W21SSA	1/23/2004	OTHER	IM40MB	SODIUM	31600		UG/L	0	10	20000
MW-210M1	MW-210M1-	4/17/2006	DEMO 1	E314.0	PERCHLORATE	4.07		UG/L	99.69	109.69	2
MW-210M1	MW-210M1	12/28/2006	DEMO 1	E314.0	PERCHLORATE	4.67		UG/L	99.69	109.69	2
MW-210M1	MW-210M1-D	12/28/2006	DEMO 1	E314.0	PERCHLORATE	4.77		UG/L	99.69	109.69	2
MW-210M1	MW-210M1	4/17/2007	DEMO 1	E314.0	PERCHLORATE	7.74		UG/L	99.69	109.69	2
MW-210M1	1986	4/17/2008	DEMO 1	E314.0	PERCHLORATE	8.26		UG/L	99.69	109.69	2
MW-210M2	W210M2A	6/6/2002	DEMO 1	E314.0	PERCHLORATE	12		UG/L	54.69	64.69	2
MW-210M2	W210M2D	6/6/2002	DEMO 1	E314.0	PERCHLORATE	11		UG/L	54.69	64.69	2
MW-210M2	W210M2A	10/28/2002	DEMO 1	E314.0	PERCHLORATE	9.93		UG/L	54.69	64.69	2
MW-210M2	W210M2A	2/28/2003	DEMO 1	E314.0	PERCHLORATE	12	J	UG/L	54.69	64.69	2
MW-210M2	W210M2A	2/5/2004	DEMO 1	E314.0	PERCHLORATE	19		UG/L	54.69	64.69	2
MW-210M2	W210M2A	3/11/2004	DEMO 1	E314.0	PERCHLORATE	23		UG/L	54.69	64.69	2
MW-210M2	W210M2A	5/20/2004	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.9		UG/L	54.69	64.69	2
MW-210M2	W210M2A	5/20/2004	DEMO 1	E314.0	PERCHLORATE	44		UG/L	54.69	64.69	2
MW-210M2	W210M2D	5/20/2004	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.1		UG/L	54.69	64.69	2
MW-210M2	W210M2D	5/20/2004	DEMO 1	E314.0	PERCHLORATE	43		UG/L	54.69	64.69	2
MW-210M2	W210M2A	8/5/2004	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	7.9		UG/L	54.69	64.69	2
MW-210M2	W210M2A	8/5/2004	DEMO 1	E314.0	PERCHLORATE	59	J	UG/L	54.69	64.69	2
MW-210M2	W210M2A	12/6/2004	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5.7		UG/L	54.69	64.69	2
MW-210M2	W210M2A	12/6/2004	DEMO 1	E314.0	PERCHLORATE	56	J	UG/L	54.69	64.69	2

AOC = Area of Concern  
J = Estimated Result

BWTS = Depth Below Water Table Start (feet)

BWTE = Depth Below Water Table End (feet)

DW Limit = Either the MCL or Lowest Health Advisory Limit

TABLE 4

## VALIDATED DETECTS EXCEEDING MCLs or HEALTH ADVISORY LIMITS 1997 THROUGH September 2008

LOCID/WELL ID	SAMPLE_ID	SAMPLED	AOC	METHOD	ANALYTE	CONC	FLAG	UNITS	BWTS	BWTE	DW LIMIT
MW-210M2	W210M2A	6/21/2005	DEMO 1	E314.0	PERCHLORATE	15		UG/L	54.69	64.69	2
MW-210M2	MW-210M2-	12/15/2005	DEMO 1	E314.0	PERCHLORATE	102		UG/L	54.69	64.69	2
MW-210M2	MW-210M2-FD	12/15/2005	DEMO 1	E314.0	PERCHLORATE	99		UG/L	54.69	64.69	2
MW-210M2	MW-210M2-	2/7/2006	DEMO 1	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	31		UG/L	54.69	64.69	2
MW-210M2	MW-210M2-	4/17/2006	DEMO 1	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	21		UG/L	54.69	64.69	2
MW-210M2	MW-210M2-	4/17/2006	DEMO 1	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	21	J	UG/L	54.69	64.69	2
MW-210M2	MW-210M2-	4/17/2006	DEMO 1	E314.0	PERCHLORATE	95.1		UG/L	54.69	64.69	2
MW-210M2	MW-210M2	12/28/2006	DEMO 1	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	60		UG/L	54.69	64.69	2
MW-210M2	MW-210M2	12/28/2006	DEMO 1	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	62		UG/L	54.69	64.69	2
MW-210M2	MW-210M2	12/28/2006	DEMO 1	E314.0	PERCHLORATE	226		UG/L	54.69	64.69	2
MW-210M2	MW-210M2	4/17/2007	DEMO 1	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	53.4		UG/L	54.69	64.69	2
MW-210M2	MW-210M2	4/17/2007	DEMO 1	E314.0	PERCHLORATE	243		UG/L	54.69	64.69	2
MW-210M2	MW-210M2	1/31/2008	Demo 1	E314.0	PERCHLORATE	3.31		UG/L	54.69	64.69	2
MW-210M2	1987	4/21/2008	DEMO 1	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.23		UG/L	156	166	2
MW-210M2	1987	4/21/2008	DEMO 1	E314.0	PERCHLORATE	3.98		UG/L	54.69	64.69	2
MW-211M1	W211M1A	2/4/2004	DEMO 1	E314.0	PERCHLORATE	5.6		UG/L	55	65	2
MW-211M1	W211M1A	3/10/2004	DEMO 1	E314.0	PERCHLORATE	9.8		UG/L	55	65	2
MW-211M1	W211M1A	5/21/2004	DEMO 1	E314.0	PERCHLORATE	11		UG/L	55	65	2
MW-211M1	W211M1A	7/30/2004	DEMO 1	E314.0	PERCHLORATE	13		UG/L	55	65	2
MW-211M1	W211M1A	12/6/2004	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	7.7		UG/L	55	65	2
MW-211M1	W211M1A	12/6/2004	DEMO 1	E314.0	PERCHLORATE	33	J	UG/L	55	65	2
MW-211M1	W211M1A	4/5/2005	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4		UG/L	55	65	2
MW-211M1	W211M1A	4/5/2005	DEMO 1	E314.0	PERCHLORATE	25	J	UG/L	55	65	2
MW-211M1	W211M1A	8/8/2005	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5.7		UG/L	55	65	2
MW-211M1	W211M1A	8/8/2005	DEMO 1	E314.0	PERCHLORATE	50.6		UG/L	55	65	2
MW-211M1	W211M1D	8/8/2005	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5.8		UG/L	55	65	2
MW-211M1	W211M1D	8/8/2005	DEMO 1	E314.0	PERCHLORATE	50.8		UG/L	55	65	2
MW-211M1	MW-211M1-	12/8/2005	DEMO 1	E314.0	PERCHLORATE	64.5		UG/L	55	65	2
MW-211M1	MW-211M1-	2/7/2006	DEMO 1	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5		UG/L	55	65	2
MW-211M1	MW-211M1-	4/10/2006	DEMO 1	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.6		UG/L	55	65	2
MW-211M1	MW-211M1-	4/10/2006	DEMO 1	E314.0	PERCHLORATE	89.7		UG/L	55	65	2
MW-211M1	MW-211M1	12/27/2006	DEMO 1	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5.6		UG/L	55	65	2
MW-211M1	MW-211M1	12/27/2006	DEMO 1	E314.0	PERCHLORATE	133		UG/L	55	65	2
MW-211M1	MW-211M1	4/9/2007	DEMO 1	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	6.45		UG/L	55	65	2
MW-211M1	MW-211M1	4/9/2007	DEMO 1	E314.0	PERCHLORATE	181		UG/L	55	65	2
MW-211M1	1930	12/5/2007	CIA	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	9.51		UG/L	200	210	2
MW-211M1	1930	12/5/2007	CIA	E314.0	PERCHLORATE	135		UG/L	55	65	2
MW-211M1	1989	4/17/2008	DEMO 1	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	8.34		UG/L	200	210	2
MW-211M1	1989	4/17/2008	DEMO 1	E314.0	PERCHLORATE	149		UG/L	55	65	2
MW-211M2	W211M2A	6/6/2002	DEMO 1	E314.0	PERCHLORATE	3		UG/L	29.7	39.7	2
MW-211M2	W211M2A	10/29/2002	DEMO 1	E314.0	PERCHLORATE	3.02		UG/L	29.7	39.7	2
MW-211M2	W211M2A	2/28/2003	DEMO 1	E314.0	PERCHLORATE	3.5		UG/L	29.7	39.7	2
MW-211M2	W211M2A	4/5/2005	DEMO 1	E314.0	PERCHLORATE	3	J	UG/L	29.7	39.7	2
MW-212	MW-212M1	5/24/2007	CIA	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	13		UG/L	125.6	135.6	2
MW-215M2	W215M2A	8/1/2002	J-2 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.1		UG/L	98.9	108.9	2
MW-215M2	W215M2A	10/28/2002	J-2 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.4		UG/L	98.9	108.9	2
MW-215M2	W215M2A	3/3/2003	J-2 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.4	J	UG/L	98.9	108.9	2

AOC = Area of Concern  
J = Estimated Result

BWTS = Depth Below Water Table Start (feet)

BWTE = Depth Below Water Table End (feet)

DW Limit = Either the MCL or Lowest Health Advisory Limit

TABLE 4

## VALIDATED DETECTS EXCEEDING MCLs or HEALTH ADVISORY LIMITS 1997 THROUGH September 2008

LOCID/WELL ID	SAMPLE_ID	SAMPLED	AOC	METHOD	ANALYTE	CONC	FLAG	UNITS	BWTS	BWTE	DW LIMIT
MW-215M2	W215M2A	7/6/2004	J-2 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.5		UG/L	98.9	108.9	2
MW-215M2	W215M2D	7/6/2004	J-2 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.4		UG/L	98.9	108.9	2
MW-215M2	W215M2A	9/9/2004	J-2 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.6		UG/L	98.9	108.9	2
MW-215M2	W215M2D	9/9/2004	J-2 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.6		UG/L	98.9	108.9	2
MW-215M2	W215M2A	2/9/2005	J-2 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.5		UG/L	98.9	108.9	2
MW-215M2	W215M2A	6/16/2005	J-2 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.7		UG/L	98.9	108.9	2
MW-215M2	W215M2A	8/30/2005	J-2 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.7		UG/L	98.9	108.9	2
MW-215M2	W215M2A	8/30/2005	J-2 RANGE	E314.0	PERCHLORATE	2		UG/L	98.9	108.9	2
MW-215M2	W215M2A	12/13/2005	J-2 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.9		UG/L	98.9	108.9	2
MW-215M2	W215M2A	3/28/2006	J-2 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3		UG/L	98.9	108.9	2
MW-215M2	MW-215M2-	4/10/2007	J-2 RANGE	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.2		UG/L	98.9	108.9	2
MW-215M2	MW-215M2_0408	4/29/2008	PRNG [180]	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.1		UG/L	205	215	2
MW-218	W218M2A	3/12/2003	J-3 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.2		UG/L	93	98	2
MW-218	W218M2A	2/2/2004	J-3 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.5		UG/L	93	98	2
MW-218	W218M2A	3/15/2004	J-3 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.3		UG/L	93	98	2
MW-218	W218M2A	5/6/2004	J-3 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.5		UG/L	93	98	2
MW-22	W22SSA	11/24/1997	OTHER	OC21B	BIS(2-ETHYLHEXYL) PHTHALATE	96		UG/L	0	10	6
MW-22	W22SSA	9/20/1999	OTHER	OC21B	BIS(2-ETHYLHEXYL) PHTHALATE	18		UG/L	0	10	6
MW-223M2	W223M2A	11/5/2002	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.5		UG/L	93.31	103.31	2
MW-223M2	W223M2A	2/28/2003	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.8	J	UG/L	93.31	103.31	2
MW-223M2	W223M2A	1/30/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.1		UG/L	93.31	103.31	2
MW-223M2	W223M2A	3/12/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2		UG/L	93.31	103.31	2
MW-223M2	W223M2D	3/12/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2		UG/L	93.31	103.31	2
MW-223M2	W223M2A	3/29/2005	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.3		UG/L	93.31	103.31	2
MW-223M2	W223M2A	10/24/2005	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.8		UG/L	93.31	103.31	2
MW-223M2	W223M2A	1/11/2006	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.3		UG/L	93.31	103.31	2
MW-223M2	W223M2D	1/11/2006	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.2		UG/L	93.31	103.31	2
MW-223M2	W223M2A	10/18/2006	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4		UG/L	93.31	103.31	2
MW-223M2	MW-223M2	5/14/2007	CIA	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.2		UG/L	93.31	103.31	2
MW-223M2	MW-223M2	12/5/2007	CIA	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.8		ug/L	93.31	103.31	2
MW-225M3	W225M3A	8/6/2002	DEMO 1	E314.0	PERCHLORATE	2.9		UG/L	26.48	36.48	2
MW-225M3	W225M3A	3/15/2004	DEMO 1	E314.0	PERCHLORATE	2.5		UG/L	26.48	36.48	2
MW-225M3	W225M3A	5/25/2004	DEMO 1	E314.0	PERCHLORATE	2.62		UG/L	26.48	36.48	2
MW-225M3	W225M3A	8/6/2004	DEMO 1	E314.0	PERCHLORATE	2.1	J	UG/L	26.48	36.48	2
MW-225M3	W225M3D	8/6/2004	DEMO 1	E314.0	PERCHLORATE	2	J	UG/L	26.48	36.48	2
MW-225M3	W225M3A	12/8/2004	DEMO 1	E314.0	PERCHLORATE	3.2	J	UG/L	26.48	36.48	2
MW-225M3	W225M3A	4/6/2005	DEMO 1	E314.0	PERCHLORATE	7.7	J	UG/L	26.48	36.48	2
MW-225M3	W225M3A	8/4/2005	DEMO 1	E314.0	PERCHLORATE	20.8	J	UG/L	26.48	36.48	2
MW-225M3	W225M3D	8/4/2005	DEMO 1	E314.0	PERCHLORATE	20.9	J	UG/L	26.48	36.48	2
MW-225M3	MW-225M3-	12/9/2005	DEMO 1	E314.0	PERCHLORATE	14.8		UG/L	26.48	36.48	2
MW-225M3	MW-225M3-	4/6/2006	DEMO 1	E314.0	PERCHLORATE	11.3		UG/L	26.48	36.48	2
MW-225M3	MW-225M3-	8/3/2006	DEMO 1	E314.0	PERCHLORATE	16		UG/L	26.48	36.48	2
MW-225M3	MW-225M3	12/21/2006	DEMO 1	E314.0	PERCHLORATE	17.6	J	UG/L	26.48	36.48	2
MW-225M3	MW-225M3	4/11/2007	DEMO 1	E314.0	PERCHLORATE	20.7		UG/L	26.48	36.48	2
MW-225M3	1934	12/5/2007	CIA	E314.0	PERCHLORATE	13.5		UG/L	26.48	36.48	2
MW-225M3	1934	12/5/2007	CIA	E314.0	PERCHLORATE	13.5		UG/L	26.48	36.48	2
MW-225M3	1935	12/5/2007	CIA	E314.0	PERCHLORATE	13.8		UG/L	26.48	36.48	2

AOC = Area of Concern  
J = Estimated Result

BWTS = Depth Below Water Table Start (feet)

BWTE = Depth Below Water Table End (feet)

DW Limit = Either the MCL or Lowest Health Advisory Limit

TABLE 4

## VALIDATED DETECTS EXCEEDING MCLs or HEALTH ADVISORY LIMITS 1997 THROUGH September 2008

LOCID/WELL ID	SAMPLE_ID	SAMPLED	AOC	METHOD	ANALYTE	CONC	FLAG	UNITS	BWTS	BWTE	DW LIMIT
MW-225M3	1997	4/14/2008	DEMO 1	E314.0	PERCHLORATE	2.37		UG/L	26.48	36.48	2
MW-227	W227M2A	8/6/2002	J-3 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	11		UG/L	56.38	66.38	2
MW-227	W227M2A	11/4/2002	J-3 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	9.9	J	UG/L	56.38	66.38	2
MW-227	W227M1A	2/10/2003	J-3 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.2	J	UG/L	76.38	86.38	2
MW-227	W227M1D	2/10/2003	J-3 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.3	J	UG/L	76.38	86.38	2
MW-227	W227M2A	2/10/2003	J-3 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	9		UG/L	56.38	66.38	2
MW-227	W227M1A	2/3/2004	J-3 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.1		UG/L	76.38	86.38	2
MW-227	W227M2A	2/3/2004	J-3 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	8.2		UG/L	56.38	66.38	2
MW-227	W227M1A	3/16/2004	J-3 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.7	J	UG/L	76.38	86.38	2
MW-227	W227M2A	3/16/2004	J-3 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5.4		UG/L	56.38	66.38	2
MW-227	W227M1A	5/13/2004	J-3 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	6.5		UG/L	76.38	86.38	2
MW-227	W227M2A	5/13/2004	J-3 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	7.4		UG/L	56.38	66.38	2
MW-227	W227M1A	9/21/2004	J-3 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	14		UG/L	76.38	86.38	2
MW-227	W227M2A	9/21/2004	J-3 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	8.9		UG/L	56.38	66.38	2
MW-227	W227M1A	11/18/2004	J-3 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	12		UG/L	76.38	86.38	2
MW-227	W227M2A	11/18/2004	J-3 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	9.9		UG/L	56.38	66.38	2
MW-227	W227M1A	6/6/2005	J-3 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	9.2	J	UG/L	76.38	86.38	2
MW-227	W227M2A	6/6/2005	J-3 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	6.5	J	UG/L	56.38	66.38	2
MW-227	W227M1A	8/1/2005	J-3 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5.1	J	UG/L	76.38	86.38	2
MW-227	W227M2A	8/1/2005	J-3 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	9.6		UG/L	56.38	66.38	2
MW-227	W227M1A	11/29/2005	J-3 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.6	J	UG/L	76.38	86.38	2
MW-227	W227M2A	11/29/2005	J-3 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	16		UG/L	56.38	66.38	2
MW-227	W227M2D	11/29/2005	J-3 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	16		UG/L	56.38	66.38	2
MW-227	MW-227M2	9/13/2007	J-3 RANGE	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	37.6	J	UG/L	56.38	66.38	2
MW-23	W23SSA	10/27/1997	PHASE 2b	OC21B	BIS(2-ETHYLHEXYL) PHTHALATE	24		UG/L	0	10	6
MW-23	W23M1A	11/7/1997	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.3	J	UG/L	103	113	2
MW-23	W23M3A	11/13/1997	CIA	OC21B	BIS(2-ETHYLHEXYL) PHTHALATE	10		UG/L	34	39	6
MW-23	W23M3D	11/13/1997	CIA	OC21B	BIS(2-ETHYLHEXYL) PHTHALATE	13		UG/L	34	39	6
MW-23	W23M1A	3/18/1999	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.4		UG/L	103	113	2
MW-23	W23M1D	3/18/1999	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.7		UG/L	103	113	2
MW-23	W23M1A	9/13/1999	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	6.1		UG/L	103	113	2
MW-23	W23SSA	9/14/1999	PHASE 2b	IM40MB	THALLIUM	4.7	J	UG/L	0	10	2
MW-23	W23M1A	5/12/2000	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	6.6	J	UG/L	103	113	2
MW-23	W23M1A	8/8/2000	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	6.3		UG/L	103	113	2
MW-23	W23M1A	12/4/2000	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	6		UG/L	103	113	2
MW-23	W23M1D	12/4/2000	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	6.2		UG/L	103	113	2
MW-23	W23M1A	4/27/2001	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5.9		UG/L	103	113	2
MW-23	W23M1A	7/30/2001	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5.3		UG/L	103	113	2
MW-23	W23M1A	12/6/2001	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5.3		UG/L	103	113	2
MW-23	W23M1A	5/9/2002	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5.5		UG/L	103	113	2
MW-23	W23M1D	5/9/2002	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5.5		UG/L	103	113	2
MW-23	W23M1A	8/15/2002	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5		UG/L	103	113	2
MW-23	W23M1A	1/30/2003	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.2		UG/L	103	113	2
MW-23	W23M1A	4/7/2003	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4		UG/L	103	113	2
MW-23	W23M1A	10/7/2003	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.1		UG/L	103	113	2
MW-23	W23M1A	2/12/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.5		UG/L	103	113	2
MW-23	W23M1A	7/9/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.2		UG/L	103	113	2

AOC = Area of Concern  
J = Estimated Result

BWTS = Depth Below Water Table Start (feet)

BWTE = Depth Below Water Table End (feet)

DW Limit = Either the MCL or Lowest Health Advisory Limit

TABLE 4

## VALIDATED DETECTS EXCEEDING MCLs or HEALTH ADVISORY LIMITS 1997 THROUGH September 2008

LOCID/WELL ID	SAMPLE_ID	SAMPLED	AOC	METHOD	ANALYTE	CONC	FLAG	UNITS	BWTS	BWTE	DW LIMIT
MW-23	W23M1A	8/30/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.6		UG/L	103	113	2
MW-23	W23M1A	1/4/2005	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.4	J	UG/L	103	113	2
MW-23	W23M1A	5/11/2005	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.2		UG/L	103	113	2
MW-23	W23M1D	5/11/2005	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.1		UG/L	103	113	2
MW-23	W23M1A	8/1/2005	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.3		UG/L	103	113	2
MW-23	W23M1A	12/6/2005	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.8		UG/L	103	113	2
MW-23	W23M1D	12/6/2005	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.6		UG/L	103	113	2
MW-23	W23M1A	4/24/2006	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.7		UG/L	103	113	2
MW-23	W23M1A	10/31/2006	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.8		UG/L	103	113	2
MW-23	MW-23M1	5/15/2007	CIA	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.7		UG/L	103	113	2
MW-23	MW-23M1-RD	5/15/2007	CIA	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.49	J	UG/L	103	113	2
MW-232	W232M1A	8/30/2002	J-3 RANGE	E314.0	PERCHLORATE	2.9		UG/L	34.94	39.94	2
MW-232	W232M1A	2/11/2003	J-3 RANGE	E314.0	PERCHLORATE	3.4	J	UG/L	34.94	39.94	2
MW-232	W232M1A	5/12/2003	J-3 RANGE	E314.0	PERCHLORATE	3.9		UG/L	34.94	39.94	2
MW-232	W232M1A	5/12/2003	J-3 RANGE	E314.0	PERCHLORATE	4.01		UG/L	34.94	39.94	2
MW-232	W232M1A-DA	5/12/2003	J-3 RANGE	E314.0	PERCHLORATE	4.32		UG/L	34.94	39.94	2
MW-232	W232M1A	9/16/2004	J-3 RANGE	E314.0	PERCHLORATE	2.6		UG/L	34.94	39.94	2
MW-232	W232M1A	3/9/2005	J-3 RANGE	E314.0	PERCHLORATE	3.3		UG/L	34.94	39.94	2
MW-232	W232M1A	5/31/2006	J-3 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5		UG/L	34.94	39.94	2
MW-232	MW-232M1	3/8/2007	J-3 RANGE	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.66		UG/L	34.94	39.94	2
MW-233M3	W233M3A	10/3/2002	WESTERN BOUNDARY	E314.0	PERCHLORATE	2.2		UG/L	231	241	2
MW-233M3	W233M3A	6/1/2005	WESTERN BOUNDARY	E314.0	PERCHLORATE	2.7	J	UG/L	231	241	2
MW-233M3	W233M3A	7/25/2005	WESTERN BOUNDARY	E314.0	PERCHLORATE	2	J	UG/L	231	241	2
MW-233M3	W233M3A	5/16/2006	WESTERN BOUNDARY	E314.0	PERCHLORATE	2.8		UG/L	231	241	2
MW-233M3	MW-233M3_WB	4/4/2007	WESTERN BOUNDARY	E314.0	PERCHLORATE	2		UG/L	231	241	2
MW-233M3	MW-233M3_0308D	3/28/2008	WESTERN BOUNDARY	E314.0	PERCHLORATE	2.1		UG/L	231	241	2
MW-234M1	W234M1A	5/12/2004	J-2 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.6		UG/L	25.3	35.3	2
MW-234M1	W234M1A	5/12/2004	J-2 RANGE	E314.0	PERCHLORATE	3.6		UG/L	25.3	35.3	2
MW-234M1	W234M1D	5/12/2004	J-2 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.6		UG/L	25.3	35.3	2
MW-234M1	W234M1D	5/12/2004	J-2 RANGE	E314.0	PERCHLORATE	3.6		UG/L	25.3	35.3	2
MW-234M1	W234M1A	8/2/2004	J-2 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.5		UG/L	25.3	35.3	2
MW-234M1	W234M1A	8/2/2004	J-2 RANGE	E314.0	PERCHLORATE	3.2	J	UG/L	25.3	35.3	2
MW-234M1	W234M1A	10/19/2004	J-2 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.2		UG/L	25.3	35.3	2
MW-234M1	W234M1A	10/19/2004	J-2 RANGE	E314.0	PERCHLORATE	2.4	J	UG/L	25.3	35.3	2
MW-234M1	W234M1A	3/10/2005	J-2 RANGE	E314.0	PERCHLORATE	2		UG/L	25.3	35.3	2
MW-234M1	W234M1A	5/16/2005	J-2 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.5		UG/L	25.3	35.3	2
MW-234M1	W234M1A	5/16/2005	J-2 RANGE	E314.0	PERCHLORATE	2.5	J	UG/L	25.3	35.3	2
MW-234M1	W234M1A	11/7/2005	J-2 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.7		UG/L	25.3	35.3	2
MW-234M1	W234M1A	11/7/2005	J-2 RANGE	E314.0	PERCHLORATE	3.1		UG/L	25.3	35.3	2
MW-234M1	W234M1A	1/30/2006	J-2 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3		UG/L	25.3	35.3	2
MW-234M1	W234M1A	1/30/2006	J-2 RANGE	E314.0	PERCHLORATE	3.7		UG/L	25.3	35.3	2
MW-234M1	W234M1A	9/13/2006	J-2 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.8		UG/L	25.3	35.3	2
MW-234M1	1820	10/2/2007	J-2 RANGE	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.1		ug/L	25.3	35.3	2
MW-234M1	1820	10/2/2007	J-2 RANGE	E314.0	PERCHLORATE	2.82	J	ug/L	25.3	35.3	2
MW-235M1	W235M1A	10/7/2002	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	9.1		UG/L	25.3	35.3	2
MW-235M1	W235M1D	10/7/2002	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	9.2		UG/L	25.3	35.3	2
MW-235M1	W235M1A	3/4/2003	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	11	J	UG/L	25.3	35.3	2

AOC = Area of Concern  
J = Estimated Result

BWTS = Depth Below Water Table Start (feet)  
BWTE = Depth Below Water Table End (feet)  
DW Limit = Either the MCL or Lowest Health Advisory Limit

TABLE 4

## VALIDATED DETECTS EXCEEDING MCLs or HEALTH ADVISORY LIMITS 1997 THROUGH September 2008

LOCID/WELL ID	SAMPLE_ID	SAMPLED	AOC	METHOD	ANALYTE	CONC	FLAG	UNITS	BWTS	BWTE	DW LIMIT
MW-235M1	W235M1A	6/27/2003	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	9.5		UG/L	25.3	35.3	2
MW-235M1	W235M1A	4/23/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	27		UG/L	25.3	35.3	2
MW-235M1	W235M1A	5/21/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	30		UG/L	25.3	35.3	2
MW-235M1	W235M1A	10/18/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	40		UG/L	25.3	35.3	2
MW-235M1	W235M1A	12/21/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	34		UG/L	25.3	35.3	2
MW-235M1	W235M1A	5/4/2005	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	38		UG/L	25.3	35.3	2
MW-235M1	W235M1A	9/29/2005	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	44		UG/L	25.3	35.3	2
MW-235M1	W235M1A	1/23/2006	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	42		UG/L	25.3	35.3	2
MW-235M1	W235M1A	5/1/2006	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	45		UG/L	25.3	35.3	2
MW-235M1	W235M1A	10/25/2006	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	31		UG/L	25.3	35.3	2
MW-235M1	MW-235M1	5/11/2007	CIA	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	36		UG/L	25.3	35.3	2
MW-235M1	MW-235M1	5/11/2007	CIA	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	37		UG/L	25.3	35.3	2
MW-235M1	MW-235M1	11/26/2007	CIA	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	23		ug/L	25.3	35.3	2
MW-235M1	MW-235M1_SPR08	5/21/2008	CIA [108]	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	22		UG/L	25.3	35.3	2
MW-235M1	MW-235M1_SPR08D	5/21/2008	CIA [108]	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	22		UG/L	25.3	35.3	2
MW-237M1	W237M1A	3/10/2005	J-3 RANGE	E314.0	PERCHLORATE	3.1		UG/L	28.5	38.5	2
MW-237M1	W237M1A	6/2/2005	J-3 RANGE	E314.0	PERCHLORATE	2.1		UG/L	28.5	38.5	2
MW-23M1	MW-23M1	10/25/2007	CIA	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.3		ug/L	103	113	2
MW-23M1	MW-23M1_SPR08	6/3/2008	CIA [108]	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.1		UG/L	225	235	2
MW-24	W24SSA	11/14/1997	OTHER	OC21B	BIS(2-ETHYLHEXYL) PHTHALATE	8		UG/L	0	10	6
MW-241	W241M1A	1/31/2005	L RANGE	SW8270	NAPHTHALENE	130		UG/L	2.75	12.75	100
MW-241	W241M1A	11/7/2005	L RANGE	SW8270	NAPHTHALENE	140		UG/L	2.75	12.75	100
MW-241	W241M1D	11/7/2005	L RANGE	SW8270	NAPHTHALENE	160		UG/L	2.75	12.75	100
MW-243	W243M1A	6/2/2005	J-3 RANGE	E314.0	PERCHLORATE	4.2		UG/L	48.85	58.85	2
MW-243	W243M1A	9/14/2005	J-3 RANGE	E314.0	PERCHLORATE	3		UG/L	48.85	58.85	2
MW-243	W243M1A	12/12/2005	J-3 RANGE	E314.0	PERCHLORATE	4.2		UG/L	48.85	58.85	2
MW-243	MW-243M1	9/7/2007	J-3 RANGE	E314.0	PERCHLORATE	2.84	J	UG/L	48.85	58.85	2
MW-247	W247M2A	1/6/2003	J-3 RANGE	E314.0	PERCHLORATE	5.2		UG/L	102.78	112.78	2
MW-247	W247M2D	1/6/2003	J-3 RANGE	E314.0	PERCHLORATE	5.4		UG/L	102.78	112.78	2
MW-247	W247M2A	3/20/2003	J-3 RANGE	E314.0	PERCHLORATE	5.7		UG/L	102.78	112.78	2
MW-247	W247M2A	6/23/2003	J-3 RANGE	E314.0	PERCHLORATE	5.5		UG/L	102.78	112.78	2
MW-247	W247M2A	4/22/2004	J-3 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.2		UG/L	102.78	112.78	2
MW-247	W247M2A	4/22/2004	J-3 RANGE	E314.0	PERCHLORATE	4.4		UG/L	102.78	112.78	2
MW-247	W247M2A	5/13/2004	J-3 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.3		UG/L	102.78	112.78	2
MW-247	W247M2A	5/13/2004	J-3 RANGE	E314.0	PERCHLORATE	4.9		UG/L	102.78	112.78	2
MW-247	W247M2A	10/12/2004	J-3 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.9		UG/L	102.78	112.78	2
MW-247	W247M2A	10/12/2004	J-3 RANGE	E314.0	PERCHLORATE	3.5	J	UG/L	102.78	112.78	2
MW-247	W247M2A	12/2/2004	J-3 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.9		UG/L	102.78	112.78	2
MW-247	W247M2A	12/2/2004	J-3 RANGE	E314.0	PERCHLORATE	3.8	J	UG/L	102.78	112.78	2
MW-247	W247M2A	11/11/2005	J-3 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.4		UG/L	102.78	112.78	2
MW-247	W247M2A	11/11/2005	J-3 RANGE	E314.0	PERCHLORATE	2.7		UG/L	102.78	112.78	2
MW-247	W247M3A	11/19/2005	J-3 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.1		UG/L	72.8	82.8	2
MW-247	W247M2A	1/16/2006	J-3 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.5		UG/L	102.78	112.78	2
MW-247	W247M2A	1/16/2006	J-3 RANGE	E314.0	PERCHLORATE	2.3		UG/L	102.78	112.78	2
MW-247	W247M3A	1/16/2006	J-3 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.9		UG/L	72.8	82.8	2
MW-25	W25SSA	10/16/1997	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2		UG/L	0	10	2
MW-25	W25SSA	3/17/1999	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.1		UG/L	0	10	2

AOC = Area of Concern  
J = Estimated Result

BWTS = Depth Below Water Table Start (feet)  
BWTE = Depth Below Water Table End (feet)  
DW Limit = Either the MCL or Lowest Health Advisory Limit

TABLE 4

## VALIDATED DETECTS EXCEEDING MCLs or HEALTH ADVISORY LIMITS 1997 THROUGH September 2008

LOCID/WELL ID	SAMPLE_ID	SAMPLED	AOC	METHOD	ANALYTE	CONC	FLAG	UNITS	BWTS	BWTE	DW LIMIT
MW-25	W25SSA	9/14/1999	CIA	IM40MB	THALLIUM	5.3	J	UG/L	0	10	2
MW-25	MW-25S	11/28/2007	CIA	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2		ug/L	0	10	2
MW-250	W250M1A	1/6/2003	J-3 RANGE	E314.0	PERCHLORATE	3.1		UG/L	174.65	184.65	2
MW-250	W250M1A	3/19/2003	J-3 RANGE	E314.0	PERCHLORATE	2.5		UG/L	174.65	184.65	2
MW-250	W250M1A	4/22/2004	J-3 RANGE	E314.0	PERCHLORATE	2		UG/L	174.65	184.65	2
MW-250	W250M3A	5/19/2004	J-3 RANGE	E314.0	PERCHLORATE	2.1		UG/L	84.85	94.85	2
MW-250M2	W250M2A	1/6/2003	J-3 RANGE	E314.0	PERCHLORATE	7		UG/L	134.82	144.82	2
MW-250M2	W250M2A	3/19/2003	J-3 RANGE	E314.0	PERCHLORATE	6.7		UG/L	134.82	144.82	2
MW-250M2	W250M2A	6/23/2003	J-3 RANGE	E314.0	PERCHLORATE	6.2		UG/L	134.82	144.82	2
MW-250M2	W250M2A	4/22/2004	J-3 RANGE	E314.0	PERCHLORATE	6.3		UG/L	134.82	144.82	2
MW-250M2	W250M2A	5/19/2004	J-3 RANGE	E314.0	PERCHLORATE	6.6		UG/L	134.82	144.82	2
MW-250M2	W250M2A	10/12/2004	J-3 RANGE	E314.0	PERCHLORATE	5.7	J	UG/L	134.82	144.82	2
MW-250M2	W250M2A	12/2/2004	J-3 RANGE	E314.0	PERCHLORATE	5.7	J	UG/L	134.82	144.82	2
MW-250M2	W250M2A	6/4/2005	J-3 RANGE	E314.0	PERCHLORATE	5.5	J	UG/L	134.82	144.82	2
MW-250M2	W250M2A	10/10/2005	J-3 RANGE	E314.0	PERCHLORATE	2.9		UG/L	134.82	144.82	2
MW-250M2	W250M2A	1/16/2006	J-3 RANGE	E314.0	PERCHLORATE	2.5		UG/L	134.82	144.82	2
MW-250M2	MW-250M2_FAL08	9/11/2007	J-3 RANGE	E314.0	PERCHLORATE	4.88		UG/L	134.82	144.82	2
MW-250M2	MW-250M2_FAL08	8/7/2008	J-3 RANGE	E314.0	PERCHLORATE	7.83		UG/L	134.82	144.82	2
MW-255	MW-255M2	4/29/2007	DEMO 1	E314.0	PERCHLORATE	2.75	J	UG/L	60.43	70.43	2
MW-258	W258M2A	6/8/2005	DEMO 1	E314.0	PERCHLORATE	4		UG/L	42.2	47.2	2
MW-259	W259M1A	1/14/2005	DEMO 2	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.2		UG/L	7.62	17.62	2
MW-262	W262M1A	8/12/2003	DEMO 2	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.2		UG/L	7.02	17.02	2
MW-262	W262M1D	8/12/2003	DEMO 2	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.3		UG/L	7.02	17.02	2
MW-263	W263M2A	5/22/2003	J-2 RANGE	E314.0	PERCHLORATE	3.71		UG/L	8.66	18.66	2
MW-263	W263M2A	8/25/2003	J-2 RANGE	E314.0	PERCHLORATE	8.7		UG/L	8.66	18.66	2
MW-263	W263M2A	12/22/2003	J-2 RANGE	E314.0	PERCHLORATE	15	J	UG/L	8.66	18.66	2
MW-263	W263M2A	8/2/2004	J-2 RANGE	E314.0	PERCHLORATE	4	J	UG/L	8.66	18.66	2
MW-263	W263M2D	8/2/2004	J-2 RANGE	E314.0	PERCHLORATE	4.3	J	UG/L	8.66	18.66	2
MW-264	W264M1A	12/9/2003	J-3 RANGE	SW8270	BENZO(A)PYRENE	0.5	J	UG/L	160.94	170.94	0.2
MW-265M2	W265M2A	5/15/2003	J-1 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.5		UG/L	97.6	107.6	2
MW-265M2	W265M2A	5/15/2003	J-1 RANGE	E314.0	PERCHLORATE	30.4		UG/L	97.6	107.6	2
MW-265M2	W265M2A	12/1/2003	J-1 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.4		UG/L	97.6	107.6	2
MW-265M2	W265M2A	12/1/2003	J-1 RANGE	E314.0	PERCHLORATE	33		UG/L	97.6	107.6	2
MW-265M2	W265M2A	3/3/2004	J-1 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.5		UG/L	97.6	107.6	2
MW-265M2	W265M2A	3/3/2004	J-1 RANGE	E314.0	PERCHLORATE	30		UG/L	97.6	107.6	2
MW-265M2	W265M2A	9/27/2004	J-1 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.6		UG/L	97.6	107.6	2
MW-265M2	W265M2A	9/27/2004	J-1 RANGE	E314.0	PERCHLORATE	23		UG/L	97.6	107.6	2
MW-265M2	W265M2A	2/16/2005	J-1 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.4		UG/L	97.6	107.6	2
MW-265M2	W265M2A	2/16/2005	J-1 RANGE	E314.0	PERCHLORATE	18		UG/L	97.6	107.6	2
MW-265M2	W265M2A	5/16/2005	J-1 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.4		UG/L	97.6	107.6	2
MW-265M2	W265M2A	5/16/2005	J-1 RANGE	E314.0	PERCHLORATE	17		UG/L	97.6	107.6	2
MW-265M2	W265M2A	8/31/2005	J-1 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.9		UG/L	97.6	107.6	2
MW-265M2	W265M2A	8/31/2005	J-1 RANGE	E314.0	PERCHLORATE	23.4		UG/L	97.6	107.6	2
MW-265M2	W265M2A	1/26/2006	J-1 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.4		UG/L	97.6	107.6	2
MW-265M2	W265M2A	1/26/2006	J-1 RANGE	E314.0	PERCHLORATE	29.4		UG/L	97.6	107.6	2
MW-265M2	W265M2A	3/21/2006	J-1 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.4		UG/L	97.6	107.6	2
MW-265M2	W265M2A	3/21/2006	J-1 RANGE	E314.0	PERCHLORATE	30.6	J	UG/L	97.6	107.6	2

AOC = Area of Concern  
J = Estimated Result

BWTS = Depth Below Water Table Start (feet)

BWTE = Depth Below Water Table End (feet)

DW Limit = Either the MCL or Lowest Health Advisory Limit

TABLE 4

## VALIDATED DETECTS EXCEEDING MCLs or HEALTH ADVISORY LIMITS 1997 THROUGH September 2008

LOCID/WELL ID	SAMPLE_ID	SAMPLED	AOC	METHOD	ANALYTE	CONC	FLAG	UNITS	BWTS	BWTE	DW LIMIT
MW-265M2	MW-265M2-	4/17/2007	J-1 RANGE	E314.0	PERCHLORATE	24.6		UG/L	97.6	107.6	2
MW-265M2	MW-265M2-FD	4/17/2007	J-1 RANGE	E314.0	PERCHLORATE	24.7		UG/L	97.6	107.6	2
MW-265M2	MW-265M2_0508	6/16/2008	CIA [108]	E314.0	PERCHLORATE	25.5		UG/L	97.6	107.6	2
MW-265M2	MW-265M2_0508D	6/16/2008	CIA [108]	E314.0	PERCHLORATE	25.2		UG/L	97.6	107.6	2
MW-265M3	W265M3A	5/15/2003	J-1 RANGE	E314.0	PERCHLORATE	4.41		UG/L	72.44	82.44	2
MW-265M3	W265M3A	12/1/2003	J-1 RANGE	E314.0	PERCHLORATE	9.7		UG/L	72.44	82.44	2
MW-265M3	W265M3A	3/3/2004	J-1 RANGE	E314.0	PERCHLORATE	10		UG/L	72.44	82.44	2
MW-265M3	W265M3A	10/5/2004	J-1 RANGE	E314.0	PERCHLORATE	8.9		UG/L	72.44	82.44	2
MW-265M3	W265M3A	2/16/2005	J-1 RANGE	E314.0	PERCHLORATE	7	J	UG/L	72.44	82.44	2
MW-265M3	W265M3A	5/16/2005	J-1 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.4		UG/L	72.44	82.44	2
MW-265M3	W265M3A	5/16/2005	J-1 RANGE	E314.0	PERCHLORATE	6.4		UG/L	72.44	82.44	2
MW-265M3	W265M3A	8/31/2005	J-1 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.7		UG/L	72.44	82.44	2
MW-265M3	W265M3A	8/31/2005	J-1 RANGE	E314.0	PERCHLORATE	4.6		UG/L	72.44	82.44	2
MW-265M3	W265M3A	3/21/2006	J-1 RANGE	E314.0	PERCHLORATE	2	J	UG/L	72.44	82.44	2
MW-267	W267M1A	5/30/2003	WESTERN BOUNDARY	E314.0	PERCHLORATE	2.89		UG/L	18.57	28.57	2
MW-267	W267M1A	6/25/2003	WESTERN BOUNDARY	E314.0	PERCHLORATE	2.8		UG/L	18.57	28.57	2
MW-267	W267M1A	7/30/2003	WESTERN BOUNDARY	E314.0	PERCHLORATE	2.62		UG/L	18.57	28.57	2
MW-27	W27SSA	9/17/1999	CIA	OC21B	BIS(2-ETHYLHEXYL) PHTHALATE	9		UG/L	0	10	6
MW-270M1	W270M1A	6/16/2003	NW CORNER	E314.0	PERCHLORATE	8.9		UG/L	50.89	55.89	2
MW-270M1	W270M1D	6/16/2003	NW CORNER	E314.0	PERCHLORATE	9.1		UG/L	50.89	55.89	2
MW-270M1	W270M1A	9/30/2003	NW CORNER	E314.0	PERCHLORATE	11		UG/L	50.89	55.89	2
MW-270M1	W270M1D	9/30/2003	NW CORNER	E314.0	PERCHLORATE	11		UG/L	50.89	55.89	2
MW-270M1	W270M1A	1/6/2004	NW CORNER	E314.0	PERCHLORATE	11	J	UG/L	50.89	55.89	2
MW-270M1	W270M1D	1/6/2004	NW CORNER	E314.0	PERCHLORATE	11	J	UG/L	50.89	55.89	2
MW-270M1	W270M1A	4/29/2004	NW CORNER	E314.0	PERCHLORATE	8.94		UG/L	50.89	55.89	2
MW-270M1	W270M1A	9/10/2004	NW CORNER	E314.0	PERCHLORATE	9.7		UG/L	50.89	55.89	2
MW-270M1	W270M1A	2/10/2005	NW CORNER	E314.0	PERCHLORATE	10.3		UG/L	50.89	55.89	2
MW-270M1	W270M1A	6/8/2005	NW CORNER	E314.0	PERCHLORATE	13		UG/L	50.89	55.89	2
MW-270M1	W270M1A	9/1/2005	NW CORNER	E314.0	PERCHLORATE	14.2		UG/L	50.89	55.89	2
MW-270M1	W270M1A	12/12/2005	NW CORNER	E314.0	PERCHLORATE	14.6		UG/L	50.89	55.89	2
MW-270M1	W270M1D	12/12/2005	NW CORNER	E314.0	PERCHLORATE	14.5		UG/L	50.89	55.89	2
MW-270M1	W270M1A	4/11/2006	NW CORNER	E314.0	PERCHLORATE	13.5		UG/L	50.89	55.89	2
MW-270M1	W270M1A	9/28/2006	NW CORNER	E314.0	PERCHLORATE	9.6		UG/L	50.89	55.89	2
MW-270M1	MW-270M1-	4/26/2007	NW CORNER	E314.0	PERCHLORATE	9		UG/L	50.89	55.89	2
MW-270M1	MW-270M1-RD	4/26/2007	NW CORNER	E314.0	PERCHLORATE	9.59		UG/L	50.89	55.89	2
MW-270M1	MW-270M1_0508	5/12/2008	NWC [167]	E314.0	PERCHLORATE	5.9		UG/L	50.89	55.89	2
MW-270M1	MW-270M1_0508D	5/12/2008	NWC [167]	E314.0	PERCHLORATE	5.7		UG/L	50.89	55.89	2
MW-270S	W270SSA	9/30/2003	NW CORNER	E314.0	PERCHLORATE	2		UG/L	0	10	2
MW-270S	W270SSA	2/10/2005	NW CORNER	E314.0	PERCHLORATE	2		UG/L	0	10	2
MW-270S	W270SSA	9/1/2005	NW CORNER	E314.0	PERCHLORATE	2.2		UG/L	0	10	2
MW-270S	W270SSA	4/11/2006	NW CORNER	E314.0	PERCHLORATE	2		UG/L	0	10	2
MW-270S	MW-270S-	4/26/2007	NW CORNER	E314.0	PERCHLORATE	2.3		UG/L	0	10	2
MW-270S	MW-270M2_0508	5/12/2008	NWC [167]	E314.0	PERCHLORATE	2		UG/L	22	32	2
MW-274	2023	4/23/2008	DEMO 1	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.06		UG/L	109	199	2
MW-274	2023	4/23/2008	DEMO 1	E314.0	PERCHLORATE	5.02		UG/L	109	199	2
MW-277	W277SSA	7/10/2003	NW CORNER	E314.0	PERCHLORATE	6.68		UG/L	0	10	2
MW-277	W277SSA	12/12/2003	NW CORNER	E314.0	PERCHLORATE	5.27		UG/L	0	10	2

AOC = Area of Concern  
J = Estimated Result

BWTS = Depth Below Water Table Start (feet)

BWTE = Depth Below Water Table End (feet)

DW Limit = Either the MCL or Lowest Health Advisory Limit

TABLE 4

## VALIDATED DETECTS EXCEEDING MCLs or HEALTH ADVISORY LIMITS 1997 THROUGH September 2008

LOCID/WELL ID	SAMPLE_ID	SAMPLED	AOC	METHOD	ANALYTE	CONC	FLAG	UNITS	BWTS	BWTE	DW LIMIT
MW-277	W277SSA	1/20/2004	NW CORNER	E314.0	PERCHLORATE	5.2		UG/L	0	10	2
MW-277	W277SSA	2/18/2004	NW CORNER	E314.0	PERCHLORATE	4.06		UG/L	0	10	2
MW-277	W277SSA	3/17/2004	NW CORNER	E314.0	PERCHLORATE	4.18		UG/L	0	10	2
MW-277	W277SSA	4/14/2004	NW CORNER	E314.0	PERCHLORATE	3.74		UG/L	0	10	2
MW-277	W277SSA	5/12/2004	NW CORNER	E314.0	PERCHLORATE	3.49		UG/L	0	10	2
MW-277	W277SSA	6/9/2004	NW CORNER	E314.0	PERCHLORATE	3.36		UG/L	0	10	2
MW-277	W277SSA	7/7/2004	NW CORNER	E314.0	PERCHLORATE	3.14		UG/L	0	10	2
MW-277	W277SSA	8/4/2004	NW CORNER	E314.0	PERCHLORATE	3.09		UG/L	0	10	2
MW-277	W277SSA	9/8/2004	NW CORNER	E314.0	PERCHLORATE	2.9		UG/L	0	10	2
MW-277	W277SSA	10/6/2004	NW CORNER	E314.0	PERCHLORATE	3.3		UG/L	0	10	2
MW-277	W277SSA	11/2/2004	NW CORNER	E314.0	PERCHLORATE	3.11		UG/L	0	10	2
MW-277	W277SSA	12/14/2004	NW CORNER	E314.0	PERCHLORATE	3.03		UG/L	0	10	2
MW-277	W277SSA	2/17/2005	NW CORNER	E314.0	PERCHLORATE	2.1		UG/L	0	10	2
MW-277	W277SSA	3/22/2005	NW CORNER	E314.0	PERCHLORATE	2.09		UG/L	0	10	2
MW-277	W277SSA	8/26/2005	NW CORNER	E314.0	PERCHLORATE	2.3		UG/L	0	10	2
MW-277	W277SSA	9/16/2005	NW CORNER	E314.0	PERCHLORATE	2.5		UG/L	0	10	2
MW-277	W277SSD	9/16/2005	NW CORNER	E314.0	PERCHLORATE	2.5		UG/L	0	10	2
MW-277	W277SSA	10/27/2005	NW CORNER	E314.0	PERCHLORATE	2.5		UG/L	0	10	2
MW-277	W277SSA	12/28/2005	NW CORNER	E314.0	PERCHLORATE	2		UG/L	0	10	2
MW-277	W277SSA	4/10/2006	NW CORNER	E314.0	PERCHLORATE	2		UG/L	0	10	2
MW-277	W277SSA	9/28/2006	NW CORNER	E314.0	PERCHLORATE	3.1		UG/L	0	10	2
MW-277	W277SSD	9/28/2006	NW CORNER	E314.0	PERCHLORATE	2.7		UG/L	0	10	2
MW-277	MW-277S-	4/20/2007	NW CORNER	E314.0	PERCHLORATE	2.1		UG/L	0	10	2
MW-278M1	W278M1A	12/27/2005	NW CORNER	E314.0	PERCHLORATE	2.4		UG/L	25.76	35.76	2
MW-278M1	W278M1A	4/6/2006	NW CORNER	E314.0	PERCHLORATE	2.6		UG/L	25.76	35.76	2
MW-278M2	W278M2A	7/16/2003	NW CORNER	E314.0	PERCHLORATE	2.53		UG/L	9.79	14.79	2
MW-278M2	W278M2D	7/16/2003	NW CORNER	E314.0	PERCHLORATE	2.45		UG/L	9.79	14.79	2
MW-278M2	W278M2A	12/3/2003	NW CORNER	E314.0	PERCHLORATE	7.1		UG/L	9.79	14.79	2
MW-278M2	W278M2D	12/3/2003	NW CORNER	E314.0	PERCHLORATE	7.4		UG/L	9.79	14.79	2
MW-278M2	W278M2A	1/20/2004	NW CORNER	E314.0	PERCHLORATE	5.4		UG/L	9.79	14.79	2
MW-278M2	W278M2A	2/19/2004	NW CORNER	E314.0	PERCHLORATE	3.91		UG/L	9.79	14.79	2
MW-278M2	W278M2A	3/17/2004	NW CORNER	E314.0	PERCHLORATE	3.4		UG/L	9.79	14.79	2
MW-278M2	W278M2A	4/14/2004	NW CORNER	E314.0	PERCHLORATE	3.02		UG/L	9.79	14.79	2
MW-278M2	W278M2A	5/12/2004	NW CORNER	E314.0	PERCHLORATE	2.61		UG/L	9.79	14.79	2
MW-278M2	W278M2A	6/9/2004	NW CORNER	E314.0	PERCHLORATE	2.22		UG/L	9.79	14.79	2
MW-278M2	W278M2A	5/25/2005	NW CORNER	E314.0	PERCHLORATE	2.1		UG/L	9.79	14.79	2
MW-278M2	W278M2A	7/20/2005	NW CORNER	E314.0	PERCHLORATE	2.6		UG/L	9.79	14.79	2
MW-278M2	W278M2D	7/20/2005	NW CORNER	E314.0	PERCHLORATE	2.6		UG/L	9.79	14.79	2
MW-278M2	W278M2A	12/27/2005	NW CORNER	E314.0	PERCHLORATE	9.2		UG/L	9.79	14.79	2
MW-278M2	W278M2A	4/6/2006	NW CORNER	E314.0	PERCHLORATE	12.4		UG/L	9.79	14.79	2
MW-278M2	MW-278M2-	4/23/2007	NW CORNER	E314.0	PERCHLORATE	6.2		UG/L	9.79	14.79	2
MW-278M2	MW-278M2_0508	5/8/2008	NWC [167]	E314.0	PERCHLORATE	4.3		UG/L	9.79	14.79	2
MW-278S	W278SSA	7/18/2003	NW CORNER	E314.0	PERCHLORATE	19.3		UG/L	0	10	2
MW-278S	W278SSA	6/20/2005	NW CORNER	E314.0	PERCHLORATE	11	J	UG/L	0	10	2
MW-278S	W278SSA	7/20/2005	NW CORNER	E314.0	PERCHLORATE	12.4		UG/L	0	10	2
MW-278S	W278SSA	8/26/2005	NW CORNER	E314.0	PERCHLORATE	13.8		UG/L	0	10	2
MW-278S	W278SSA	9/16/2005	NW CORNER	E314.0	PERCHLORATE	15.4		UG/L	0	10	2

AOC = Area of Concern  
J = Estimated Result

BWTS = Depth Below Water Table Start (feet)

BWTE = Depth Below Water Table End (feet)

DW Limit = Either the MCL or Lowest Health Advisory Limit

TABLE 4

## VALIDATED DETECTS EXCEEDING MCLs or HEALTH ADVISORY LIMITS 1997 THROUGH September 2008

LOCID/WELL ID	SAMPLE_ID	SAMPLED	AOC	METHOD	ANALYTE	CONC	FLAG	UNITS	BWTS	BWTE	DW LIMIT
MW-278S	W278SSA	10/27/2005	NW CORNER	E314.0	PERCHLORATE	15.8		UG/L	0	10	2
MW-278S	W278SSA	12/5/2005	NW CORNER	E314.0	PERCHLORATE	15.6		UG/L	0	10	2
MW-278S	W278SSA	12/27/2005	NW CORNER	E314.0	PERCHLORATE	15.4		UG/L	0	10	2
MW-278S	W278SSA	12/27/2005	NW CORNER	E314.0	PERCHLORATE	15.8		UG/L	0	10	2
MW-278S	W278SSA	4/10/2006	NW CORNER	E314.0	PERCHLORATE	15.9		UG/L	0	10	2
MW-278S	W278SSA	9/28/2006	NW CORNER	E314.0	PERCHLORATE	10.5		UG/L	0	10	2
MW-278S	MW-278S-	4/23/2007	NW CORNER	E314.0	PERCHLORATE	6.9		UG/L	0	10	2
MW-278S	MW-278S-	10/8/2007	NW CORNER	E314.0	PERCHLORATE	5.3		ug/L	0	10	2
MW-278S	MW-278S_0508	5/8/2008	NWC [167]	E314.0	PERCHLORATE	2		UG/L	0	10	2
MW-279M1	W279M1A	7/30/2003	NW CORNER	E314.0	PERCHLORATE	2.66		UG/L	37.4	47.4	2
MW-279M1	W279M1A	12/10/2003	NW CORNER	E314.0	PERCHLORATE	2.24		UG/L	37.4	47.4	2
MW-279M1	W279M1A	2/18/2004	NW CORNER	E314.0	PERCHLORATE	3.31		UG/L	37.4	47.4	2
MW-279M1	W279M1A	3/17/2004	NW CORNER	E314.0	PERCHLORATE	4.6		UG/L	37.4	47.4	2
MW-279M1	W279M1A	4/14/2004	NW CORNER	E314.0	PERCHLORATE	6.15		UG/L	37.4	47.4	2
MW-279M1	W279M1A	5/12/2004	NW CORNER	E314.0	PERCHLORATE	5.17		UG/L	37.4	47.4	2
MW-279M1	W279M1A	6/9/2004	NW CORNER	E314.0	PERCHLORATE	5.05		UG/L	37.4	47.4	2
MW-279M1	W279M1D	6/9/2004	NW CORNER	E314.0	PERCHLORATE	5.14		UG/L	37.4	47.4	2
MW-279M1	W279M1A	7/7/2004	NW CORNER	E314.0	PERCHLORATE	4.63		UG/L	37.4	47.4	2
MW-279M1	W279M1A	8/4/2004	NW CORNER	E314.0	PERCHLORATE	4.61		UG/L	37.4	47.4	2
MW-279M1	W279M1A	9/8/2004	NW CORNER	E314.0	PERCHLORATE	3.76		UG/L	37.4	47.4	2
MW-279M1	W279M1A	10/6/2004	NW CORNER	E314.0	PERCHLORATE	3.95		UG/L	37.4	47.4	2
MW-279M1	W279M1A	11/2/2004	NW CORNER	E314.0	PERCHLORATE	3.87		UG/L	37.4	47.4	2
MW-279M1	W279M1A	12/14/2004	NW CORNER	E314.0	PERCHLORATE	3.54		UG/L	37.4	47.4	2
MW-279M1	W279M1A	5/25/2005	NW CORNER	E314.0	PERCHLORATE	3.8		UG/L	37.4	47.4	2
MW-279M1	W279M1A	7/19/2005	NW CORNER	E314.0	PERCHLORATE	4		UG/L	37.4	47.4	2
MW-279M1	W279M1A	4/10/2006	NW CORNER	E314.0	PERCHLORATE	8.1		UG/L	37.4	47.4	2
MW-279M1	MW-279M1-	4/24/2007	NW CORNER	E314.0	PERCHLORATE	3.1		UG/L	37.4	47.4	2
MW-279M2	W279M2A	7/30/2003	NW CORNER	E314.0	PERCHLORATE	6.06		UG/L	26.8	31.8	2
MW-279M2	W279M2D	7/30/2003	NW CORNER	E314.0	PERCHLORATE	6.15		UG/L	26.8	31.8	2
MW-279M2	W279M2A	12/10/2003	NW CORNER	E314.0	PERCHLORATE	2.92		UG/L	26.8	31.8	2
MW-279M2	W279M2A	2/19/2004	NW CORNER	E314.0	PERCHLORATE	3.22		UG/L	26.8	31.8	2
MW-279M2	W279M2A	3/17/2004	NW CORNER	E314.0	PERCHLORATE	3.9		UG/L	26.8	31.8	2
MW-279M2	W279M2D	3/17/2004	NW CORNER	E314.0	PERCHLORATE	3.9		UG/L	26.8	31.8	2
MW-279M2	W279M2A	4/14/2004	NW CORNER	E314.0	PERCHLORATE	4.03		UG/L	26.8	31.8	2
MW-279M2	W279M2D	4/14/2004	NW CORNER	E314.0	PERCHLORATE	4.04		UG/L	26.8	31.8	2
MW-279M2	W279M2A	5/12/2004	NW CORNER	E314.0	PERCHLORATE	4.51		UG/L	26.8	31.8	2
MW-279M2	W279M2A	6/9/2004	NW CORNER	E314.0	PERCHLORATE	4.95		UG/L	26.8	31.8	2
MW-279M2	W279M2A	7/7/2004	NW CORNER	E314.0	PERCHLORATE	4.84		UG/L	26.8	31.8	2
MW-279M2	W279M2D	7/7/2004	NW CORNER	E314.0	PERCHLORATE	4.87		UG/L	26.8	31.8	2
MW-279M2	W279M2A	8/4/2004	NW CORNER	E314.0	PERCHLORATE	4.99		UG/L	26.8	31.8	2
MW-279M2	W279M2A	9/8/2004	NW CORNER	E314.0	PERCHLORATE	4.5		UG/L	26.8	31.8	2
MW-279M2	W279M2D	9/8/2004	NW CORNER	E314.0	PERCHLORATE	4.63		UG/L	26.8	31.8	2
MW-279M2	W279M2A	10/6/2004	NW CORNER	E314.0	PERCHLORATE	5.12		UG/L	26.8	31.8	2
MW-279M2	W279M2A	11/2/2004	NW CORNER	E314.0	PERCHLORATE	5.26		UG/L	26.8	31.8	2
MW-279M2	W279M2A	12/14/2004	NW CORNER	E314.0	PERCHLORATE	5.67		UG/L	26.8	31.8	2
MW-279M2	W279M2A	2/17/2005	NW CORNER	E314.0	PERCHLORATE	6.26		UG/L	26.8	31.8	2
MW-279M2	W279M2A	5/25/2005	NW CORNER	E314.0	PERCHLORATE	14		UG/L	26.8	31.8	2

AOC = Area of Concern  
J = Estimated Result

BWTS = Depth Below Water Table Start (feet)

BWTE = Depth Below Water Table End (feet)

DW Limit = Either the MCL or Lowest Health Advisory Limit

TABLE 4

## VALIDATED DETECTS EXCEEDING MCLs or HEALTH ADVISORY LIMITS 1997 THROUGH September 2008

LOCID/WELL ID	SAMPLE_ID	SAMPLED	AOC	METHOD	ANALYTE	CONC	FLAG	UNITS	BWTS	BWTE	DW LIMIT
MW-279M2	W279M2A	7/19/2005	NW CORNER	E314.0	PERCHLORATE	10.3		UG/L	26.8	31.8	2
MW-279M2	W279M2A	4/10/2006	NW CORNER	E314.0	PERCHLORATE	13.9		UG/L	26.8	31.8	2
MW-279M2	MW-279M2-	4/24/2007	NW CORNER	E314.0	PERCHLORATE	12		UG/L	26.8	31.8	2
MW-279M2	MW-279M2_0508	5/8/2008	NWC [167]	E314.0	PERCHLORATE	13.4		UG/L	26.8	31.8	2
MW-279S	W279SSA	7/30/2003	NW CORNER	E314.0	PERCHLORATE	16.7		UG/L	10	20	2
MW-279S	W279SSA	12/10/2003	NW CORNER	E314.0	PERCHLORATE	15.7		UG/L	10	20	2
MW-279S	W279SSA	1/20/2004	NW CORNER	E314.0	PERCHLORATE	17		UG/L	10	20	2
MW-279S	W279SSA	2/19/2004	NW CORNER	E314.0	PERCHLORATE	11.4		UG/L	10	20	2
MW-279S	W279SSA	3/17/2004	NW CORNER	E314.0	PERCHLORATE	11.2		UG/L	10	20	2
MW-279S	W279SSA	4/15/2004	NW CORNER	E314.0	PERCHLORATE	9.84		UG/L	10	20	2
MW-279S	W279SSA	5/14/2004	NW CORNER	E314.0	PERCHLORATE	11.9		UG/L	10	20	2
MW-279S	W279SSA	6/9/2004	NW CORNER	E314.0	PERCHLORATE	11.1		UG/L	10	20	2
MW-279S	W279SSA	7/7/2004	NW CORNER	E314.0	PERCHLORATE	10.5		UG/L	10	20	2
MW-279S	W279SSA	8/4/2004	NW CORNER	E314.0	PERCHLORATE	13.7		UG/L	10	20	2
MW-279S	W279SSA	9/8/2004	NW CORNER	E314.0	PERCHLORATE	15.2		UG/L	10	20	2
MW-279S	W279SSA	10/6/2004	NW CORNER	E314.0	PERCHLORATE	19.7		UG/L	10	20	2
MW-279S	W279SSA	11/3/2004	NW CORNER	E314.0	PERCHLORATE	20.4		UG/L	10	20	2
MW-279S	W279SSA	12/14/2004	NW CORNER	E314.0	PERCHLORATE	23.1		UG/L	10	20	2
MW-279S	W279SSA	3/22/2005	NW CORNER	E314.0	PERCHLORATE	26.3		UG/L	10	20	2
MW-279S	W279SSA	4/27/2005	NW CORNER	E314.0	PERCHLORATE	17		UG/L	10	20	2
MW-279S	W279SSA	5/25/2005	NW CORNER	E314.0	PERCHLORATE	16		UG/L	10	20	2
MW-279S	W279SSA	6/20/2005	NW CORNER	E314.0	PERCHLORATE	13		UG/L	10	20	2
MW-279S	W279SSA	7/19/2005	NW CORNER	E314.0	PERCHLORATE	16.3		UG/L	10	20	2
MW-279S	W279SSA	8/26/2005	NW CORNER	E314.0	PERCHLORATE	21.1		UG/L	10	20	2
MW-279S	W279SSA	9/16/2005	NW CORNER	E314.0	PERCHLORATE	24.4		UG/L	10	20	2
MW-279S	W279SSA	10/27/2005	NW CORNER	E314.0	PERCHLORATE	23.9		UG/L	10	20	2
MW-279S	W279SSD	10/27/2005	NW CORNER	E314.0	PERCHLORATE	23.9		UG/L	10	20	2
MW-279S	W279SSA	12/5/2005	NW CORNER	E314.0	PERCHLORATE	20.4		UG/L	10	20	2
MW-279S	W279SSA	12/28/2005	NW CORNER	E314.0	PERCHLORATE	9.5		UG/L	10	20	2
MW-279S	W279SSA	12/28/2005	NW CORNER	E314.0	PERCHLORATE	9.6		UG/L	10	20	2
MW-279S	W279SSA	4/10/2006	NW CORNER	E314.0	PERCHLORATE	10.4		UG/L	10	20	2
MW-279S	W279SSA	9/28/2006	NW CORNER	E314.0	PERCHLORATE	9.2		UG/L	10	20	2
MW-279S	MW-279S-	4/24/2007	NW CORNER	E314.0	PERCHLORATE	2.6		UG/L	10	20	2
MW-279S	MW-279S-RD	4/24/2007	NW CORNER	E314.0	PERCHLORATE	2.61		UG/L	10	20	2
MW-279S	MW-279S-	10/11/2007	NW CORNER	E314.0	PERCHLORATE	13	ug/L	10	20	2	
MW-279S	MW-279S_0508D	5/8/2008	NWC [167]	E314.0	PERCHLORATE	2		UG/L	10	20	2
MW-28	W28SSA	11/3/1997	OTHER	OC21B	BIS(2-ETHYLHEXYL) PHTHALATE	11		UG/L	0	10	6
MW-28	W28SSA	9/17/1999	OTHER	OC21B	BIS(2-ETHYLHEXYL) PHTHALATE	150	J	UG/L	0	10	6
MW-28	W28M1A	1/12/2001	J-3 RANGE	SW8270	BIS(2-ETHYLHEXYL) PHTHALATE	9.7		UG/L	173	183	6
MW-28	W28SSA	10/12/2005	OTHER	OC21VM	1,2-DIBROMO-3-CHLOROPROPANE	0.2	J	UG/L	0	10	0.2
MW-283M1	W283M1A	6/17/2005	NW CORNER	E314.0	PERCHLORATE	2.5		UG/L	29.12	39.12	2
MW-283M1	W283M1D	6/17/2005	NW CORNER	E314.0	PERCHLORATE	2.7		UG/L	29.12	39.12	2
MW-283M1	W283M1A	9/19/2005	NW CORNER	E314.0	PERCHLORATE	3.8		UG/L	29.12	39.12	2
MW-283M1	W283M1D	9/19/2005	NW CORNER	E314.0	PERCHLORATE	3.8		UG/L	29.12	39.12	2
MW-283M1	W283M1A	1/9/2006	NW CORNER	E314.0	PERCHLORATE	3.7		UG/L	29.12	39.12	2
MW-283M1	W283M1A	4/11/2006	NW CORNER	E314.0	PERCHLORATE	3.8		UG/L	29.12	39.12	2
MW-283M1	W283M1A	10/9/2006	NW CORNER	E314.0	PERCHLORATE	3.3		UG/L	29.12	39.12	2

AOC = Area of Concern  
J = Estimated Result

BWTS = Depth Below Water Table Start (feet)

BWTE = Depth Below Water Table End (feet)

DW Limit = Either the MCL or Lowest Health Advisory Limit

TABLE 4

## VALIDATED DETECTS EXCEEDING MCLs or HEALTH ADVISORY LIMITS 1997 THROUGH September 2008

LOCID/WELL ID	SAMPLE_ID	SAMPLED	AOC	METHOD	ANALYTE	CONC	FLAG	UNITS	BWTS	BWTE	DW LIMIT
MW-283M1	MW-283M1-	4/26/2007	NW CORNER	E314.0	PERCHLORATE	3		UG/L	29.12	39.12	2
MW-283M1	MW-283M1-	10/16/2007	NW CORNER	E314.0	PERCHLORATE	2.3		ug/L	29.1	39.1	2
MW-283M1	MW-283M1_0508	5/12/2008	NWC [167]	E314.0	PERCHLORATE	2.8		UG/L	29.1	39.1	2
MW-284M2	W284M2A	9/12/2003	NW CORNER	E314.0	PERCHLORATE	3.04		UG/L	21.2	31.2	2
MW-284M2	W284M2A	12/2/2003	NW CORNER	E314.0	PERCHLORATE	2.89		UG/L	21.2	31.2	2
MW-284M2	W284M2A	3/10/2004	NW CORNER	E314.0	PERCHLORATE	3.3		UG/L	21.2	31.2	2
MW-284M2	W284M2A	8/26/2004	NW CORNER	E314.0	PERCHLORATE	3.1	J	UG/L	21.2	31.2	2
MW-284M2	W284M2A	2/15/2005	NW CORNER	E314.0	PERCHLORATE	3.4		UG/L	21.2	31.2	2
MW-284M2	W284M2A	6/10/2005	NW CORNER	E314.0	PERCHLORATE	4		UG/L	21.2	31.2	2
MW-284M2	W284M2D	6/10/2005	NW CORNER	E314.0	PERCHLORATE	4.2		UG/L	21.2	31.2	2
MW-284M2	W284M2A	9/19/2005	NW CORNER	E314.0	PERCHLORATE	4.1		UG/L	21.2	31.2	2
MW-284M2	W284M2A	1/3/2006	NW CORNER	E314.0	PERCHLORATE	4.2		UG/L	21.2	31.2	2
MW-284M2	W284M2A	10/9/2006	NW CORNER	E314.0	PERCHLORATE	4.9		UG/L	21.2	31.2	2
MW-284M2	MW-284M2-	4/25/2007	NW CORNER	E314.0	PERCHLORATE	5.1		UG/L	21.2	31.2	2
MW-284M2	MW-284M2-FD	4/25/2007	NW CORNER	E314.0	PERCHLORATE	5.2		UG/L	21.2	31.2	2
MW-284M2	MW-284M2-RD	4/25/2007	NW CORNER	E314.0	PERCHLORATE	5.31		UG/L	21.2	31.2	2
MW-284M2	MW-284M2-	10/11/2007	NW CORNER	E314.0	PERCHLORATE	5.5		ug/L	21.2	31.2	2
MW-284M2	MW-284M2-FD	10/11/2007	NW CORNER	E314.0	PERCHLORATE	5.6		ug/L	21.2	31.2	2
MW-284M2	MW-284M2_0508	5/13/2008	NWC [167]	E314.0	PERCHLORATE	5.9		UG/L	21.2	31.2	2
MW-284M2	MW-284M2_0508D	5/13/2008	NWC [167]	E314.0	PERCHLORATE	5.9		UG/L	21.2	31.2	2
MW-286	W286M2A	12/2/2003	J-1 RANGE	E314.0	PERCHLORATE	2.13		UG/L	81.42	91.42	2
MW-286	W286M2A	1/14/2005	J-1 RANGE	E314.0	PERCHLORATE	2		UG/L	81.42	91.42	2
MW-286	W286M2A	6/13/2005	J-1 RANGE	E314.0	PERCHLORATE	6.4		UG/L	81.42	91.42	2
MW-286	W286M2A	9/29/2005	J-1 RANGE	E314.0	PERCHLORATE	7.6		UG/L	81.42	91.42	2
MW-286	W286M2A	1/23/2006	J-1 RANGE	E314.0	PERCHLORATE	6.8		UG/L	81.42	91.42	2
MW-286	W286M2A	3/20/2006	J-1 RANGE	E314.0	PERCHLORATE	7	J	UG/L	81.42	91.42	2
MW-286	MW-286M2-	4/13/2007	J-1 RANGE	E314.0	PERCHLORATE	5.1		UG/L	81.42	91.42	2
MW-287	W287SSA	3/23/2004	NW CORNER	E314.0	PERCHLORATE	2.2		UG/L	0	10	2
MW-289M1	MW-289M1-	9/18/2003	J-2 RANGE	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2		UG/L	203	213	2
MW-289M1	MW-289M1-	9/18/2003	J-2 RANGE	E314.0	PERCHLORATE	24		UG/L	203	213	2
MW-289M1	MW-289M1-	3/31/2004	J-2 RANGE	E314.0	PERCHLORATE	6.9		UG/L	203	213	2
MW-289M1	MW-289M1-	7/29/2004	J-2 RANGE	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.1		UG/L	203	213	2
MW-289M1	MW-289M1-	7/29/2004	J-2 RANGE	E314.0	PERCHLORATE	9.2		UG/L	203	213	2
MW-289M1	W289M1A	2/16/2005	J-2 RANGE	E314.0	PERCHLORATE	8.2	J	UG/L	203	213	2
MW-289M1	W289M1A	5/31/2005	J-2 RANGE	E314.0	PERCHLORATE	5.5		UG/L	203	213	2
MW-289M1	W289M1A	8/23/2005	J-2 RANGE	E314.0	PERCHLORATE	3.5		UG/L	203	213	2
MW-289M1	W289M1A	2/3/2006	J-2 RANGE	E314.0	PERCHLORATE	2.5		UG/L	203	213	2
MW-289M1	W289M1A	9/20/2006	J-2 RANGE	E314.0	PERCHLORATE	2.6		UG/L	203	213	2
MW-289M1	W289M1D	9/20/2006	J-2 RANGE	E314.0	PERCHLORATE	2.7		UG/L	203	213	2
MW-289M2	MW-289M2-	9/18/2003	J-2 RANGE	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	11		UG/L	59.7	69.7	2
MW-289M2	MW-289M2-	9/18/2003	J-2 RANGE	E314.0	PERCHLORATE	140		UG/L	59.7	69.7	2
MW-289M2	MW-289M2-FD	9/18/2003	J-2 RANGE	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	11		UG/L	59.7	69.7	2
MW-289M2	MW-289M2-FD	9/18/2003	J-2 RANGE	E314.0	PERCHLORATE	140		UG/L	59.7	69.7	2
MW-289M2	MW-289M2-	3/31/2004	J-2 RANGE	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	8		UG/L	59.7	69.7	2
MW-289M2	MW-289M2-	3/31/2004	J-2 RANGE	E314.0	PERCHLORATE	110		UG/L	59.7	69.7	2
MW-289M2	MW-289M2-	7/29/2004	J-2 RANGE	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5.9		UG/L	59.7	69.7	2
MW-289M2	MW-289M2-	7/29/2004	J-2 RANGE	E314.0	PERCHLORATE	63		UG/L	59.7	69.7	2

AOC = Area of Concern  
J = Estimated Result

BWTS = Depth Below Water Table Start (feet)

BWTE = Depth Below Water Table End (feet)

DW Limit = Either the MCL or Lowest Health Advisory Limit

TABLE 4

## VALIDATED DETECTS EXCEEDING MCLs or HEALTH ADVISORY LIMITS 1997 THROUGH September 2008

LOCID/WELL ID	SAMPLE_ID	SAMPLED	AOC	METHOD	ANALYTE	CONC	FLAG	UNITS	BWTS	BWTE	DW LIMIT
MW-289M2	MW-289M2-FD	7/29/2004	J-2 RANGE	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5.7		UG/L	59.7	69.7	2
MW-289M2	MW-289M2-FD	7/29/2004	J-2 RANGE	E314.0	PERCHLORATE	64		UG/L	59.7	69.7	2
MW-289M2	W289M2A	2/17/2005	J-2 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.5		UG/L	59.7	69.7	2
MW-289M2	W289M2A	2/17/2005	J-2 RANGE	E314.0	PERCHLORATE	50	J	UG/L	59.7	69.7	2
MW-289M2	W289M2A	5/31/2005	J-2 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.8		UG/L	59.7	69.7	2
MW-289M2	W289M2A	5/31/2005	J-2 RANGE	E314.0	PERCHLORATE	17		UG/L	59.7	69.7	2
MW-289M2	W289M2A	8/22/2005	J-2 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.8		UG/L	59.7	69.7	2
MW-289M2	W289M2A	8/22/2005	J-2 RANGE	E314.0	PERCHLORATE	14.8		UG/L	59.7	69.7	2
MW-289M2	W289M2A	2/3/2006	J-2 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.1		UG/L	59.7	69.7	2
MW-289M2	W289M2A	2/3/2006	J-2 RANGE	E314.0	PERCHLORATE	12.5		UG/L	59.7	69.7	2
MW-289M2	W289M2A	9/20/2006	J-2 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.1		UG/L	59.7	69.7	2
MW-289M2	W289M2A	9/20/2006	J-2 RANGE	E314.0	PERCHLORATE	7.4		UG/L	59.7	69.7	2
MW-289M2	1840	10/11/2007	J-2 RANGE	E314.0	PERCHLORATE	3.66		ug/L	59.7	69.7	2
MW-29	W29SSA	11/3/1997	J-2 RANGE	OC21B	BIS(2-ETHYLHEXYL) PHTHALATE	16		UG/L	0	10	6
MW-29	W29SSA	9/17/1999	J-2 RANGE	OC21B	BIS(2-ETHYLHEXYL) PHTHALATE	20		UG/L	0	10	6
MW-293M2	MW-293M2-	2/26/2004	J-2 RANGE	E314.0	PERCHLORATE	44		UG/L	90.22	100.22	2
MW-293M2	MW-293M2-FD	2/26/2004	J-2 RANGE	E314.0	PERCHLORATE	44		UG/L	90.22	100.22	2
MW-293M2	MW-293M2-	7/15/2004	J-2 RANGE	E314.0	PERCHLORATE	43		UG/L	90.22	100.22	2
MW-293M2	MW-293M2-	11/19/2004	J-2 RANGE	E314.0	PERCHLORATE	52		UG/L	90.22	100.22	2
MW-293M2	W293M2A	11/4/2005	J-2 RANGE	E314.0	PERCHLORATE	35.3		UG/L	90.22	100.22	2
MW-293M2	W293M2D	11/4/2005	J-2 RANGE	E314.0	PERCHLORATE	35.2		UG/L	90.22	100.22	2
MW-293M2	W293M2A	1/18/2006	J-2 RANGE	E314.0	PERCHLORATE	41.1		UG/L	90.22	100.22	2
MW-293M2	W293M2D	1/18/2006	J-2 RANGE	E314.0	PERCHLORATE	40.3		UG/L	90.22	100.22	2
MW-293M2	W293M2A	9/18/2006	J-2 RANGE	E314.0	PERCHLORATE	28.9		UG/L	90.22	100.22	2
MW-293M2	1844	10/1/2007	J-2 RANGE	E314.0	PERCHLORATE	8.38	J	ug/L	90.22	100.22	2
MW-295M1	W295M1A	1/14/2004	J-3 RANGE	E314.0	PERCHLORATE	2.1		UG/L	49.5	59.5	2
MW-295M1	W295M1D	1/14/2004	J-3 RANGE	E314.0	PERCHLORATE	2.15		UG/L	49.5	59.5	2
MW-295M1	MW-295M1	3/7/2007	J-3 RANGE	E314.0	PERCHLORATE	2.04		UG/L	49.5	59.5	2
MW-295M1	MW-295M1	9/7/2007	J-3 RANGE	E314.0	PERCHLORATE	2.64	J	UG/L	49.5	59.5	2
MW-295M1	MW-295M1_3S	2/27/2008	J-3 RANGE	E314.0	PERCHLORATE	2.4	J	UG/L	49.5	59.5	2
MW-297	W297SSA	12/23/2003	NW CORNER	E314.0	PERCHLORATE	2.53		UG/L	0.32	10.32	2
MW-297	W297SSA	3/23/2004	NW CORNER	E314.0	PERCHLORATE	2.4		UG/L	0.32	10.32	2
MW-297	W297SSA	5/25/2005	NW CORNER	E314.0	PERCHLORATE	2.2		UG/L	0.32	10.32	2
MW-297M1	W297M1A	3/23/2004	NW CORNER	E314.0	PERCHLORATE	2		UG/L	20.28	30.28	2
MW-297M1	W297M1A	4/10/2006	NW CORNER	E314.0	PERCHLORATE	2.1		UG/L	20.28	30.28	2
MW-297M1	MW-297M1-	4/25/2007	NW CORNER	E314.0	PERCHLORATE	2.6		UG/L	20.28	30.28	2
MW-297M1	MW-297M1_0508	5/13/2008	NWC [167]	E314.0	PERCHLORATE	2.3		UG/L	20.28	30.28	2
MW-3	W03DDL	3/6/1998	CIA	IM40MB	ANTIMONY	13.8	J	UG/L	219	224	6
MW-3	W03DDA	12/20/2000	CIA	IM40MB	THALLIUM	3.3		UG/L	219	224	2
MW-3	W03DDA	5/18/2001	CIA	IM40MB	ARSENIC	14.7		UG/L	219	224	10
MW-300M2	MW-300M2-	3/3/2004	J-2 RANGE	E314.0	PERCHLORATE	51		UG/L	94.38	104.38	2
MW-300M2	MW-300M2-	7/7/2004	J-2 RANGE	E314.0	PERCHLORATE	41		UG/L	94.38	104.38	2
MW-300M2	MW-300M2-FD	7/7/2004	J-2 RANGE	E314.0	PERCHLORATE	41		UG/L	94.38	104.38	2
MW-300M2	MW-300M2-	11/4/2004	J-2 RANGE	E314.0	PERCHLORATE	57		UG/L	94.38	104.38	2
MW-300M2	MW-300M2-FD	11/4/2004	J-2 RANGE	E314.0	PERCHLORATE	57		UG/L	94.38	104.38	2
MW-300M2	W300M2A	6/13/2005	J-2 RANGE	E314.0	PERCHLORATE	74		UG/L	94.38	104.38	2
MW-300M2	W300M2A	10/11/2005	J-2 RANGE	E314.0	PERCHLORATE	85.2		UG/L	94.38	104.38	2

AOC = Area of Concern  
J = Estimated Result

BWTS = Depth Below Water Table Start (feet)

BWTE = Depth Below Water Table End (feet)

DW Limit = Either the MCL or Lowest Health Advisory Limit

TABLE 4

## VALIDATED DETECTS EXCEEDING MCLs or HEALTH ADVISORY LIMITS 1997 THROUGH September 2008

LOCID/WELL ID	SAMPLE_ID	SAMPLED	AOC	METHOD	ANALYTE	CONC	FLAG	UNITS	BWTS	BWTE	DW LIMIT
MW-300M2	W300M2A	1/30/2006	J-2 RANGE	E314.0	PERCHLORATE	115		UG/L	94.38	104.38	2
MW-300M2	W300M2A	9/25/2006	J-2 RANGE	E314.0	PERCHLORATE	113		UG/L	94.38	104.38	2
MW-300M2	1851	10/10/2007	J-2 RANGE	E314.0	PERCHLORATE	60.8	J	ug/L	94.38	104.38	2
MW-300M2	MW-300M2_F08	9/9/2008	J2N [149]	E314.0	PERCHLORATE	3.48		UG/L	94.38	104.38	2
MW-300M2	MW-300M2_F08D	9/9/2008	J2N [149]	E314.0	PERCHLORATE	3.28		UG/L	94.38	104.38	2
MW-301	W301SSA	2/25/2004	NW CORNER	E314.0	PERCHLORATE	2.75		UG/L	1.32	11.32	2
MW-301	W301SSA	5/21/2004	NW CORNER	E314.0	PERCHLORATE	2.3		UG/L	1.32	11.32	2
MW-301	W301SSA	8/12/2004	NW CORNER	E314.0	PERCHLORATE	3.1		UG/L	1.32	11.32	2
MW-301	W301SSA	12/7/2005	NW CORNER	E314.0	PERCHLORATE	2		UG/L	1.32	11.32	2
MW-302	MW-302M2-	3/9/2004	J-2 RANGE	E314.0	PERCHLORATE	6.9		UG/L	85	95	2
MW-302	MW-302M2-FD	3/9/2004	J-2 RANGE	E314.0	PERCHLORATE	7		UG/L	85	95	2
MW-302	MW-302M2-	7/12/2004	J-2 RANGE	E314.0	PERCHLORATE	9.3		UG/L	85	95	2
MW-302	MW-302M2-	11/15/2004	J-2 RANGE	E314.0	PERCHLORATE	11		UG/L	85	95	2
MW-302	W302M2A	2/3/2006	J-2 RANGE	E314.0	PERCHLORATE	17.1		UG/L	85	95	2
MW-302	W302M2A	9/19/2006	J-2 RANGE	E314.0	PERCHLORATE	15		UG/L	85	95	2
MW-303M2	MW-303M2-	3/30/2004	J-1 RANGE	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	32		UG/L	122	132	2
MW-303M2	MW-303M2-	3/30/2004	J-1 RANGE	E314.0	PERCHLORATE	31		UG/L	122	132	2
MW-303M2	MW-303M2-	8/12/2004	J-1 RANGE	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	28		UG/L	122	132	2
MW-303M2	MW-303M2-	8/12/2004	J-1 RANGE	E314.0	PERCHLORATE	29		UG/L	122	132	2
MW-303M2	MW-303M2-	12/15/2004	J-1 RANGE	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	31		UG/L	122	132	2
MW-303M2	MW-303M2-	12/15/2004	J-1 RANGE	E314.0	PERCHLORATE	20		UG/L	122	132	2
MW-303M2	W303M2A	6/7/2005	J-1 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	27		UG/L	122	132	2
MW-303M2	W303M2A	6/7/2005	J-1 RANGE	E314.0	PERCHLORATE	19		UG/L	122	132	2
MW-303M2	W303M2A	8/30/2005	J-1 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	26		UG/L	122	132	2
MW-303M2	W303M2A	8/30/2005	J-1 RANGE	E314.0	PERCHLORATE	13.5		UG/L	122	132	2
MW-303M2	W303M2A	12/2/2005	J-1 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	24		UG/L	122	132	2
MW-303M2	W303M2A	12/2/2005	J-1 RANGE	E314.0	PERCHLORATE	10.1		UG/L	122	132	2
MW-303M2	W303M2A	3/15/2006	J-1 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	22		UG/L	122	132	2
MW-303M2	W303M2A	3/15/2006	J-1 RANGE	E314.0	PERCHLORATE	10.7		UG/L	122	132	2
MW-303M2	W303M2A	10/30/2006	J-1 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	15		UG/L	122	132	2
MW-303M2	W303M2A	10/30/2006	J-1 RANGE	E314.0	PERCHLORATE	5.4		UG/L	122	132	2
MW-303M2	MW-303M2-	4/19/2007	J-1 RANGE	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	14		UG/L	122	132	2
MW-303M2	MW-303M2-	4/19/2007	J-1 RANGE	E314.0	PERCHLORATE	5		UG/L	122	132	2
MW-303M2	MW-303M2-FD	4/19/2007	J-1 RANGE	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	14		UG/L	122	132	2
MW-303M2	MW-303M2-FD	4/19/2007	J-1 RANGE	E314.0	PERCHLORATE	5.5		UG/L	122	132	2
MW-303M2	MW-303M2-	10/5/2007	J-1 NORTH	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	13		ug/L	122	132.1	2
MW-303M2	MW-303M2-	10/5/2007	J-1 NORTH	E314.0	PERCHLORATE	3.3		ug/L	122	132	2
MW-303M2	MW-303M2-FD	10/5/2007	J-1 NORTH	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	12		ug/L	122	132.1	2
MW-303M2	MW-303M2-FD	10/5/2007	J-1 NORTH	E314.0	PERCHLORATE	3.6		ug/L	122	132	2
MW-303M2	MW-303M2_0508	6/4/2008	CIA [108]	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	12		UG/L	122	132.1	2
MW-303M2	MW-303M2_0508	6/4/2008	CIA [108]	SW6850	PERCHLORATE	3.8		UG/L	122	132.1	2
MW-303M2	MW-303M2_0508D	6/4/2008	CIA [108]	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	12		UG/L	122	132.1	2
MW-303M2	MW-303M2_0508D	6/4/2008	CIA [108]	SW6850	PERCHLORATE	3.8		UG/L	122	132.1	2
MW-303M3	MW-303M3-	3/25/2004	J-1 RANGE	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3		UG/L	27	37	2
MW-303M3	MW-303M3-	3/25/2004	J-1 RANGE	E314.0	PERCHLORATE	2.2		UG/L	27	37	2
MW-303M3	MW-303M3_0508	6/5/2008	CIA [108]	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.4		UG/L	27	37	2
MW-305	MW-305M1-	3/9/2004	J-2 RANGE	E314.0	PERCHLORATE	36		UG/L	99.82	109.82	2

AOC = Area of Concern  
J = Estimated Result

BWTS = Depth Below Water Table Start (feet)

BWTE = Depth Below Water Table End (feet)

DW Limit = Either the MCL or Lowest Health Advisory Limit

TABLE 4

## VALIDATED DETECTS EXCEEDING MCLs or HEALTH ADVISORY LIMITS 1997 THROUGH September 2008

LOCID/WELL ID	SAMPLE_ID	SAMPLED	AOC	METHOD	ANALYTE	CONC	FLAG	UNITS	BWTS	BWTE	DW LIMIT
MW-305	MW-305M1-	7/6/2004	J-2 RANGE	E314.0	PERCHLORATE	34		UG/L	99.82	109.82	2
MW-305	MW-305M1-	11/3/2004	J-2 RANGE	E314.0	PERCHLORATE	34		UG/L	99.82	109.82	2
MW-305	W305M1A	6/17/2005	J-2 RANGE	E314.0	PERCHLORATE	26		UG/L	99.82	109.82	2
MW-305	W305M1D	6/17/2005	J-2 RANGE	E314.0	PERCHLORATE	26		UG/L	99.82	109.82	2
MW-305	W305M1A	11/4/2005	J-2 RANGE	E314.0	PERCHLORATE	24.9		UG/L	99.82	109.82	2
MW-305	W305M1A	1/18/2006	J-2 RANGE	E314.0	PERCHLORATE	27.3		UG/L	99.82	109.82	2
MW-305	W305M1D	1/18/2006	J-2 RANGE	E314.0	PERCHLORATE	27.9		UG/L	99.82	109.82	2
MW-305	W305M1A	10/2/2006	J-2 RANGE	E314.0	PERCHLORATE	21.7		UG/L	99.82	109.82	2
MW-306	MW-306M1-	4/1/2004	J-1 RANGE	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.1		UG/L	61	71	2
MW-306	MW-306M2-	4/1/2004	J-1 RANGE	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	8.3		UG/L	41	51	2
MW-306	MW-306M2-	8/13/2004	J-1 RANGE	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5.2		UG/L	41	51	2
MW-306	MW-306M2-FD	8/13/2004	J-1 RANGE	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5.5		UG/L	41	51	2
MW-306	MW-306M1-	12/14/2004	J-1 RANGE	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.4		UG/L	61	71	2
MW-306	MW-306M2-	12/14/2004	J-1 RANGE	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5.1		UG/L	41	51	2
MW-306	W306M1A	6/15/2005	J-1 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.2		UG/L	61	71	2
MW-306	W306M2A	6/16/2005	J-1 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.3		UG/L	41	51	2
MW-306	W306M1A	10/25/2005	J-1 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.3	J	UG/L	61	71	2
MW-306	W306M1A	1/26/2006	J-1 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.2		UG/L	61	71	2
MW-306	W306M1A	3/20/2006	J-1 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4		UG/L	61	71	2
MW-306	MW-306M1-	4/19/2007	J-1 RANGE	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.8		UG/L	61	71	2
MW-307M3	MW-307M3-	4/27/2004	J-2 RANGE	E314.0	PERCHLORATE	24		UG/L	17.8	27.82	2
MW-307M3	MW-307M3-	10/25/2004	J-2 RANGE	E314.0	PERCHLORATE	24		UG/L	17.8	27.82	2
MW-307M3	MW-307M3-	2/22/2005	J-2 RANGE	E314.0	PERCHLORATE	21		UG/L	17.8	27.82	2
MW-307M3	W307M3A	10/19/2005	J-2 RANGE	E314.0	PERCHLORATE	12.8		UG/L	17.8	27.82	2
MW-307M3	W307M3A	1/30/2006	J-2 RANGE	E314.0	PERCHLORATE	10.1		UG/L	17.8	27.82	2
MW-307M3	W307M3A	3/27/2006	J-2 RANGE	E314.0	PERCHLORATE	12		UG/L	17.8	27.82	2
MW-307M3	W307M3D	3/27/2006	J-2 RANGE	E314.0	PERCHLORATE	11.9		UG/L	17.8	27.82	2
MW-307M3	W307M3A	9/28/2006	J-2 RANGE	E314.0	PERCHLORATE	14.9		UG/L	17.8	27.82	2
MW-307M3	MW-307M3-	4/11/2007	J-2 RANGE	E314.0	PERCHLORATE	25.3		UG/L	17.8	27.82	2
MW-307M3	MW-307M3-FD	4/11/2007	J-2 RANGE	E314.0	PERCHLORATE	25		UG/L	17.8	27.82	2
MW-307M3	MW-307M3_0408	4/14/2008	J-2 RANGE East	E314.0	PERCHLORATE	19.4		UG/L	17.8	27.82	2
MW-307M3	MW-307M3_0408D	4/14/2008	J-2 RANGE East	E314.0	PERCHLORATE	18.9		UG/L	17.8	27.82	2
MW-309	W309M1A	9/15/2004	NW CORNER	E314.0	PERCHLORATE	3.72		UG/L	31.91	41.91	2
MW-309	W309M1A	6/10/2005	NW CORNER	E314.0	PERCHLORATE	4.2		UG/L	31.91	41.91	2
MW-309	W309SSA	6/10/2005	NW CORNER	E314.0	PERCHLORATE	3.7		UG/L	0	10	2
MW-309	W309M1A	8/25/2005	NW CORNER	E314.0	PERCHLORATE	4.1		UG/L	31.91	41.91	2
MW-309	W309SSA	8/25/2005	NW CORNER	E314.0	PERCHLORATE	3.9		UG/L	0	10	2
MW-309	W309M1A	12/13/2005	NW CORNER	E314.0	PERCHLORATE	3		UG/L	31.91	41.91	2
MW-309	W309SSA	12/13/2005	NW CORNER	E314.0	PERCHLORATE	3.4		UG/L	0	10	2
MW-309	W309M1A	3/27/2006	NW CORNER	E314.0	PERCHLORATE	2.6		UG/L	31.91	41.91	2
MW-309	W309SSA	3/27/2006	NW CORNER	E314.0	PERCHLORATE	2.6		UG/L	0	10	2
MW-309	W309SSA	10/9/2006	NW CORNER	E314.0	PERCHLORATE	2.1		UG/L	0	10	2
MW-309	MW-309M1-FD	4/25/2007	NW CORNER	E314.0	PERCHLORATE	2.5	J	UG/L	31.91	41.91	2
MW-310M1	MW-310M1-	4/23/2004	J-2 RANGE	E314.0	PERCHLORATE	16		UG/L	86	96	2
MW-310M1	MW-310M1-	8/23/2004	J-2 RANGE	E314.0	PERCHLORATE	15		UG/L	86	96	2
MW-310M1	MW-310M1-	12/20/2004	J-2 RANGE	E314.0	PERCHLORATE	17		UG/L	86	96	2
MW-310M1	MW-310M1-FD	12/20/2004	J-2 RANGE	E314.0	PERCHLORATE	18		UG/L	86	96	2

AOC = Area of Concern  
J = Estimated Result

BWTS = Depth Below Water Table Start (feet)

BWTE = Depth Below Water Table End (feet)

DW Limit = Either the MCL or Lowest Health Advisory Limit

TABLE 4

## VALIDATED DETECTS EXCEEDING MCLs or HEALTH ADVISORY LIMITS 1997 THROUGH September 2008

LOCID/WELL ID	SAMPLE_ID	SAMPLED	AOC	METHOD	ANALYTE	CONC	FLAG	UNITS	BWTS	BWTE	DW LIMIT
MW-310M1	W310M1A	6/16/2005	J-2 RANGE	E314.0	PERCHLORATE	13		UG/L	86	96	2
MW-310M1	W310M1A	11/7/2005	J-2 RANGE	E314.0	PERCHLORATE	9.4		UG/L	86	96	2
MW-310M1	W310M1A	1/31/2006	J-2 RANGE	E314.0	PERCHLORATE	7.3		UG/L	86	96	2
MW-310M1	W310M1A	4/3/2006	J-2 RANGE	E314.0	PERCHLORATE	4.9		UG/L	86	96	2
MW-310M1	W310M1A	9/28/2006	J-2 RANGE	E314.0	PERCHLORATE	8.5		UG/L	86	96	2
MW-310M1	W310M1D	9/28/2006	J-2 RANGE	E314.0	PERCHLORATE	8.4		UG/L	86	96	2
MW-310M1	MW-310M1-	4/10/2007	J-2 RANGE	E314.0	PERCHLORATE	8.6		UG/L	86	96	2
MW-310M1	MW-310M1_0408	4/11/2008	J-2 RANGE East	E314.0	PERCHLORATE	17.4		UG/L	86	96	2
MW-313M2	MW-313M2-	6/29/2004	J-2 RANGE	E314.0	PERCHLORATE	8.2		UG/L	93	103	2
MW-313M2	MW-313M2-	10/25/2004	J-2 RANGE	E314.0	PERCHLORATE	9.1		UG/L	93	103	2
MW-313M2	MW-313M2-	2/23/2005	J-2 RANGE	E314.0	PERCHLORATE	7.7		UG/L	93	103	2
MW-313M2	MW-313M2-FD	2/23/2005	J-2 RANGE	E314.0	PERCHLORATE	7.6		UG/L	93	103	2
MW-313M2	W313M2A	10/27/2005	J-2 RANGE	E314.0	PERCHLORATE	3.5		UG/L	93	103	2
MW-313M2	W313M2A	2/3/2006	J-2 RANGE	E314.0	PERCHLORATE	4.1		UG/L	93	103	2
MW-313M2	W313M2A	3/8/2006	J-2 RANGE	E314.0	PERCHLORATE	5		UG/L	93	103	2
MW-313M2	W313M2A	9/21/2006	J-2 RANGE	E314.0	PERCHLORATE	7.5		UG/L	93	103	2
MW-313M2	MW-313M2	3/20/2007	J-2 RANGE	E314.0	PERCHLORATE	3.92		UG/L	93	103	2
MW-313M2	1857	10/5/2007	J-2 RANGE	E314.0	PERCHLORATE	5.72	J	ug/L	93	103	2
MW-313M2	MW-313M2_3S	3/7/2008	J-3 RANGE	E314.0	PERCHLORATE	3.82		UG/L	93	103	2
MW-313M2	MW-313M2_3SD	3/7/2008	J-3 RANGE	E314.0	PERCHLORATE	3.38		UG/L	93	103	2
MW-319	MW-319M2-	5/11/2004	J-2 RANGE	E314.0	PERCHLORATE	2.6		UG/L	72	82	2
MW-319	MW-319M1-	5/24/2004	J-2 RANGE	E314.0	PERCHLORATE	2.8		UG/L	107.25	117.25	2
MW-319	MW-319M1-	9/14/2004	J-2 RANGE	E314.0	PERCHLORATE	2.8		UG/L	107.25	117.25	2
MW-319	MW-319M2-	9/14/2004	J-2 RANGE	E314.0	PERCHLORATE	3.7		UG/L	72	82	2
MW-319	MW-319M2-FD	9/14/2004	J-2 RANGE	E314.0	PERCHLORATE	3.7		UG/L	72	82	2
MW-319	MW-319M1-	1/19/2005	J-2 RANGE	E314.0	PERCHLORATE	2.3		UG/L	107.25	117.25	2
MW-319	MW-319M2-	1/19/2005	J-2 RANGE	E314.0	PERCHLORATE	3.2		UG/L	72	82	2
MW-319	W319M2A	10/12/2005	J-2 RANGE	E314.0	PERCHLORATE	3.2		UG/L	72	82	2
MW-319	W319M2A	2/1/2006	J-2 RANGE	E314.0	PERCHLORATE	2.5		UG/L	72	82	2
MW-319	W319M2A	3/30/2006	J-2 RANGE	E314.0	PERCHLORATE	3		UG/L	72	82	2
MW-319	W319M2D	3/30/2006	J-2 RANGE	E314.0	PERCHLORATE	2.9		UG/L	72	82	2
MW-319	MW-319M2-	4/11/2007	J-2 RANGE	E314.0	PERCHLORATE	3.5		UG/L	72	82	2
MW-31D	W31DDA	8/9/2000	DEMO 1	8330	2,4,6-TRINITROTOLUENE	3.9	J	UG/L	48	53	2
MW-31D	W31DDA	8/9/2000	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	150		UG/L	48	53	2
MW-31M	W31MMA	7/15/1998	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	280		UG/L	28	38	2
MW-31M	W31MMA	2/2/1999	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	370		UG/L	28	38	2
MW-31M	W31MMA	9/15/1999	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	29		UG/L	28	38	2
MW-31M	W31M1A	5/15/2000	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	19		UG/L	28	38	2
MW-31M	W31M1A	8/9/2000	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	14		UG/L	28	38	2
MW-31M	W31M1A	8/9/2000	DEMO 1	E314.0	PERCHLORATE	46	J	UG/L	28	38	2
MW-31M	W31MMA	5/23/2001	DEMO 1	8330	2,4,6-TRINITROTOLUENE	5.2		UG/L	28	38	2
MW-31M	W31MMA	5/23/2001	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	70		UG/L	28	38	2
MW-31M	W31MMA	5/23/2001	DEMO 1	E314.0	PERCHLORATE	19		UG/L	28	38	2
MW-31M	W31MMA	4/22/2002	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	7.4		UG/L	28	38	2
MW-31M	W31MMA	4/22/2002	DEMO 1	E314.0	PERCHLORATE	2.98	J	UG/L	28	38	2
MW-31M	W31MMD	4/22/2002	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	7.2		UG/L	28	38	2
MW-31M	W31MMD	4/22/2002	DEMO 1	E314.0	PERCHLORATE	3.04	J	UG/L	28	38	2

AOC = Area of Concern  
J = Estimated Result

BWTS = Depth Below Water Table Start (feet)

BWTE = Depth Below Water Table End (feet)

DW Limit = Either the MCL or Lowest Health Advisory Limit

TABLE 4

## VALIDATED DETECTS EXCEEDING MCLs or HEALTH ADVISORY LIMITS 1997 THROUGH September 2008

LOCID/WELL ID	SAMPLE_ID	SAMPLED	AOC	METHOD	ANALYTE	CONC	FLAG	UNITS	BWTS	BWTE	DW LIMIT
MW-31M	W31MMA	8/7/2002	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	7.8		UG/L	28	38	2
MW-31M	W31MMA	8/7/2002	DEMO 1	E314.0	PERCHLORATE	10	J	UG/L	28	38	2
MW-31M	W31MMA	11/15/2002	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.6		UG/L	28	38	2
MW-31M	W31MMA	11/15/2002	DEMO 1	E314.0	PERCHLORATE	5.2		UG/L	28	38	2
MW-31M	W31MMA	3/27/2003	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	8.1		UG/L	28	38	2
MW-31M	W31MMA	9/27/2003	DEMO 1	E314.0	PERCHLORATE	2.9		UG/L	28	38	2
MW-31M	W31MMA	5/11/2004	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2		UG/L	28	38	2
MW-31M	W31MMA	10/27/2004	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	50	J	UG/L	28	38	2
MW-31M	W31MMA	10/27/2004	DEMO 1	E314.0	PERCHLORATE	7.44	J	UG/L	28	38	2
MW-31M	W31MMA	4/30/2005	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	120		UG/L	28	38	2
MW-31M	W31MMA	4/30/2005	DEMO 1	E314.0	PERCHLORATE	16		UG/L	28	38	2
MW-31M	MW-31M-	4/13/2006	DEMO 1	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	26		UG/L	28	38	2
MW-31M	MW-31M-	4/13/2006	DEMO 1	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	27	J	UG/L	28	38	2
MW-31M	MW-31M-	4/13/2006	DEMO 1	E314.0	PERCHLORATE	2.68		UG/L	28	38	2
MW-31M	MW-31M	4/26/2007	DEMO 1	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	25.9		UG/L	28	38	2
MW-31M	1924	12/7/2007	DEMO 1	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	11.6	J	UG/L	113	123	2
MW-31M	1956	4/24/2008	DEMO 1	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	21.2		UG/L	113	123	2
MW-31S	W31SSA	7/15/1998	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	64		UG/L	13	18	2
MW-31S	W31SSA	2/1/1999	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	210		UG/L	13	18	2
MW-31S	W31SSA	9/15/1999	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	50		UG/L	13	18	2
MW-31S	W31SSA	5/15/2000	DEMO 1	8330	2,4,6-TRINITROTOLUENE	3.3		UG/L	13	18	2
MW-31S	W31SSA	5/15/2000	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	110		UG/L	13	18	2
MW-31S	W31SSA	8/9/2000	DEMO 1	8330	2,4,6-TRINITROTOLUENE	3.9	J	UG/L	13	18	2
MW-31S	W31SSA	8/9/2000	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	140		UG/L	13	18	2
MW-31S	W31SSA	8/9/2000	DEMO 1	E314.0	PERCHLORATE	43	J	UG/L	13	18	2
MW-31S	W31SSA	12/8/2000	DEMO 1	8330	2,4,6-TRINITROTOLUENE	5.2	J	UG/L	13	18	2
MW-31S	W31SSA	12/8/2000	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	120		UG/L	13	18	2
MW-31S	W31SSA	12/8/2000	DEMO 1	E314.0	PERCHLORATE	30		UG/L	13	18	2
MW-31S	W31SSA	5/2/2001	DEMO 1	8330	2,4,6-TRINITROTOLUENE	5.2		UG/L	13	18	2
MW-31S	W31SSA	5/2/2001	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	81		UG/L	13	18	2
MW-31S	W31SSA	5/2/2001	DEMO 1	E314.0	PERCHLORATE	20	J	UG/L	13	18	2
MW-31S	W31SSA	8/24/2001	DEMO 1	8330	2,4,6-TRINITROTOLUENE	5.4		UG/L	13	18	2
MW-31S	W31SSA	8/24/2001	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	88		UG/L	13	18	2
MW-31S	W31SSA	8/24/2001	DEMO 1	E314.0	PERCHLORATE	16.2		UG/L	13	18	2
MW-31S	W31SSA	1/4/2002	DEMO 1	8330	2,4,6-TRINITROTOLUENE	5.9		UG/L	13	18	2
MW-31S	W31SSA	1/4/2002	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	31		UG/L	13	18	2
MW-31S	W31SSA	1/4/2002	DEMO 1	E314.0	PERCHLORATE	12.5		UG/L	13	18	2
MW-31S	W31SSA	5/29/2002	DEMO 1	8330	2,4,6-TRINITROTOLUENE	5.5		UG/L	13	18	2
MW-31S	W31SSA	5/29/2002	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	130		UG/L	13	18	2
MW-31S	W31SSA	5/29/2002	DEMO 1	E314.0	PERCHLORATE	12		UG/L	13	18	2
MW-31S	W31SSA	8/7/2002	DEMO 1	8330	2,4,6-TRINITROTOLUENE	5.9		UG/L	13	18	2
MW-31S	W31SSA	8/7/2002	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	85		UG/L	13	18	2
MW-31S	W31SSA	8/7/2002	DEMO 1	E314.0	PERCHLORATE	7.2	J	UG/L	13	18	2
MW-31S	W31SSA	11/15/2002	DEMO 1	8330	2,4,6-TRINITROTOLUENE	5.5		UG/L	13	18	2
MW-31S	W31SSA	11/15/2002	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	11		UG/L	13	18	2
MW-31S	W31SSA	11/15/2002	DEMO 1	E314.0	PERCHLORATE	4.9		UG/L	13	18	2
MW-31S	W31SSA	3/28/2003	DEMO 1	8330	2,4,6-TRINITROTOLUENE	5.2		UG/L	13	18	2

AOC = Area of Concern  
J = Estimated Result

BWTS = Depth Below Water Table Start (feet)  
BWTE = Depth Below Water Table End (feet)  
DW Limit = Either the MCL or Lowest Health Advisory Limit

TABLE 4

## VALIDATED DETECTS EXCEEDING MCLs or HEALTH ADVISORY LIMITS 1997 THROUGH September 2008

LOCID/WELL ID	SAMPLE_ID	SAMPLED	AOC	METHOD	ANALYTE	CONC	FLAG	UNITS	BWTS	BWTE	DW LIMIT
MW-31S	W31SSA	3/28/2003	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	86		UG/L	13	18	2
MW-31S	W31SSA	3/28/2003	DEMO 1	E314.0	PERCHLORATE	10		UG/L	13	18	2
MW-31S	W31SSA	9/27/2003	DEMO 1	8330	2,4,6-TRINITROTOLUENE	5.2	J	UG/L	13	18	2
MW-31S	W31SSA	9/27/2003	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	63		UG/L	13	18	2
MW-31S	W31SSA	9/27/2003	DEMO 1	E314.0	PERCHLORATE	4.6		UG/L	13	18	2
MW-31S	W31SSD	9/27/2003	DEMO 1	8330	2,4,6-TRINITROTOLUENE	5.2	J	UG/L	13	18	2
MW-31S	W31SSD	9/27/2003	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	62		UG/L	13	18	2
MW-31S	W31SSD	9/27/2003	DEMO 1	E314.0	PERCHLORATE	5.3		UG/L	13	18	2
MW-31S	W31SSA	2/28/2004	DEMO 1	8330	2,4,6-TRINITROTOLUENE	5.7		UG/L	13	18	2
MW-31S	W31SSA	2/28/2004	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	21		UG/L	13	18	2
MW-31S	W31SSA	2/28/2004	DEMO 1	E314.0	PERCHLORATE	7.77	J	UG/L	13	18	2
MW-31S	W31SSA	5/11/2004	DEMO 1	8330	2,4,6-TRINITROTOLUENE	6.2		UG/L	13	18	2
MW-31S	W31SSA	5/11/2004	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	72		UG/L	13	18	2
MW-31S	W31SSA	5/11/2004	DEMO 1	E314.0	PERCHLORATE	5.02		UG/L	13	18	2
MW-31S	W31SSA	10/27/2004	DEMO 1	8330	2,4,6-TRINITROTOLUENE	6.3		UG/L	13	18	2
MW-31S	W31SSA	10/27/2004	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	13	J	UG/L	13	18	2
MW-31S	W31SSA	10/27/2004	DEMO 1	E314.0	PERCHLORATE	4.7	J	UG/L	13	18	2
MW-31S	W31SSA	4/30/2005	DEMO 1	8330	2,4,6-TRINITROTOLUENE	5.9		UG/L	13	18	2
MW-31S	W31SSA	4/30/2005	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	61		UG/L	13	18	2
MW-31S	W31SSA	4/30/2005	DEMO 1	E314.0	PERCHLORATE	4.6		UG/L	13	18	2
MW-31S	MW-31S-	4/13/2006	DEMO 1	SW8330	2,4,6-TRINITROTOLUENE	4.8		UG/L	13	18	2
MW-31S	MW-31S-	4/13/2006	DEMO 1	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	27	J	UG/L	13	18	2
MW-31S	MW-31S-	4/13/2006	DEMO 1	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	28		UG/L	13	18	2
MW-31S	MW-31S	4/26/2007	DEMO 1	SW8330	2,4,6-TRINITROTOLUENE	2.84		UG/L	13	18	2
MW-31S	MW-31S	4/26/2007	DEMO 1	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	6.3		UG/L	13	18	2
MW-31S	1925	12/7/2007		SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	28.2		UG/L	98	103	2
MW-31S	1957	4/24/2008	DEMO 1	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	12.7		UG/L	98	103	2
MW-32	W32MMA	1/29/2003	DEMO 1	E314.0	PERCHLORATE	2.3		UG/L	65	75	2
MW-32	W32MMD	1/29/2003	DEMO 1	E314.0	PERCHLORATE	2.3		UG/L	65	75	2
MW-32	W32SSA	1/29/2003	DEMO 1	E314.0	PERCHLORATE	2.1		UG/L	50	55	2
MW-32	W32MMA	3/31/2003	DEMO 1	E314.0	PERCHLORATE	2.5		UG/L	65	75	2
MW-32	W32DDA	11/18/2003	DEMO 1	E314.0	PERCHLORATE	2.2	J	UG/L	85	90	2
MW-32	W32MMA	11/18/2003	DEMO 1	E314.0	PERCHLORATE	2.6	J	UG/L	65	75	2
MW-32	W32MMD	11/18/2003	DEMO 1	E314.0	PERCHLORATE	2.8	J	UG/L	65	75	2
MW-32	W32SSA	11/18/2003	DEMO 1	E314.0	PERCHLORATE	2	J	UG/L	50	55	2
MW-32	W32MMA	3/4/2004	DEMO 1	E314.0	PERCHLORATE	3.93		UG/L	65	75	2
MW-32	W32DDA	3/10/2004	DEMO 1	E314.0	PERCHLORATE	2.2	J	UG/L	85	90	2
MW-32	W32DDA	4/21/2004	DEMO 1	E314.0	PERCHLORATE	2.35		UG/L	85	90	2
MW-32	W32MMA	4/21/2004	DEMO 1	E314.0	PERCHLORATE	4.14		UG/L	65	75	2
MW-32	W32DDA	8/3/2004	DEMO 1	E314.0	PERCHLORATE	4.78		UG/L	85	90	2
MW-32	W32MMA	8/4/2004	DEMO 1	E314.0	PERCHLORATE	4.21		UG/L	65	75	2
MW-32	W32MMD	8/4/2004	DEMO 1	E314.0	PERCHLORATE	4.03		UG/L	65	75	2
MW-321	MW-321M1-	6/14/2004	J-2 RANGE	E314.0	PERCHLORATE	3.5		UG/L	70	80	2
MW-321	MW-321M1-	10/14/2004	J-2 RANGE	E314.0	PERCHLORATE	4.5		UG/L	70	80	2
MW-321	MW-321M1-	2/11/2005	J-2 RANGE	E314.0	PERCHLORATE	5.2		UG/L	70	80	2
MW-321	W321M1A	11/22/2005	J-2 RANGE	E314.0	PERCHLORATE	2.8		UG/L	70	80	2
MW-321	W321M1A	1/31/2006	J-2 RANGE	E314.0	PERCHLORATE	2.1		UG/L	70	80	2

AOC = Area of Concern

J = Estimated Result

BWTS = Depth Below Water Table Start (feet)

BWTE = Depth Below Water Table End (feet)

DW Limit = Either the MCL or Lowest Health Advisory Limit

TABLE 4

## VALIDATED DETECTS EXCEEDING MCLs or HEALTH ADVISORY LIMITS 1997 THROUGH September 2008

LOCID/WELL ID	SAMPLE_ID	SAMPLED	AOC	METHOD	ANALYTE	CONC	FLAG	UNITS	BWTS	BWTE	DW LIMIT
MW-322M1	MW-322M1_3S	3/6/2008	J2N [149]	E314.0	PERCHLORATE	2.94		UG/L	245	255	2
MW-322M1	MW-322M1_3SD	3/6/2008	J2N [149]	E314.0	PERCHLORATE	3.06		UG/L	245	255	2
MW-322M1	MW-322M1_F08	9/11/2008	J2N [149]	E314.0	PERCHLORATE	2.5		UG/L	245	255	2
MW-323	W323SSA	4/19/2004	NW CORNER	E314.0	PERCHLORATE	3.14		UG/L	73	83	2
MW-323	W323SSA	7/27/2004	NW CORNER	E314.0	PERCHLORATE	2.78		UG/L	73	83	2
MW-323	W323SSA	6/15/2005	NW CORNER	E314.0	PERCHLORATE	3.6		UG/L	73	83	2
MW-323	W323SSA	7/20/2005	NW CORNER	E314.0	PERCHLORATE	3		UG/L	73	83	2
MW-323M2	W323M2A	4/19/2004	NW CORNER	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5.7		UG/L	46.05	56.05	2
MW-323M2	W323M2A	7/27/2004	NW CORNER	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	6.5		UG/L	46.05	56.05	2
MW-323M2	W323M2D	7/27/2004	NW CORNER	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	6.6		UG/L	46.05	56.05	2
MW-323M2	W323M2A	10/8/2004	NW CORNER	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	9.6		UG/L	46.05	56.05	2
MW-323M2	W323M2A	6/15/2005	NW CORNER	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	9.5		UG/L	46.05	56.05	2
MW-323M2	W323M2A	7/20/2005	NW CORNER	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	8.4		UG/L	46.05	56.05	2
MW-323M2	W323M2A	12/7/2005	NW CORNER	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	7.6		UG/L	46.05	56.05	2
MW-323M2	W323M2A	4/12/2006	NW CORNER	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.6		UG/L	46.05	56.05	2
MW-323M2	MW-323M2-	4/23/2007	NW CORNER	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	6.9		UG/L	46.05	56.05	2
MW-323M2	MW-323M2-FD	4/23/2007	NW CORNER	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	7.1		UG/L	46.05	56.05	2
MW-323M2	MW-323M2_0508	5/7/2008	NWC [167]	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5.6		UG/L	46.05	56.05	2
MW-324	MW-324M2-	7/7/2004	J-2 RANGE	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.7		UG/L	82	92	2
MW-324	MW-324M1-	10/20/2004	J-2 RANGE	E314.0	PERCHLORATE	2.2		UG/L	111.85	121.85	2
MW-324	MW-324M1-FD	10/20/2004	J-2 RANGE	E314.0	PERCHLORATE	2.3		UG/L	111.85	121.85	2
MW-324	MW-324M2-	10/20/2004	J-2 RANGE	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2		UG/L	82	92	2
MW-324	MW-324M1-	2/23/2005	J-2 RANGE	E314.0	PERCHLORATE	2.2		UG/L	111.85	121.85	2
MW-326M2	MW-326M2-	6/30/2004	J-1 RANGE	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.1		UG/L	75	85	2
MW-326M2	MW-326M2-	6/30/2004	J-1 RANGE	E314.0	PERCHLORATE	21		UG/L	75	85	2
MW-326M2	MW-326M2-	10/29/2004	J-1 RANGE	E314.0	PERCHLORATE	18		UG/L	75	85	2
MW-326M2	MW-326M2-	4/11/2005	J-1 RANGE	E314.0	PERCHLORATE	16		UG/L	75	85	2
MW-326M2	W326M2A	11/18/2005	J-1 RANGE	E314.0	PERCHLORATE	12.4		UG/L	75	85	2
MW-326M2	W326M2A	1/27/2006	J-1 RANGE	E314.0	PERCHLORATE	12.3		UG/L	75	85	2
MW-326M2	W326M2A	3/22/2006	J-1 RANGE	E314.0	PERCHLORATE	12.5	J	UG/L	75	85	2
MW-326M2	MW-326M2-	4/18/2007	J-1 RANGE	E314.0	PERCHLORATE	10.1		UG/L	75	85	2
MW-326M2	MW-326M2_0508	6/16/2008	CIA [108]	E314.0	PERCHLORATE	8.3		UG/L	75	85	2
MW-326M3	MW-326M3-	4/18/2007	J-1 RANGE	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.8		UG/L	44	54	2
MW-326M3	MW-326M3_0508	6/18/2008	CIA [108]	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	6.2		UG/L	165	175	2
MW-329	MW-329M2-	4/7/2005	J-3 RANGE	E314.0	PERCHLORATE	2.1		UG/L	124.75	134.75	2
MW-33	W33DDA	4/23/2002	DEMO 1	E314.0	PERCHLORATE	2.02		UG/L	85	90	2
MW-33	W33DDA	8/8/2002	DEMO 1	E314.0	PERCHLORATE	2	J	UG/L	85	90	2
MW-33	W33MMA	8/8/2002	DEMO 1	E314.0	PERCHLORATE	2.1	J	UG/L	65	75	2
MW-33	W33DDA	11/15/2002	DEMO 1	E314.0	PERCHLORATE	2.2		UG/L	85	90	2
MW-33	W33DDD	11/15/2002	DEMO 1	E314.0	PERCHLORATE	2.2		UG/L	85	90	2
MW-33	W33DDA	2/6/2003	DEMO 1	E314.0	PERCHLORATE	3		UG/L	85	90	2
MW-33	MW-33D-	4/14/2006	DEMO 1	E314.0	PERCHLORATE	2.02		UG/L	85	90	2
MW-335M1	MW-335M1-	4/9/2007	J-2 RANGE	E314.0	PERCHLORATE	5.5		UG/L	145.2	155.2	2
MW-335M1	MW-335M1_0408	4/28/2008	J2E [190]	E314.0	PERCHLORATE	18.3		UG/L	145.2	155.2	2
MW-339M1	MW-339M1-	8/20/2004	J-2 RANGE	E314.0	PERCHLORATE	5.6		UG/L	125	135	2
MW-339M1	MW-339M1-	12/20/2004	J-2 RANGE	E314.0	PERCHLORATE	5.2		UG/L	125	135	2
MW-339M1	MW-339M1-	4/18/2005	J-2 RANGE	E314.0	PERCHLORATE	3.5		UG/L	125	135	2

AOC = Area of Concern

J = Estimated Result

BWTS = Depth Below Water Table Start (feet)

BWTE = Depth Below Water Table End (feet)

DW Limit = Either the MCL or Lowest Health Advisory Limit

TABLE 4

## VALIDATED DETECTS EXCEEDING MCLs or HEALTH ADVISORY LIMITS 1997 THROUGH September 2008

LOCID/WELL ID	SAMPLE_ID	SAMPLED	AOC	METHOD	ANALYTE	CONC	FLAG	UNITS	BWTS	BWTE	DW LIMIT
MW-339M1	W339M1A	11/7/2005	J-2 RANGE	E314.0	PERCHLORATE	3.6		UG/L	125	135	2
MW-339M1	W339M1D	11/7/2005	J-2 RANGE	E314.0	PERCHLORATE	2.8		UG/L	125	135	2
MW-339M1	W339M1A	1/31/2006	J-2 RANGE	E314.0	PERCHLORATE	2.7		UG/L	125	135	2
MW-339M1	W339M1A	4/4/2006	J-2 RANGE	E314.0	PERCHLORATE	2.8		UG/L	125	135	2
MW-339M1	MW-339M1-	4/11/2007	J-2 RANGE	E314.0	PERCHLORATE	3.6		UG/L	125	135	2
MW-339M1	MW-339M1_0408	5/1/2008	FKRNG [123]	E314.0	PERCHLORATE	3.4		UG/L	125	135	2
MW-34	W34M2A	2/19/1999	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	6.2		UG/L	53	63	2
MW-34	W34M2A	8/16/1999	DEMO 1	IM40MB	ANTIMONY	6.6	J	UG/L	53	63	6
MW-34	W34M1A	5/17/2000	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.2		UG/L	73	83	2
MW-34	W34M2A	5/18/2000	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.7		UG/L	53	63	2
MW-34	W34M2A	8/10/2000	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.1		UG/L	53	63	2
MW-34	W34M2A	8/10/2000	DEMO 1	E314.0	PERCHLORATE	56	J	UG/L	53	63	2
MW-34	W34M1A	8/11/2000	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5		UG/L	73	83	2
MW-34	W34M1A	11/17/2000	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.5		UG/L	73	83	2
MW-34	W34M2A	11/17/2000	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.5		UG/L	53	63	2
MW-34	W34M1A	12/18/2000	DEMO 1	E314.0	PERCHLORATE	109		UG/L	73	83	2
MW-34	W34M2A	12/18/2000	DEMO 1	E314.0	PERCHLORATE	34		UG/L	53	63	2
MW-34	W34M2A	5/1/2001	DEMO 1	E314.0	PERCHLORATE	28	J	UG/L	53	63	2
MW-34	W34M1A	5/5/2001	DEMO 1	E314.0	PERCHLORATE	46		UG/L	73	83	2
MW-34	W34M2A	7/30/2001	DEMO 1	E314.0	PERCHLORATE	16.2		UG/L	53	63	2
MW-34	W34M1A	7/31/2001	DEMO 1	E314.0	PERCHLORATE	30.8		UG/L	73	83	2
MW-34	W34M1D	7/31/2001	DEMO 1	E314.0	PERCHLORATE	31.4		UG/L	73	83	2
MW-34	W34M1A	12/26/2001	DEMO 1	E314.0	PERCHLORATE	17.7		UG/L	73	83	2
MW-34	W34M2A	12/26/2001	DEMO 1	E314.0	PERCHLORATE	5.85	J	UG/L	53	63	2
MW-34	W34M1A	4/24/2002	DEMO 1	E314.0	PERCHLORATE	7.9		UG/L	73	83	2
MW-34	W34M2A	4/24/2002	DEMO 1	E314.0	PERCHLORATE	19.6		UG/L	53	63	2
MW-34	W34M1A	8/20/2002	DEMO 1	E314.0	PERCHLORATE	7.1	J	UG/L	73	83	2
MW-34	W34M1D	8/20/2002	DEMO 1	E314.0	PERCHLORATE	7.3		UG/L	73	83	2
MW-34	W34M2A	8/20/2002	DEMO 1	E314.0	PERCHLORATE	17		UG/L	53	63	2
MW-34	W34M1A	11/15/2002	DEMO 1	E314.0	PERCHLORATE	8		UG/L	73	83	2
MW-34	W34M2A	11/15/2002	DEMO 1	E314.0	PERCHLORATE	14		UG/L	53	63	2
MW-34	W34M1A	3/24/2003	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.3		UG/L	73	83	2
MW-34	W34M1A	3/24/2003	DEMO 1	E314.0	PERCHLORATE	8	J	UG/L	73	83	2
MW-34	W34M2A	3/24/2003	DEMO 1	E314.0	PERCHLORATE	10	J	UG/L	53	63	2
MW-34	W34M1A	11/12/2003	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.9		UG/L	73	83	2
MW-34	W34M1A	11/12/2003	DEMO 1	E314.0	PERCHLORATE	6.9		UG/L	73	83	2
MW-34	W34M2A	11/12/2003	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.9		UG/L	53	63	2
MW-34	W34M2A	11/12/2003	DEMO 1	E314.0	PERCHLORATE	7.3		UG/L	53	63	2
MW-34	W34M1A	3/5/2004	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.6		UG/L	73	83	2
MW-34	W34M1A	3/5/2004	DEMO 1	E314.0	PERCHLORATE	3.43		UG/L	73	83	2
MW-34	W34M2A	3/5/2004	DEMO 1	E314.0	PERCHLORATE	7.02		UG/L	53	63	2
MW-34	W34M1A	5/14/2004	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	6.8		UG/L	73	83	2
MW-34	W34M1A	5/14/2004	DEMO 1	E314.0	PERCHLORATE	5.28		UG/L	73	83	2
MW-34	W34M2A	5/14/2004	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.2		UG/L	53	63	2
MW-34	W34M2A	5/14/2004	DEMO 1	E314.0	PERCHLORATE	5.23		UG/L	53	63	2
MW-34	W34M1A	8/5/2004	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.7		UG/L	73	83	2
MW-34	W34M1A	8/5/2004	DEMO 1	E314.0	PERCHLORATE	3.32	J	UG/L	73	83	2

AOC = Area of Concern  
J = Estimated Result

BWTS = Depth Below Water Table Start (feet)  
BWTE = Depth Below Water Table End (feet)  
DW Limit = Either the MCL or Lowest Health Advisory Limit

TABLE 4

## VALIDATED DETECTS EXCEEDING MCLs or HEALTH ADVISORY LIMITS 1997 THROUGH September 2008

LOCID/WELL ID	SAMPLE_ID	SAMPLED	AOC	METHOD	ANALYTE	CONC	FLAG	UNITS	BWTS	BWTE	DW LIMIT
MW-34	W34M2A	8/5/2004	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.1		UG/L	53	63	2
MW-34	W34M2A	8/5/2004	DEMO 1	E314.0	PERCHLORATE	5.87	J	UG/L	53	63	2
MW-34	W34M2A	12/8/2004	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.2		UG/L	53	63	2
MW-34	W34M1A	4/21/2005	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.7		UG/L	73	83	2
MW-34	W34M1A	4/21/2005	DEMO 1	E314.0	PERCHLORATE	3.1		UG/L	73	83	2
MW-34	W34M2A	4/21/2005	DEMO 1	E314.0	PERCHLORATE	3.9		UG/L	53	63	2
MW-34	W34M2A	6/22/2005	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.8		UG/L	53	63	2
MW-34	MW-34M2-	2/8/2006	DEMO 1	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.9		UG/L	53	63	2
MW-34	MW-34M1-	4/18/2006	DEMO 1	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	6.6		UG/L	73	83	2
MW-34	MW-34M1-	4/18/2006	DEMO 1	E314.0	PERCHLORATE	7.35		UG/L	73	83	2
MW-34	MW-34M2-	4/18/2006	DEMO 1	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.9		UG/L	53	63	2
MW-34	MW-34M2-	4/18/2006	DEMO 1	E314.0	PERCHLORATE	6.13		UG/L	53	63	2
MW-34	MW-34M2	1/2/2007	DEMO 1	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.7		UG/L	53	63	2
MW-34	MW-34M2	4/25/2007	DEMO 1	E314.0	PERCHLORATE	2.05		UG/L	53	63	2
MW-341	W341M3A	8/18/2004	DEMO 1	E314.0	PERCHLORATE	2.95		UG/L	50.66	60.66	2
MW-341	W341M4A	8/31/2004	DEMO 1	E314.0	PERCHLORATE	14.7		UG/L	22.66	27.66	2
MW-341	W341M3A	12/10/2004	DEMO 1	E314.0	PERCHLORATE	15.5		UG/L	50.66	60.66	2
MW-341	W341M3A	4/18/2005	DEMO 1	E314.0	PERCHLORATE	40	J	UG/L	50.66	60.66	2
MW-341	W341M3A	8/8/2005	DEMO 1	E314.0	PERCHLORATE	20		UG/L	50.66	60.66	2
MW-341	MW-341M3-	12/8/2005	DEMO 1	E314.0	PERCHLORATE	7.52		UG/L	50.66	60.66	2
MW-341	MW-341M3 -	4/7/2006	DEMO 1	E314.0	PERCHLORATE	4.66		UG/L	50.66	60.66	2
MW-341	MW-341M3	12/27/2006	DEMO 1	E314.0	PERCHLORATE	2.64		UG/L	50.66	60.66	2
MW-343	MW-343M1-	11/22/2004	J-3 RANGE	E314.0	PERCHLORATE	2.9		UG/L	122	132	2
MW-343	MW-343M2-	11/22/2004	J-3 RANGE	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	19		UG/L	74	84	2
MW-343	MW-343M2-FD	11/22/2004	J-3 RANGE	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	18		UG/L	74	84	2
MW-343	MW-343M1-	3/23/2005	J-3 RANGE	E314.0	PERCHLORATE	2.3		UG/L	122	132	2
MW-343	MW-343M2-	3/23/2005	J-3 RANGE	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	34		UG/L	74	84	2
MW-343	MW-343M1-	7/18/2005	J-3 RANGE	E314.0	PERCHLORATE	3.5		UG/L	122	132	2
MW-343	MW-343M2-	7/18/2005	J-3 RANGE	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	35		UG/L	74	84	2
MW-343	W343M1A	1/10/2006	J-3 RANGE	E314.0	PERCHLORATE	3.6		UG/L	122	132	2
MW-343	W343M2A	1/10/2006	J-3 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	24		UG/L	74	84	2
MW-343	W343M1A	6/6/2006	J-3 RANGE	E314.0	PERCHLORATE	5.4	J	UG/L	122	132	2
MW-343	MW-343M1	9/14/2007	J-3 RANGE	E314.0	PERCHLORATE	5.39	J	UG/L	122	132	2
MW-344	MW-344S-FD	4/24/2007	NW CORNER	E314.0	PERCHLORATE	2.2		UG/L	0	8.07	2
MW-346M1	MW-346M1-	12/9/2004	J-1 RANGE	E314.0	PERCHLORATE	2.8		UG/L	130	140	2
MW-346M1	MW-346M1-	4/14/2005	J-1 RANGE	E314.0	PERCHLORATE	5.2		UG/L	130	140	2
MW-346M1	MW-346M1-	8/15/2005	J-1 RANGE	E314.0	PERCHLORATE	6.5		UG/L	130	140	2
MW-346M1	W346M1A	1/27/2006	J-1 RANGE	E314.0	PERCHLORATE	10.4		UG/L	130	140	2
MW-346M1	W346M1A	3/15/2006	J-1 RANGE	E314.0	PERCHLORATE	11.8		UG/L	130	140	2
MW-346M1	MW-346M1-	4/17/2007	J-1 RANGE	E314.0	PERCHLORATE	25		UG/L	130	140	2
MW-346M1	MW-346M1_0508	6/18/2008	CIA [108]	E314.0	PERCHLORATE	37.7		UG/L	130	140	2
MW-346M2	MW-346M2-	12/9/2004	J-1 RANGE	E314.0	PERCHLORATE	3		UG/L	90	100	2
MW-346M2	MW-346M2-	4/13/2005	J-1 RANGE	E314.0	PERCHLORATE	5.8		UG/L	90	100	2
MW-346M2	MW-346M2-FD	4/13/2005	J-1 RANGE	E314.0	PERCHLORATE	5.9		UG/L	90	100	2
MW-346M2	MW-346M3-	5/18/2005	J-1 RANGE	E314.0	PERCHLORATE	8.5		UG/L	60	70	2
MW-346M2	MW-346M2-	8/15/2005	J-1 RANGE	E314.0	PERCHLORATE	11		UG/L	90	100	2
MW-346M2	W346M2A	1/27/2006	J-1 RANGE	E314.0	PERCHLORATE	25.9		UG/L	90	100	2

AOC = Area of Concern  
J = Estimated Result

BWTS = Depth Below Water Table Start (feet)

BWTE = Depth Below Water Table End (feet)

DW Limit = Either the MCL or Lowest Health Advisory Limit

TABLE 4

## VALIDATED DETECTS EXCEEDING MCLs or HEALTH ADVISORY LIMITS 1997 THROUGH September 2008

LOCID/WELL ID	SAMPLE_ID	SAMPLED	AOC	METHOD	ANALYTE	CONC	FLAG	UNITS	BWTS	BWTE	DW LIMIT
MW-348	MW-348M2-	11/3/2004	J-2 RANGE	E314.0	PERCHLORATE	38		UG/L	89.54	99.54	2
MW-348	MW-348M2-	3/23/2005	J-2 RANGE	E314.0	PERCHLORATE	61		UG/L	89.54	99.54	2
MW-348	MW-348M2-	7/19/2005	J-2 RANGE	E314.0	PERCHLORATE	51.6		UG/L	89.54	99.54	2
MW-348	W348M2A	2/2/2006	J-2 RANGE	E314.0	PERCHLORATE	43		UG/L	89.54	99.54	2
MW-348	W348M2A	9/27/2006	J-2 RANGE	E314.0	PERCHLORATE	25		UG/L	89.54	99.54	2
MW-34M2	1966	4/21/2008	DEMO 1	E314.0	PERCHLORATE	3.61		UG/L	131	141	2
MW-35	W35SSA	8/19/1999	DEMO 1	IM40MB	ANTIMONY	6.9	J	UG/L	0	10	6
MW-35	W35SSD	8/19/1999	DEMO 1	IM40MB	ANTIMONY	13.8	J	UG/L	0	10	6
MW-35	W35SSA	12/18/2000	DEMO 1	IM40MB	THALLIUM	2.9	J	UG/L	0	10	2
MW-35	W35M1A	5/4/2001	DEMO 1	E314.0	PERCHLORATE	4	J	UG/L	68	78	2
MW-35	W35M1A	8/3/2001	DEMO 1	E314.0	PERCHLORATE	5.4		UG/L	68	78	2
MW-35	W35M1A	12/21/2001	DEMO 1	E314.0	PERCHLORATE	6.34	J	UG/L	68	78	2
MW-35	W35M1A	4/24/2002	DEMO 1	E314.0	PERCHLORATE	6.44	J	UG/L	68	78	2
MW-35	W35M1A	8/19/2002	DEMO 1	E314.0	PERCHLORATE	5		UG/L	68	78	2
MW-35	W35M1A	11/18/2002	DEMO 1	E314.0	PERCHLORATE	4.2		UG/L	68	78	2
MW-35	W35M1A	4/8/2003	DEMO 1	E314.0	PERCHLORATE	3.9		UG/L	68	78	2
MW-35	W35M1A	8/25/2004	DEMO 1	E314.0	PERCHLORATE	3.5	J	UG/L	68	78	2
MW-356	MW-356M1-FD	6/17/2005	J-3 RANGE	SW8270	BIS(2-ETHYLHEXYL) PHTHALATE	37	J	UG/L	82.4	92.4	6
MW-36	W36M2A	8/17/1999	DEMO 1	OC21B	BIS(2-ETHYLHEXYL) PHTHALATE	8		UG/L	54	64	6
MW-36	W36SSA	8/17/1999	DEMO 1	IM40MB	ANTIMONY	6.7	J	UG/L	0	10	6
MW-36	W36M2D	1/8/2002	DEMO 1	E314.0	PERCHLORATE	2.16		UG/L	54	64	2
MW-36	W36M2A	4/24/2002	DEMO 1	E314.0	PERCHLORATE	3.44		UG/L	54	64	2
MW-36	W36M2A	8/8/2002	DEMO 1	E314.0	PERCHLORATE	4	J	UG/L	54	64	2
MW-36	W36M2A	11/18/2002	DEMO 1	E314.0	PERCHLORATE	4.2	J	UG/L	54	64	2
MW-36	W36M2A	3/25/2003	DEMO 1	E314.0	PERCHLORATE	3.7	J	UG/L	54	64	2
MW-36	W36M2A	11/12/2003	DEMO 1	E314.0	PERCHLORATE	4.8		UG/L	54	64	2
MW-36	W36M2A	3/3/2004	DEMO 1	E314.0	PERCHLORATE	3.13		UG/L	54	64	2
MW-36	W36M2D	3/3/2004	DEMO 1	E314.0	PERCHLORATE	3.09		UG/L	54	64	2
MW-36	W36M2A	8/3/2004	DEMO 1	E314.0	PERCHLORATE	2.9	J	UG/L	54	64	2
MW-36	W36M2A	4/21/2005	DEMO 1	E314.0	PERCHLORATE	5.3		UG/L	54	64	2
MW-36	MW-36M2-	4/18/2006	DEMO 1	E314.0	PERCHLORATE	2.29		UG/L	54	64	2
MW-360	MW-360M2-	7/25/2005	J-1 RANGE	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.4		UG/L	5	15	2
MW-366	MW-366M3-	3/15/2005	J-2 RANGE	E314.0	PERCHLORATE	2.3		UG/L	49.6	59.6	2
MW-368M1	MW-368M1-	6/30/2005	J-2 RANGE	E314.0	PERCHLORATE	15.8	J	UG/L	133.85	143.85	2
MW-368M1	MW-368M1-	10/28/2005	J-2 RANGE	E314.0	PERCHLORATE	19.3		UG/L	133.85	143.85	2
MW-368M1	MW-368M1-	2/24/2006	J-2 RANGE	E314.0	PERCHLORATE	15.9		UG/L	133.85	143.85	2
MW-368M1	W368M1A	3/27/2006	J-2 RANGE	E314.0	PERCHLORATE	14.1		UG/L	133.85	143.85	2
MW-368M1	MW-368M1-	4/12/2007	J-2 RANGE	E314.0	PERCHLORATE	38.6		UG/L	133.85	143.85	2
MW-368M1	MW-368M1_0408	4/14/2008	J-2 RANGE East	E314.0	PERCHLORATE	70.8		UG/L	133.85	143.85	2
MW-368M2	MW-368M2-	6/30/2005	J-2 RANGE	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	9.5		UG/L	99.5	109.5	2
MW-368M2	MW-368M2-	6/30/2005	J-2 RANGE	E314.0	PERCHLORATE	39.8	J	UG/L	99.5	109.5	2
MW-368M2	MW-368M2-FD	6/30/2005	J-2 RANGE	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	9.2		UG/L	99.5	109.5	2
MW-368M2	MW-368M2-FD	6/30/2005	J-2 RANGE	E314.0	PERCHLORATE	40	J	UG/L	99.5	109.5	2
MW-368M2	MW-368M2-	10/28/2005	J-2 RANGE	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	11		UG/L	99.5	109.5	2
MW-368M2	MW-368M2-	10/28/2005	J-2 RANGE	E314.0	PERCHLORATE	50.8		UG/L	99.5	109.5	2
MW-368M2	MW-368M2-FD	10/28/2005	J-2 RANGE	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	12		UG/L	99.5	109.5	2
MW-368M2	MW-368M2-FD	10/28/2005	J-2 RANGE	E314.0	PERCHLORATE	51.5		UG/L	99.5	109.5	2

AOC = Area of Concern  
J = Estimated Result

BWTS = Depth Below Water Table Start (feet)

BWTE = Depth Below Water Table End (feet)

DW Limit = Either the MCL or Lowest Health Advisory Limit

TABLE 4

## VALIDATED DETECTS EXCEEDING MCLs or HEALTH ADVISORY LIMITS 1997 THROUGH September 2008

LOCID/WELL ID	SAMPLE_ID	SAMPLED	AOC	METHOD	ANALYTE	CONC	FLAG	UNITS	BWTS	BWTE	DW LIMIT
MW-368M2	MW-368M2-	2/24/2006	J-2 RANGE	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	11		UG/L	99.5	109.5	2
MW-368M2	MW-368M2-	2/24/2006	J-2 RANGE	E314.0	PERCHLORATE	55.6		UG/L	99.5	109.5	2
MW-368M2	W368M2A	3/28/2006	J-2 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	12		UG/L	99.5	109.5	2
MW-368M2	W368M2A	3/28/2006	J-2 RANGE	E314.0	PERCHLORATE	50.8		UG/L	99.5	109.5	2
MW-368M2	W368M2A	10/10/2006	J-2 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	12		UG/L	99.5	109.5	2
MW-368M2	W368M2A	10/10/2006	J-2 RANGE	E314.0	PERCHLORATE	42.5		UG/L	99.5	109.5	2
MW-368M2	MW-368M2-	4/12/2007	J-2 RANGE	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	11		UG/L	99.5	109.5	2
MW-368M2	MW-368M2-	4/12/2007	J-2 RANGE	E314.0	PERCHLORATE	53		UG/L	99.5	109.5	2
MW-368M2	MW-368M2-FD	4/12/2007	J-2 RANGE	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	11		UG/L	99.5	109.5	2
MW-368M2	MW-368M2-FD	4/12/2007	J-2 RANGE	E314.0	PERCHLORATE	50.5		UG/L	99.5	109.5	2
MW-368M2	MW-368M2_0408	4/14/2008	J-2 RANGE East	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	14		UG/L	99.5	109.5	2
MW-368M2	MW-368M2_0408	4/14/2008	J-2 RANGE East	E314.0	PERCHLORATE	68.6		UG/L	99.5	109.5	2
MW-368M2	MW-368M2_0408D	4/14/2008	J-2 RANGE East	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	15		UG/L	99.5	109.5	2
MW-368M2	MW-368M2_0408D	4/14/2008	J-2 RANGE East	E314.0	PERCHLORATE	67.9		UG/L	99.5	109.5	2
MW-368M2	MW-369M1A	11/7/2006	J-1 NORTH	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.1		UG/L	137.87	147.87	2
MW-369M1	MW-369M1-	4/17/2007	J-1 NORTH	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2		UG/L	137.87	147.87	2
MW-369M1	MW-369M1-	10/2/2007	J-1 NORTH	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.2		ug/L	99.8	109.8	2
MW-369M1	MW-369M1_0508	6/9/2008	CIA [108]	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.5		UG/L	254	264	2
MW-36M2	1970	4/23/2008	DEMO 1	E314.0	PERCHLORATE	2.06		UG/L	131	141	2
MW-37	W37M2A	9/29/1999	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.9		UG/L	26	36	2
MW-37	W37M2A	12/29/1999	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.6		UG/L	26	36	2
MW-37	W37M2A	12/29/1999	CIA	IM40MB	THALLIUM	4.9	J	UG/L	26	36	2
MW-37	71MW0037M2-	3/16/2000	CS-19	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3		UG/L			2
MW-37	71MW0037M2-FD	3/16/2000	CS-19	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3		UG/L			2
MW-37	W37M2A	3/27/2000	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.1		UG/L	26	36	2
MW-37	W37M2A	8/31/2000	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.8	J	UG/L	26	36	2
MW-37	W37M2A	11/27/2000	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.4		UG/L	26	36	2
MW-37	W37M2D	11/27/2000	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.4		UG/L	26	36	2
MW-37	W37M2A	6/11/2002	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4		UG/L	26	36	2
MW-37	W37M2D	6/11/2002	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4		UG/L	26	36	2
MW-37	W37M2A	8/13/2002	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.6	J	UG/L	26	36	2
MW-37	W37M2A	1/31/2003	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.4		UG/L	26	36	2
MW-37	W37M2A	4/10/2003	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.1		UG/L	26	36	2
MW-37	W37M2A	10/1/2003	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.6		UG/L	26	36	2
MW-37	W37M2A	3/1/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.1		UG/L	26	36	2
MW-37	W37M3A	3/1/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2		UG/L	11	21	2
MW-37	W37M2A	12/21/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.3	J	UG/L	26	36	2
MW-37	W37M2A	5/2/2005	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.1		UG/L	26	36	2
MW-37	W37M3A	1/17/2006	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.7		UG/L	11	21	2
MW-37	W37M2A	11/16/2006	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.5		UG/L	26	36	2
MW-370M2	MW-370M2-	7/11/2005	J-1 RANGE	E314.0	PERCHLORATE	7.9		UG/L	93.5	103.5	2
MW-370M2	MW-370M2-FD	7/11/2005	J-1 RANGE	E314.0	PERCHLORATE	8		UG/L	93.5	103.5	2
MW-370M2	MW-370M2-	11/7/2005	J-1 RANGE	E314.0	PERCHLORATE	10		UG/L	93.5	103.5	2
MW-370M2	MW-370M2-	3/7/2006	J-1 RANGE	E314.0	PERCHLORATE	11.3		UG/L	93.5	103.5	2
MW-370M2	MW-370M2-FD	3/7/2006	J-1 RANGE	E314.0	PERCHLORATE	11.5		UG/L	93.5	103.5	2
MW-370M2	W370M2A	3/20/2006	J-1 RANGE	E314.0	PERCHLORATE	11.8	J	UG/L	93.5	103.5	2
MW-370M2	W370M2A	11/1/2006	J-1 RANGE	E314.0	PERCHLORATE	16.3		UG/L	93.5	103.5	2

AOC = Area of Concern  
J = Estimated Result

BWTS = Depth Below Water Table Start (feet)

BWTE = Depth Below Water Table End (feet)

DW Limit = Either the MCL or Lowest Health Advisory Limit

TABLE 4

## VALIDATED DETECTS EXCEEDING MCLs or HEALTH ADVISORY LIMITS 1997 THROUGH September 2008

LOCID/WELL ID	SAMPLE_ID	SAMPLED	AOC	METHOD	ANALYTE	CONC	FLAG	UNITS	BWTS	BWTE	DW LIMIT
MW-370M2	MW-370M2-	4/13/2007	J-1 RANGE	E314.0	PERCHLORATE	19.6		UG/L	93.5	103.5	2
MW-370M2	MW-370M2-FD	4/13/2007	J-1 RANGE	E314.0	PERCHLORATE	20.6		UG/L	93.5	103.5	2
MW-370M2	MW-370M2-	10/1/2007	J-1 NORTH	E314.0	PERCHLORATE	38		ug/L	93.5	103.5	2
MW-370M2	MW-370M2_0508	5/12/2008	CIA [108]	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.1		UG/L	216	226	2
MW-370M2	MW-370M2_0508	5/12/2008	CIA [108]	E314.0	PERCHLORATE	47.1		UG/L	93.5	103.5	2
MW-370M2	MW-370M2_0508D	5/12/2008	CIA [108]	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.1		UG/L	216	226	2
MW-370M2	MW-370M2_0508D	5/12/2008	CIA [108]	E314.0	PERCHLORATE	48.4		UG/L	93.5	103.5	2
MW-38	W38M2A	5/11/1999	CIA	IM40MB	THALLIUM	4.9	J	UG/L	69	79	2
MW-38	W38DDA	8/17/1999	CIA	IM40MB	ANTIMONY	6.9	J	UG/L	124	134	6
MW-38	W38M4A	8/18/1999	CIA	IM40MB	THALLIUM	2.8	J	UG/L	14	24	2
MW-38	W38SSA	8/18/1999	CIA	IM40MB	ANTIMONY	7.4		UG/L	0	10	6
MW-38	71MW0038M3-	3/10/2000	CS-19	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3		UG/L			2
MW-38	W38DDA	8/22/2001	CIA	IM40MB	THALLIUM	3	J	UG/L	124	134	2
MW-38	W38M4A	11/5/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.1	J	UG/L	14	24	2
MW-38	W38M4A	2/18/2005	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.4	J	UG/L	14	24	2
MW-38	W38M4A	5/13/2005	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.1	J	UG/L	14	24	2
MW-38	W38M2A	10/14/2005	CIA	6020SB	ANTIMONY	12.4	J	UG/L	69	79	6
MW-38	MW-38M4	5/11/2007	CIA	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.1		UG/L	14	24	2
MW-38M3	W38M3A	5/6/1999	CIA	OC21B	BIS(2-ETHYLHEXYL) PHTHALATE	15		UG/L	52	62	6
MW-38M3	W38M3A	5/6/1999	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.5		UG/L	52	62	2
MW-38M3	W38M3A	8/18/1999	CIA	IM40MB	ANTIMONY	6.6	J	UG/L	52	62	6
MW-38M3	W38M3A	8/18/1999	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.6		UG/L	52	62	2
MW-38M3	W38M3A	11/10/1999	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3		UG/L	52	62	2
MW-38M3	W38M3A	5/16/2000	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.9	J	UG/L	52	62	2
MW-38M3	W38M3A	8/11/2000	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.6		UG/L	52	62	2
MW-38M3	W38M3A	11/20/2000	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.4		UG/L	52	62	2
MW-38M3	W38M3A	4/30/2001	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.3	J	UG/L	52	62	2
MW-38M3	W38M3A	8/14/2001	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2		UG/L	52	62	2
MW-38M3	W38M3A	11/29/2001	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.1	J	UG/L	52	62	2
MW-38M3	W38M3D	11/29/2001	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2	J	UG/L	52	62	2
MW-38M3	W38M3A	11/19/2003	CIA	E314.0	PERCHLORATE	2.3		UG/L	52	62	2
MW-38M3	W38M3A	2/26/2004	CIA	E314.0	PERCHLORATE	2.3		UG/L	52	62	2
MW-38M3	W38M3A	4/26/2004	CIA	E314.0	PERCHLORATE	2.1		UG/L	52	62	2
MW-38M3	W38M3A	11/4/2004	CIA	E314.0	PERCHLORATE	2.7		UG/L	52	62	2
MW-38M3	W38M3A	2/18/2005	CIA	E314.0	PERCHLORATE	3.1	J	UG/L	52	62	2
MW-38M3	W38M3A	5/13/2005	CIA	E314.0	PERCHLORATE	2.8		UG/L	52	62	2
MW-38M3	W38M3A	10/25/2005	CIA	E314.0	PERCHLORATE	3		UG/L	52	62	2
MW-38M3	W38M3A	1/17/2006	CIA	E314.0	PERCHLORATE	3.2		UG/L	52	62	2
MW-38M3	W38M3D	1/17/2006	CIA	E314.0	PERCHLORATE	3.2		UG/L	52	62	2
MW-38M3	W38M3A	4/26/2006	CIA	E314.0	PERCHLORATE	3.4		UG/L	52	62	2
MW-38M3	W38M3A	11/27/2006	CIA	E314.0	PERCHLORATE	3.3		UG/L	52	62	2
MW-38M3	MW-38M3	5/11/2007	CIA	E314.0	PERCHLORATE	3.3		UG/L	52	62	2
MW-38M3	MW-38M3	5/11/2007	CIA	E314.0	PERCHLORATE	3.8		UG/L	52	62	2
MW-38M3	MW-38M3	11/29/2007	CIA	E314.0	PERCHLORATE	3		ug/L	52	62	2
MW-38M3	MW-38M3_SPR08	5/20/2008	CIA [108]	E314.0	PERCHLORATE	3.1		UG/L	52	62	2
MW-39	W39M1A	8/18/1999	CIA	IM40MB	ANTIMONY	7.5		UG/L	84	94	6
MW-39	W39M1A	12/21/2000	CIA	IM40MB	THALLIUM	4		UG/L	84	94	2

AOC = Area of Concern

J = Estimated Result

BWTS = Depth Below Water Table Start (feet)

BWTE = Depth Below Water Table End (feet)

DW Limit = Either the MCL or Lowest Health Advisory Limit

TABLE 4

## VALIDATED DETECTS EXCEEDING MCLs or HEALTH ADVISORY LIMITS 1997 THROUGH September 2008

LOCID/WELL ID	SAMPLE_ID	SAMPLED	AOC	METHOD	ANALYTE	CONC	FLAG	UNITS	BWTS	BWTE	DW LIMIT
MW-393M1	W393M1A	10/10/2006	J-2 RANGE	E314.0	PERCHLORATE	2.6		UG/L	180.42	190.42	2
MW-393M1	MW-393M1-	4/9/2007	J-2 RANGE	E314.0	PERCHLORATE	2.8		UG/L	180.42	190.42	2
MW-393M1	MW-393M1-FD	4/9/2007	J-2 RANGE	E314.0	PERCHLORATE	2.9		UG/L	180.42	190.42	2
MW-393M1	MW-393M1-	9/21/2007	J-2 RANGE	E314.0	PERCHLORATE	3.7		UG/L	180.42	190.42	2
MW-393M1	MW-393M1_0408	4/10/2008	J-2 RANGE East	E314.0	PERCHLORATE	4.7		UG/L	180.42	190.42	2
MW-398	MW-398M2-	10/19/2005	J-1 RANGE	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	120		UG/L	40.63	50.63	2
MW-398	MW-398M2-FD	10/19/2005	J-1 RANGE	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	120		UG/L	40.63	50.63	2
MW-398	MW-398M2-	2/16/2006	J-1 RANGE	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	130		UG/L	40.63	50.63	2
MW-398	MW-398M2-FD	2/16/2006	J-1 RANGE	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	120		UG/L	40.63	50.63	2
MW-398	MW-398M2-	6/16/2006	J-1 RANGE	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	100		UG/L	40.63	50.63	2
MW-398	MW-398M2	2/1/2007	J-1 RANGE	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	34		UG/L	40.63	50.63	2
MW-398	MW-398M2-	8/9/2007	J-1 RANGE	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	26		UG/L	40.63	50.63	2
MW-398	MW-398M2-FD	8/9/2007	J-1 RANGE	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	26		UG/L	40.63	50.63	2
MW-4	W04SSA	11/4/1997	CIA	OC21B	BIS(2-ETHYLHEXYL) PHTHALATE	30		UG/L	0	10	6
MW-40	W40M1A	9/21/1999	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.8		UG/L	13	23	2
MW-40	W40M1D	9/21/1999	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.6		UG/L	13	23	2
MW-40	W40M1A	12/30/1999	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3	J	UG/L	13	23	2
MW-40	W40M1A	4/14/2000	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2	J	UG/L	13	23	2
MW-40	W40M1A	9/1/2000	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.4	J	UG/L	13	23	2
MW-40	W40M1A	11/27/2000	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.5		UG/L	13	23	2
MW-40	W40M1A	6/2/2001	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.1		UG/L	13	23	2
MW-40	W40M1A	8/16/2001	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.9		UG/L	13	23	2
MW-40	W40M1A	11/29/2001	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.1	J	UG/L	13	23	2
MW-404	MW-404M2-	12/22/2005	DEMO 2	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.5		UG/L	16	26	2
MW-404	MW-404M2-FD	12/22/2005	DEMO 2	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.3		UG/L	16	26	2
MW-404	MW-404M2-	4/20/2006	DEMO 2	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5.7		UG/L	16	26	2
MW-404	MW-404M2-	8/16/2006	DEMO 2	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	6.7		UG/L	16	26	2
MW-404	MW-404M2_D2	4/3/2007	DEMO 2	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.8		UG/L	16	26	2
MW-404	MW-404M2_D2-FD	4/3/2007	DEMO 2	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.9		UG/L	16	26	2
MW-41	W41M2A	4/2/1999	CIA	IM40MB	THALLIUM	2.5	J	UG/L	67	77	2
MW-41	W41M2A	11/12/1999	CIA	OC21B	BIS(2-ETHYLHEXYL) PHTHALATE	7		UG/L	67	77	6
MW-41	W41M1A	5/18/2000	CIA	8151	PENTACHLOROPHENOL	1.8	J	UG/L	108	118	1
MW-42	W42M2A	11/19/1999	CIA	IM40MB	THALLIUM	4	J	UG/L	118	128	2
MW-431	2020	4/23/2008	DEMO 1	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5.89		UG/L	88	188	2
MW-432	2021	4/23/2008	DEMO 1	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	6.91		UG/L	88	188	2
MW-432	2021	4/23/2008	DEMO 1	E314.0	PERCHLORATE	11.7		UG/L	88	188	2
MW-433	2022	4/23/2008	DEMO 1	E314.0	PERCHLORATE	3.98		UG/L	148	228	2
MW-43M2	W43M1A	5/26/1999	CIA	OC21B	BIS(2-ETHYLHEXYL) PHTHALATE	6		UG/L	90	100	6
MW-43M2	W43M2A	4/27/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2		UG/L	67	77	2
MW-43M2	W43M2A	9/21/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.1		UG/L	67	77	2
MW-43M2	W43M2A	3/8/2005	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.2		UG/L	67	77	2
MW-43M2	W43M2D	3/8/2005	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.1		UG/L	67	77	2
MW-43M2	W43M2A	5/11/2005	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.1		UG/L	67	77	2
MW-43M2	W43M2A	5/4/2006	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	7.3		UG/L	67	77	2
MW-43M2	W43M2A	11/1/2006	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.4		UG/L	67	77	2
MW-43M2	MW-43M2	10/23/2007	CIA	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2		ug/L	67	77	2
MW-43M2	MW-43M2_SPR08	5/21/2008	CIA [108]	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2		UG/L	200	210	2

AOC = Area of Concern  
J = Estimated Result

BWTS = Depth Below Water Table Start (feet)

BWTE = Depth Below Water Table End (feet)

DW Limit = Either the MCL or Lowest Health Advisory Limit

TABLE 4

## VALIDATED DETECTS EXCEEDING MCLs or HEALTH ADVISORY LIMITS 1997 THROUGH September 2008

LOCID/WELL ID	SAMPLE_ID	SAMPLED	AOC	METHOD	ANALYTE	CONC	FLAG	UNITS	BWTS	BWTE	DW LIMIT
MW-44	W44M1A	9/20/1999	CIA	OC21B	BIS(2-ETHYLHEXYL) PHTHALATE	14		UG/L	53	63	6
MW-44	W44SSA	8/24/2001	CIA	IM40MB	THALLIUM	3	J	UG/L	0	10	2
MW-45	W45M1A	5/24/1999	L RANGE	OC21B	BIS(2-ETHYLHEXYL) PHTHALATE	37		UG/L	98	108	6
MW-45	W45SSA	5/26/1999	L RANGE; FS-12	IM40MB	THALLIUM	3	J	UG/L	0	10	2
MW-45	W45SSA	11/16/1999	L RANGE; FS-12	IM40MB	ARSENIC	13.8		UG/L	0	10	10
MW-45	W45SSA	11/16/1999	L RANGE; FS-12	OC21V	TOLUENE	1000		UG/L	0	10	1000
MW-45	W45SSA	5/29/2000	L RANGE; FS-12	IM40MB	ARSENIC	18.2		UG/L	0	10	10
MW-45	W45SSA	5/29/2000	L RANGE; FS-12	OC21V	TOLUENE	1100		UG/L	0	10	1000
MW-45	W45SSA	8/31/2000	L RANGE; FS-12	IM40MB	ARSENIC	13.1	J	UG/L	0	10	10
MW-45	W45SSA	8/31/2000	L RANGE; FS-12	IM40MB	THALLIUM	4.4	J	UG/L	0	10	2
MW-45	W45SSA	12/27/2000	L RANGE; FS-12	IM40MB	ARSENIC	13.7		UG/L	0	10	10
MW-45	W45SSA	12/27/2000	L RANGE; FS-12	OC21V	TOLUENE	1300		UG/L	0	10	1000
MW-45	W45SSA	8/23/2001	L RANGE; FS-12	8330	2,6-DINITROTOLUENE	8.3	J	UG/L	0	10	5
MW-45	W45SSA	8/23/2001	L RANGE; FS-12	IM40MB	ARSENIC	19		UG/L	0	10	10
MW-45	W45SSA	8/23/2001	L RANGE; FS-12	IM40MB	LEAD	42.2		UG/L	0	10	15
MW-45	W45SSA	12/14/2001	L RANGE; FS-12	IM40MB	ARSENIC	19.8		UG/L	0	10	10
MW-45	W45SSA	12/14/2001	L RANGE; FS-12	IM40MB	LEAD	42.8		UG/L	0	10	15
MW-45	W45SSA	12/14/2001	L RANGE; FS-12	OC21V	TOLUENE	1300		UG/L	0	10	1000
MW-45	W45SSA	6/9/2003	L RANGE; FS-12	IM40MB	ARSENIC	32.9		UG/L	0	10	10
MW-45	W45SSA	6/9/2003	L RANGE; FS-12	IM40MB	LEAD	619		UG/L	0	10	15
MW-45	W45SSA	6/9/2003	L RANGE; FS-12	OC21V	METHYLENE CHLORIDE	5	J	UG/L	0	10	5
MW-45	W45SSL	6/9/2003	L RANGE; FS-12	IM40MB	ARSENIC	23.9		UG/L	0	10	10
MW-45	W45SSL	6/9/2003	L RANGE; FS-12	IM40MB	LEAD	516		UG/L	0	10	15
MW-45	W45SSA	7/28/2003	L RANGE; FS-12	IM40MB	ARSENIC	40.1		UG/L	0	10	10
MW-45	W45SSA	7/28/2003	L RANGE; FS-12	IM40MB	LEAD	326		UG/L	0	10	15
MW-45	W45SSA	7/28/2003	L RANGE; FS-12	OC21V	METHYLENE CHLORIDE	8	J	UG/L	0	10	5
MW-45	W45SSA	1/21/2004	L RANGE; FS-12	IM40MB	ARSENIC	27.2		UG/L	0	10	10
MW-45	W45SSA	1/21/2004	L RANGE; FS-12	IM40MB	LEAD	50.7		UG/L	0	10	15
MW-45	W45SSA	6/30/2004	L RANGE; FS-12	IM40MBM	ARSENIC	27.8		UG/L	0	10	10
MW-45	W45SSA	6/30/2004	L RANGE; FS-12	IM40MBM	LEAD	35.2		UG/L	0	10	15
MW-45	W45SSA	9/29/2004	L RANGE; FS-12	IM40MBM	ARSENIC	28.5		UG/L	0	10	10
MW-45	W45SSA	9/29/2004	L RANGE; FS-12	IM40MBM	LEAD	35.7		UG/L	0	10	15
MW-45	W45SSA	1/6/2005	L RANGE; FS-12	IM40MBM	ARSENIC	31.1		UG/L	0	10	10
MW-45	W45SSA	1/6/2005	L RANGE; FS-12	IM40MBM	LEAD	24.9		UG/L	0	10	15
MW-45	W45SSX	1/6/2005	L RANGE; FS-12	IM40MBM	ARSENIC	29		UG/L	0	10	10
MW-45	W45SSX	1/6/2005	L RANGE; FS-12	IM40MBM	LEAD	18.2		UG/L	0	10	15
MW-45	W45SSA	6/6/2005	L RANGE; FS-12	IM40MBM	ARSENIC	23.1		UG/L	0	10	10
MW-45	W45SSA	6/6/2005	L RANGE; FS-12	IM40MBM	LEAD	21.4		UG/L	0	10	15
MW-45	W45SSA	9/15/2005	L RANGE; FS-12	IM40MB	ARSENIC	16.5		UG/L	0	10	10
MW-45	W45SSA	9/15/2005	L RANGE; FS-12	IM40MB	LEAD	20		UG/L	0	10	15
MW-45	W45SSD	9/15/2005	L RANGE; FS-12	IM40MB	ARSENIC	18.4		UG/L	0	10	10
MW-45	W45SSD	9/15/2005	L RANGE; FS-12	IM40MB	LEAD	16.4		UG/L	0	10	15
MW-45	W45SSA	2/6/2006	L RANGE; FS-12	IM40MBM	ARSENIC	20.1		UG/L	0	10	10
MW-46	W46M2A	3/30/1999	WESTERN BOUNDARY	IM40MB	MOLYBDENUM	48.9		UG/L	56	66	40
MW-46	W46M2A	3/30/1999	WESTERN BOUNDARY	IM40MB	SODIUM	23300		UG/L	56	66	20000
MW-46	W46M2L	3/30/1999	WESTERN BOUNDARY	IM40MB	MOLYBDENUM	51		UG/L	56	66	40
MW-46	W46M2L	3/30/1999	WESTERN BOUNDARY	IM40MB	SODIUM	24400		UG/L	56	66	20000

AOC = Area of Concern  
J = Estimated Result

BWTS = Depth Below Water Table Start (feet)

BWTE = Depth Below Water Table End (feet)

DW Limit = Either the MCL or Lowest Health Advisory Limit

TABLE 4

## VALIDATED DETECTS EXCEEDING MCLs or HEALTH ADVISORY LIMITS 1997 THROUGH September 2008

LOCID/WELL ID	SAMPLE_ID	SAMPLED	AOC	METHOD	ANALYTE	CONC	FLAG	UNITS	BWTS	BWTE	DW LIMIT
MW-46	W46SSA	8/25/1999	WESTERN BOUNDARY	IM40MB	SODIUM	20600		UG/L	0	10	20000
MW-46	W46M1A	11/1/1999	WESTERN BOUNDARY	OC21B	BIS(2-ETHYLHEXYL) PHTHALATE	6	J	UG/L	103	113	6
MW-46	W46DDA	11/2/1999	WESTERN BOUNDARY	OC21B	BIS(2-ETHYLHEXYL) PHTHALATE	14	J	UG/L	136	146	6
MW-46	W46DDA	11/2/1999	WESTERN BOUNDARY	IM40MB	THALLIUM	5.1	J	UG/L	136	146	2
MW-46	W46M1A	5/16/2000	WESTERN BOUNDARY	IM40MB	THALLIUM	5.3	J	UG/L	103	113	2
MW-46	W46SSA	6/15/2000	WESTERN BOUNDARY	IM40MB	SODIUM	32200		UG/L	0	10	20000
MW-46	W46SSA	9/12/2000	WESTERN BOUNDARY	IM40MB	SODIUM	31300		UG/L	0	10	20000
MW-46	W46SSA	11/17/2000	WESTERN BOUNDARY	IM40MB	SODIUM	22500	J	UG/L	0	10	20000
MW-47	W47M2A	3/26/1999	WESTERN BOUNDARY	IM40MB	THALLIUM	3.2	J	UG/L	38	48	2
MW-47	W47M3A	3/29/1999	OTHER	IM40MB	MOLYBDENUM	43.1		UG/L	21	31	40
MW-47	W47M3L	3/29/1999	OTHER	IM40MB	MOLYBDENUM	40.5		UG/L	21	31	40
MW-47	W47DDA	8/24/1999	WESTERN BOUNDARY	OC21B	BIS(2-ETHYLHEXYL) PHTHALATE	16		UG/L	100	110	6
MW-47	W47M1A	8/24/1999	WESTERN BOUNDARY	OC21B	BIS(2-ETHYLHEXYL) PHTHALATE	14		UG/L	75	85	6
MW-47	W47M1A	8/24/1999	WESTERN BOUNDARY	IM40MB	THALLIUM	2.6	J	UG/L	75	85	2
MW-47	W47M2A	8/25/1999	WESTERN BOUNDARY	IM40MB	THALLIUM	4	J	UG/L	38	48	2
MW-47	W47M3A	8/25/1999	OTHER	IM40MB	THALLIUM	3.2	J	UG/L	21	31	2
MW-47	W47M2A	5/30/2000	WESTERN BOUNDARY	IM40MB	THALLIUM	4.5	J	UG/L	38	48	2
MW-47	W47M3A	5/31/2000	OTHER	IM40MB	THALLIUM	5	J	UG/L	21	31	2
MW-47	W47M2D	2/5/2003	WESTERN BOUNDARY	SW8270	BIS(2-ETHYLHEXYL) PHTHALATE	9.6	J	UG/L	38	48	6
MW-477M2	MW-477M2-	1/8/2007	J-1 RANGE	SW8270	BIS(2-ETHYLHEXYL) PHTHALATE	14		UG/L	26.1	36.1	6
MW-477M2	MW-477M2-	1/8/2007	J-1 RANGE	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	7.3		UG/L	26.1	36.1	2
MW-477M2	MW-477M2-	5/10/2007	J-1 RANGE	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.8		UG/L	26.1	36.1	2
MW-477M2	MW-477M2_0508	6/26/2008	J1N [148]	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.5		UG/L	26.1	36.1	2
MW-48	W48M3A	2/28/2000	J-2 RANGE	IM40MB	THALLIUM	4.2	J	UG/L	31	41	2
MW-48	W48DAA	6/26/2000	J-2 RANGE	IM40MB	THALLIUM	4.7	J	UG/L	121	131	2
MW-481M2	MW-481M2-	2/27/2007	J1S [189]	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	12		UG/L	148	158	2
MW-481M2	MW-481M2-FD	2/27/2007	J1S [189]	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	12		UG/L	148	158	2
MW-481M2	MW-481M2-	6/28/2007	J1S [189]	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	22		UG/L	148	158	2
MW-481M2	MW-481M2-FD	6/28/2007	J1S [189]	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	22		UG/L	148	158	2
MW-481M2	MW-481M2-	10/26/2007	J1S [189]	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	12		ug/L	148	158	2
MW-481M2	MW-481M2-FD	10/26/2007	J1S [189]	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	12		ug/L	148	158	2
MW-481M2	MW-481M2_0408	4/4/2008	J1S [189]	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	7.85		UG/L	148	158	2
MW-481M2	MW-481M2_0408D	4/4/2008	J1S [189]	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	8.14		UG/L	148	158	2
MW-481M2	MW-481M2_0708	7/31/2008	J1S [189]	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.2		UG/L	148	158	2
MW-485M1	MW-485M1-	4/18/2007	J-1 RANGE	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	7		UG/L	4.7	14.7	2
MW-485M1	MW-485M1-	8/13/2007	J-1 RANGE	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5.8		UG/L	4.7	14.7	2
MW-485M1	MW-485M1-	12/11/2007	J-1 RANGE	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5		ug/L	4.7	14.7	2
MW-485M1	MW-485M1_0508	6/26/2008	J1N [148]	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	6		UG/L	125	135	2
MW-486M1	MW-486M1-	4/18/2007	J-1 RANGE	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	8.4		UG/L	70.7	80.7	2
MW-486M1	MW-486M1-	8/14/2007	J-1 RANGE	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	6		UG/L	70.7	80.7	2
MW-486M1	MW-486M1-FD	8/14/2007	J-1 RANGE	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5.9		UG/L	70.7	80.7	2
MW-486M1	MW-486M1-	12/11/2007	J-1 RANGE	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5.6		ug/L	70.7	80.7	2
MW-486M1	MW-486M1_0508	6/26/2008	J1N [148]	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	8		UG/L	186	196	2
MW-486M1	MW-486M1_0508D	6/26/2008	J1N [148]	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	7.9		UG/L	186	196	2
MW-487M2	MW-487M2-	4/18/2007	J-1 RANGE	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	8.1		UG/L	68.89	78.89	2
MW-487M2	MW-487M2-FD	4/18/2007	J-1 RANGE	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	8.2		UG/L	68.89	78.89	2
MW-487M2	MW-487M2-	8/15/2007	J-1 RANGE	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	8.3		UG/L	68.89	78.89	2

AOC = Area of Concern  
J = Estimated Result

BWTS = Depth Below Water Table Start (feet)

BWTE = Depth Below Water Table End (feet)

DW Limit = Either the MCL or Lowest Health Advisory Limit

TABLE 4

## VALIDATED DETECTS EXCEEDING MCLs or HEALTH ADVISORY LIMITS 1997 THROUGH September 2008

LOCID/WELL ID	SAMPLE_ID	SAMPLED	AOC	METHOD	ANALYTE	CONC	FLAG	UNITS	BWTS	BWTE	DW LIMIT
MW-487M2	MW-487M2-	12/13/2007	J-1 RANGE	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	7.6		ug/L	68.89	78.89	2
MW-487M2	MW-487M2_0508	6/30/2008	J1N [148]	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	6.8		UG/L	196	206	2
MW-49	W49SSA	11/19/1999	J-2 RANGE	IM40MB	THALLIUM	4.7	J	UG/L	0	10	2
MW-49	W49SSA	3/1/2000	J-2 RANGE	OC21B	BIS(2-ETHYLHEXYL) PHTHALATE	290		UG/L	0	10	6
MW-49	W49M3D	6/27/2000	J-2 RANGE	IM40MB	THALLIUM	4.3	J	UG/L	31	41	2
MW-5	W05DDA	2/13/1998	J-2 RANGE	OC21B	BIS(2-ETHYLHEXYL) PHTHALATE	9	J	UG/L	223	228	6
MW-50	W50M1A	5/15/2000	CIA	IM40MB	ANTIMONY	9.5		UG/L	89	99	6
MW-50	W50M1A	5/15/2000	CIA	IM40MB	THALLIUM	6.2	J	UG/L	89	99	2
MW-51	W51M3A	8/25/1999	CIA	IM40MB	THALLIUM	4.3	J	UG/L	28	38	2
MW-52	W52DDA	4/2/1999	OTHER	IM40MB	MOLYBDENUM	51.1		UG/L	218	228	40
MW-52	W52DDA	4/2/1999	OTHER	IM40MB	THALLIUM	2.8	J	UG/L	218	228	2
MW-52	W52DDL	4/2/1999	OTHER	IM40MB	MOLYBDENUM	48.9		UG/L	218	228	40
MW-52	W52DDL	4/2/1999	OTHER	IM40MB	THALLIUM	2.6	J	UG/L	218	228	2
MW-52	W52M3A	4/7/1999	OTHER	IM40MB	MOLYBDENUM	72.6		UG/L	59	64	40
MW-52	W52M3L	4/7/1999	OTHER	IM40MB	MOLYBDENUM	67.6		UG/L	59	64	40
MW-52	W52M3L	4/7/1999	OTHER	IM40MB	THALLIUM	3.6	J	UG/L	59	64	2
MW-52	W52SSA	8/26/1999	OTHER	IM40MB	THALLIUM	3.6	J	UG/L	0	10	2
MW-52	W52M3A	8/27/1999	OTHER	OC21B	BIS(2-ETHYLHEXYL) PHTHALATE	7	J	UG/L	59	64	6
MW-52	W52M3L	8/27/1999	OTHER	IM40MB	CADMIUM	12.2		UG/L	59	64	5
MW-52	W52DDA	8/30/1999	OTHER	IM40MB	THALLIUM	3.8	J	UG/L	218	228	2
MW-52	W52SSA	11/18/1999	OTHER	IM40MB	THALLIUM	4.3	J	UG/L	0	10	2
MW-52	W52M2A	5/23/2000	OTHER	IM40MB	ARSENIC	11.3		UG/L	74	84	10
MW-52	W52SSA	5/23/2000	OTHER	IM40MB	THALLIUM	4.7	J	UG/L	0	10	2
MW-53	W53DDA	2/18/1999	OTHER	OC21B	BIS(2-ETHYLHEXYL) PHTHALATE	18		UG/L	158	168	6
MW-53	W53M1A	5/3/1999	OTHER	IM40MB	MOLYBDENUM	122		UG/L	99	109	40
MW-53	W53M1L	5/3/1999	OTHER	IM40MB	MOLYBDENUM	132		UG/L	99	109	40
MW-53	W53M1A	8/30/1999	OTHER	OC21B	BIS(2-ETHYLHEXYL) PHTHALATE	31		UG/L	99	109	6
MW-53	W53M1A	8/30/1999	OTHER	IM40MB	MOLYBDENUM	55.2		UG/L	99	109	40
MW-53	W53M1L	8/30/1999	OTHER	IM40MB	MOLYBDENUM	54.1		UG/L	99	109	40
MW-53	W53M1A	11/5/1999	OTHER	IM40MB	MOLYBDENUM	41.2		UG/L	99	109	40
MW-53	W53M1A	11/5/1999	OTHER	IM40MB	THALLIUM	3.4	J	UG/L	99	109	2
MW-54	W54SSA	4/30/1999	OTHER	IM40MB	MOLYBDENUM	56.7		UG/L	0	10	40
MW-54	W54SSL	4/30/1999	OTHER	IM40MB	MOLYBDENUM	66.2		UG/L	0	10	40
MW-54	W54M2A	8/27/1999	OTHER	IM40MB	MOLYBDENUM	43.7		UG/L	59	69	40
MW-54	W54M2L	8/27/1999	OTHER	IM40MB	MOLYBDENUM	43.2		UG/L	59	69	40
MW-54	W54SSA	8/27/1999	OTHER	IM40MB	MOLYBDENUM	61.4		UG/L	0	10	40
MW-54	W54SSA	8/27/1999	OTHER	IM40MB	SODIUM	33300		UG/L	0	10	20000
MW-54	W54M1A	8/30/1999	OTHER	IM40MB	THALLIUM	2.8	J	UG/L	79	89	2
MW-54	W54M1A	11/5/1999	OTHER	IM40MB	THALLIUM	3.9	J	UG/L	79	89	2
MW-54	W54SSA	11/8/1999	OTHER	IM40MB	THALLIUM	7.4	J	UG/L	0	10	2
MW-54	W54SSA	6/6/2000	OTHER	IM40MB	THALLIUM	4.6	J	UG/L	0	10	2
MW-54	W54SSA	11/15/2000	OTHER	IM40MB	THALLIUM	3.1	J	UG/L	0	10	2
MW-55	W55DDA	5/13/1999	OTHER	OC21B	BIS(2-ETHYLHEXYL) PHTHALATE	8		UG/L	119	129	6
MW-55	W55M1A	8/31/1999	OTHER	IM40MB	THALLIUM	2.5	J	UG/L	89	99	2
MW-55	W55DDA	7/31/2001	OTHER	SW8270	BIS(2-ETHYLHEXYL) PHTHALATE	6.4		UG/L	119	129	6
MW-56	W56M3A	9/5/2000	J-2 RANGE	IM40MB	THALLIUM	6.1	J	UG/L	31	41	2
MW-56	W56M3D	9/5/2000	J-2 RANGE	IM40MB	THALLIUM	4.4	J	UG/L	31	41	2

AOC = Area of Concern  
J = Estimated Result

BWTS = Depth Below Water Table Start (feet)

BWTE = Depth Below Water Table End (feet)

DW Limit = Either the MCL or Lowest Health Advisory Limit

TABLE 4

## VALIDATED DETECTS EXCEEDING MCLs or HEALTH ADVISORY LIMITS 1997 THROUGH September 2008

LOCID/WELL ID	SAMPLE_ID	SAMPLED	AOC	METHOD	ANALYTE	CONC	FLAG	UNITS	BWTS	BWTE	DW LIMIT
MW-56	W56SSA	9/5/2000	J-2 RANGE	IM40MB	THALLIUM	4	J	UG/L	1	11	2
MW-57	W57DDA	12/13/1999	J-2 RANGE	OC21B	BIS(2-ETHYLHEXYL) PHTHALATE	95		UG/L	127	137	6
MW-57	W57M1A	12/14/1999	J-2 RANGE	IM40MB	SODIUM	23700		UG/L	102	112	20000
MW-57	W57M2A	12/21/1999	J-2 RANGE	IM40MB	SODIUM	23500		UG/L	62	72	20000
MW-57	W57SSA	12/21/1999	J-2 RANGE	OC21B	BIS(2-ETHYLHEXYL) PHTHALATE	3300	J	UG/L	0	10	6
MW-57	W57M1A	3/7/2000	J-2 RANGE	IM40MB	SODIUM	20900		UG/L	102	112	20000
MW-57	W57M2A	3/22/2000	J-2 RANGE	IM40MB	SODIUM	24500		UG/L	62	72	20000
MW-57	W57M2A	3/22/2000	J-2 RANGE	IM40MB	THALLIUM	4.1	J	UG/L	62	72	2
MW-57	W57M2A	6/30/2000	J-2 RANGE	OC21B	BIS(2-ETHYLHEXYL) PHTHALATE	7		UG/L	62	72	6
MW-57	W57M2A	6/30/2000	J-2 RANGE	IM40MB	SODIUM	25900		UG/L	62	72	20000
MW-57	W57M1A	7/5/2000	J-2 RANGE	IM40MB	SODIUM	22200		UG/L	102	112	20000
MW-57	W57M1A	8/29/2000	J-2 RANGE	IM40MB	SODIUM	20100		UG/L	102	112	20000
MW-57	W57M2A	8/29/2000	J-2 RANGE	IM40MB	SODIUM	23200		UG/L	62	72	20000
MW-57	W57M3A	10/7/2002	J-2 RANGE	IM40MB	SODIUM	21500		UG/L	31	41	20000
MW-57	W57M1A	9/14/2004	J-2 RANGE	IM40MBM	SODIUM	21800		UG/L	102	112	20000
MW-57	W57M3A	10/18/2005	J-2 RANGE	IM40MBM	SODIUM	22100		UG/L	31	41	20000
MW-58	W58SSA	11/23/1999	J-1 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.7	J	UG/L	0	10	2
MW-58	W58SSA	2/15/2000	J-1 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	6		UG/L	0	10	2
MW-58	W58SSA	5/11/2000	J-1 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	7.4	J	UG/L	0	10	2
MW-58	W58SSA	5/11/2000	J-1 RANGE	IM40MB	THALLIUM	7.3	J	UG/L	0	10	2
MW-58	W58SSA	9/5/2000	J-1 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	6.1		UG/L	0	10	2
MW-58	W58SSA	12/20/2000	J-1 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5.1		UG/L	0	10	2
MW-58	W58SSA	12/20/2000	J-1 RANGE	IM40MB	THALLIUM	2	J	UG/L	0	10	2
MW-58	W58SSA	6/14/2001	J-1 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5.3		UG/L	0	10	2
MW-58	W58SSA	8/22/2001	J-1 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5.4		UG/L	0	10	2
MW-58	W58SSA	12/12/2001	J-1 RANGE	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5.8		UG/L	0	10	2
MW-61	W61SSA	8/22/2001	PHASE 2b	IM40MB	THALLIUM	3.7	J	UG/L	0	10	2
MW-64	W64M1A	2/7/2000	GUN & MORTAR	IM40MB	THALLIUM	4.1	J	UG/L	38	48	2
MW-66	W66SSA	9/21/2001	NW CORNER	E314.0	PERCHLORATE	2.2	J	UG/L	7	17	2
MW-66	W66SSA	7/1/2002	NW CORNER	E314.0	PERCHLORATE	2		UG/L	7	17	2
MW-66	W66SSA	8/9/2002	NW CORNER	E314.0	PERCHLORATE	2.9		UG/L	7	17	2
MW-66	W66SSD	8/9/2002	NW CORNER	E314.0	PERCHLORATE	2.3		UG/L	7	17	2
MW-66	W66SSA	1/30/2003	NW CORNER	E314.0	PERCHLORATE	3	J	UG/L	7	17	2
MW-66	W66SSA	4/3/2003	NW CORNER	E314.0	PERCHLORATE	2.5		UG/L	7	17	2
MW-66	W66M2A	2/23/2004	NW CORNER	E314.0	PERCHLORATE	2.3	J	UG/L	22	32	2
MW-66	W66M2D	2/23/2004	NW CORNER	E314.0	PERCHLORATE	2.3	J	UG/L	22	32	2
MW-66	W66SSA	2/23/2004	NW CORNER	E314.0	PERCHLORATE	3.2	J	UG/L	7	17	2
MW-66	W66SSA	5/10/2004	NW CORNER	E314.0	PERCHLORATE	3	J	UG/L	7	17	2
MW-66	W66SSA	8/31/2004	NW CORNER	E314.0	PERCHLORATE	2.7	J	UG/L	7	17	2
MW-7	W07SSA	10/31/1997	CIA	OC21B	BIS(2-ETHYLHEXYL) PHTHALATE	10		UG/L	0	10	6
MW-7	W07MMA	1/23/1998	CIA	IM40MB	ARSENIC	10.7		UG/L	135	140	10
MW-7	W07MML	1/23/1998	CIA	IM40MB	ARSENIC	11.7		UG/L	135	140	10
MW-7	W07M2L	2/5/1998	CIA	IM40MB	THALLIUM	6.6	J	UG/L	65	70	2
MW-7	W07MMA	2/23/1999	CIA	IM40MB	ARSENIC	13.6		UG/L	135	140	10
MW-7	W07MMA	2/23/1999	CIA	IM40MB	THALLIUM	4.1	J	UG/L	135	140	2
MW-7	W07MML	2/23/1999	CIA	IM40MB	ARSENIC	14.7		UG/L	135	140	10
MW-7	W07M2A	2/24/1999	CIA	IM40MB	THALLIUM	4.4	J	UG/L	65	70	2

AOC = Area of Concern  
J = Estimated Result

BWTS = Depth Below Water Table Start (feet)

BWTE = Depth Below Water Table End (feet)

DW Limit = Either the MCL or Lowest Health Advisory Limit

TABLE 4

## VALIDATED DETECTS EXCEEDING MCLs or HEALTH ADVISORY LIMITS 1997 THROUGH September 2008

LOCID/WELL ID	SAMPLE_ID	SAMPLED	AOC	METHOD	ANALYTE	CONC	FLAG	UNITS	BWTS	BWTE	DW LIMIT
MW-7	W07M1A	9/7/1999	CIA	IM40MB	ARSENIC	52.8		UG/L	135	140	10
MW-7	W07M1A	9/7/1999	CIA	IM40MB	CHROMIUM, TOTAL	114		UG/L	135	140	100
MW-7	W07M1A	9/7/1999	CIA	IM40MB	LEAD	40.2		UG/L	135	140	15
MW-7	W07M1A	9/7/1999	CIA	IM40MB	THALLIUM	26.2		UG/L	135	140	2
MW-7	W07M1D	9/7/1999	CIA	IM40MB	ARSENIC	30.7		UG/L	135	140	10
MW-7	W07M1D	9/7/1999	CIA	IM40MB	LEAD	18.3		UG/L	135	140	15
MW-7	W07M1D	9/7/1999	CIA	IM40MB	THALLIUM	12.7		UG/L	135	140	2
MW-7	W07M1L	9/7/1999	CIA	IM40MB	ARSENIC	21.1		UG/L	135	140	10
MW-7	W07M1X	9/7/1999	CIA	IM40MB	ARSENIC	22.1		UG/L	135	140	10
MW-7	W07M1A	5/23/2000	CIA	IM40MB	ARSENIC	13.6		UG/L	135	140	10
MW-7	W07M1A-FL	5/23/2000	CIA	IM40MB	ARSENIC	15.5		UG/L	135	140	10
MW-7	W07M1A	12/1/2000	CIA	IM40MB	ARSENIC	19		UG/L	135	140	10
MW-7	W07M1A	5/24/2001	CIA	IM40MB	ARSENIC	19.4		UG/L	135	140	10
MW-7	W07M1L	5/24/2001	CIA	IM40MB	ARSENIC	17.2		UG/L	135	140	10
MW-7	W07M1A	7/30/2001	CIA	IM40MB	ARSENIC	18		UG/L	135	140	10
MW-7	W07M1L	7/30/2001	CIA	IM40MB	ARSENIC	15		UG/L	135	140	10
MW-7	W07M1A	12/1/2001	CIA	IM40MB	ARSENIC	21.9		UG/L	135	140	10
MW-7	W07M1A	5/15/2002	CIA	IM40MB	ARSENIC	16.7		UG/L	135	140	10
MW-7	W07M1D	5/15/2002	CIA	IM40MB	ARSENIC	17.9		UG/L	135	140	10
MW-7	W07M1A	8/8/2002	CIA	IM40MB	ARSENIC	18.2		UG/L	135	140	10
MW-7	W07M1A	11/22/2002	CIA	IM40MB	ARSENIC	21.3		UG/L	135	140	10
MW-7	W07M1X	11/22/2002	CIA	IM40MB	ARSENIC	17		UG/L	135	140	10
MW-7	W07M1A	7/7/2003	CIA	IM40MB	ARSENIC	22.2		UG/L	135	140	10
MW-7	W07M1A	9/21/2004	CIA	IM40MBM	ARSENIC	12.4		UG/L	135	140	10
MW-7	W07M1A	8/29/2005	CIA	IM40MBM	ARSENIC	14	J	UG/L	135	140	10
MW-70	W70M1A	10/27/1999	OTHER	OC21B	BIS(2-ETHYLHEXYL) PHTHALATE	10		UG/L	129	139	6
MW-72	W72SSA	5/27/1999	SAR	IM40MB	THALLIUM	4		UG/L	0	10	2
MW-73S	W73SSA	7/9/1999	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	50	J	UG/L	0	10	2
MW-73S	W73SSA	9/16/1999	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	63		UG/L	0	10	2
MW-73S	W73SSA	11/2/1999	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	57		UG/L	0	10	2
MW-73S	W73SSA	6/2/2000	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	44		UG/L	0	10	2
MW-73S	W73SSA	9/5/2000	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	29		UG/L	0	10	2
MW-73S	W73SSA	11/14/2000	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	28		UG/L	0	10	2
MW-73S	W73SSD	11/14/2000	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	29		UG/L	0	10	2
MW-73S	W73SSA	12/19/2000	DEMO 1	IM40MB	THALLIUM	4.3		UG/L	0	10	2
MW-73S	W73SSD	12/19/2000	DEMO 1	E314.0	PERCHLORATE	6		UG/L	0	10	2
MW-73S	W73SSD	12/19/2000	DEMO 1	IM40MB	THALLIUM	2	J	UG/L	0	10	2
MW-73S	W73SSA	6/14/2001	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	22		UG/L	0	10	2
MW-73S	W73SSA	6/14/2001	DEMO 1	E314.0	PERCHLORATE	10		UG/L	0	10	2
MW-73S	W73SSA	1/11/2002	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	79		UG/L	0	10	2
MW-73S	W73SSA	1/11/2002	DEMO 1	E314.0	PERCHLORATE	3.3		UG/L	0	10	2
MW-73S	W73SSA	8/20/2002	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	34	J	UG/L	0	10	2
MW-73S	W73SSA	9/27/2003	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	12		UG/L	0	10	2
MW-73S	W73SSA	9/27/2003	DEMO 1	E314.0	PERCHLORATE	3.9		UG/L	0	10	2
MW-73S	W73SSA	2/28/2004	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	18		UG/L	0	10	2
MW-73S	W73SSA	2/28/2004	DEMO 1	E314.0	PERCHLORATE	3	J	UG/L	0	10	2
MW-73S	W73SSA	6/1/2004	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	11		UG/L	0	10	2

AOC = Area of Concern  
J = Estimated Result

BWTS = Depth Below Water Table Start (feet)

BWTE = Depth Below Water Table End (feet)

DW Limit = Either the MCL or Lowest Health Advisory Limit

TABLE 4

## VALIDATED DETECTS EXCEEDING MCLs or HEALTH ADVISORY LIMITS 1997 THROUGH September 2008

LOCID/WELL ID	SAMPLE_ID	SAMPLED	AOC	METHOD	ANALYTE	CONC	FLAG	UNITS	BWTS	BWTE	DW LIMIT
MW-73S	W73SSA	6/1/2004	DEMO 1	E314.0	PERCHLORATE	2.46	J	UG/L	0	10	2
MW-73S	W73SSA	8/8/2005	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	9.3	UG/L	0	10	2	
MW-73S	MW-73S-	2/8/2006	DEMO 1	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	13	UG/L	0	10	2	
MW-73S	MW-73S-	4/12/2006	DEMO 1	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	9.7	UG/L	0	10	2	
MW-73S	MW-73S-FD	4/12/2006	DEMO 1	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	9.7	UG/L	0	10	2	
MW-73S	MW-73S	1/3/2007	DEMO 1	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	9.7	UG/L	0	10	2	
MW-73S	MW-73S	4/30/2007	DEMO 1	SW6010B	ANTIMONY	21.3	J	UG/L	0	10	6
MW-73S	MW-73S	4/30/2007	DEMO 1	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.6	UG/L	0	10	2	
MW-73S	MW-73S-D	4/30/2007	DEMO 1	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.64	UG/L	0	10	2	
MW-73S	1926	12/7/2007		SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.32	UG/L	0	10	2	
MW-73S	1971	4/24/2008	DEMO 1	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.46	UG/L	0	10	2	
MW-73S	1972	4/24/2008	DEMO 1	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.44	UG/L	0	10	2	
MW-75	W75M2A	5/9/2001	DEMO 1	E314.0	PERCHLORATE	9	J	UG/L	34	44	2
MW-75	W75M2D	5/9/2001	DEMO 1	E314.0	PERCHLORATE	9	J	UG/L	34	44	2
MW-75	W75M2A	8/9/2001	DEMO 1	E314.0	PERCHLORATE	6.24	UG/L	34	44	2	
MW-75	W75M2A	1/7/2002	DEMO 1	E314.0	PERCHLORATE	4.08	UG/L	34	44	2	
MW-75	W75M2A	4/25/2002	DEMO 1	E314.0	PERCHLORATE	4.89	UG/L	34	44	2	
MW-75	W75M2A	8/19/2002	DEMO 1	E314.0	PERCHLORATE	2.8	UG/L	34	44	2	
MW-75	W75M2D	8/19/2002	DEMO 1	E314.0	PERCHLORATE	3.2	UG/L	34	44	2	
MW-75	W75M2A	11/18/2002	DEMO 1	E314.0	PERCHLORATE	3.6	J	UG/L	34	44	2
MW-75	W75M2A	3/26/2003	DEMO 1	E314.0	PERCHLORATE	6.8	J	UG/L	34	44	2
MW-75	W75M2A	12/4/2003	DEMO 1	E314.0	PERCHLORATE	4.2	UG/L	34	44	2	
MW-75	W75M2A	2/25/2004	DEMO 1	E314.0	PERCHLORATE	3.08	UG/L	34	44	2	
MW-75	W75M2D	2/25/2004	DEMO 1	E314.0	PERCHLORATE	2.84	UG/L	34	44	2	
MW-75	W75M2A	4/7/2004	DEMO 1	E314.0	PERCHLORATE	2.59	UG/L	34	44	2	
MW-75	W75M2D	4/7/2004	DEMO 1	E314.0	PERCHLORATE	2.46	UG/L	34	44	2	
MW-76M1	W76M1A	12/7/2000	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5.3	UG/L	58	68	2	
MW-76M1	W76M1A	5/7/2001	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	28	UG/L	58	68	2	
MW-76M1	W76M1A	5/7/2001	DEMO 1	E314.0	PERCHLORATE	8	UG/L	58	68	2	
MW-76M1	W76M1A	8/13/2001	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	90	UG/L	58	68	2	
MW-76M1	W76M1A	8/13/2001	DEMO 1	E314.0	PERCHLORATE	16	UG/L	58	68	2	
MW-76M1	W76M1A	12/28/2001	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	110	UG/L	58	68	2	
MW-76M1	W76M1A	12/28/2001	DEMO 1	E314.0	PERCHLORATE	30.6	UG/L	58	68	2	
MW-76M1	W76M1A	4/24/2002	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	79	UG/L	58	68	2	
MW-76M1	W76M1A	4/24/2002	DEMO 1	E314.0	PERCHLORATE	15.3	UG/L	58	68	2	
MW-76M1	W76M1A	8/19/2002	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	14	J	UG/L	58	68	2
MW-76M1	W76M1A	8/19/2002	DEMO 1	E314.0	PERCHLORATE	3.1	UG/L	58	68	2	
MW-76M1	W76M1A	11/18/2002	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.7	UG/L	58	68	2	
MW-76M1	W76M1A	11/18/2002	DEMO 1	E314.0	PERCHLORATE	11	J	UG/L	58	68	2
MW-76M1	W76M1A	3/25/2003	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	110	UG/L	58	68	2	
MW-76M1	W76M1A	3/25/2003	DEMO 1	E314.0	PERCHLORATE	200	J	UG/L	58	68	2
MW-76M1	W76M1A	9/27/2003	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	170	UG/L	58	68	2	
MW-76M1	W76M1A	9/27/2003	DEMO 1	E314.0	PERCHLORATE	97	J	UG/L	58	68	2
MW-76M1	W76M1A	2/24/2004	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	51	UG/L	58	68	2	
MW-76M1	W76M1A	2/24/2004	DEMO 1	E314.0	PERCHLORATE	16.4	UG/L	58	68	2	
MW-76M1	W76M1A	4/21/2004	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	38	UG/L	58	68	2	
MW-76M1	W76M1A	4/21/2004	DEMO 1	E314.0	PERCHLORATE	17.9	UG/L	58	68	2	

AOC = Area of Concern  
J = Estimated Result

BWTS = Depth Below Water Table Start (feet)  
BWTE = Depth Below Water Table End (feet)  
DW Limit = Either the MCL or Lowest Health Advisory Limit

TABLE 4

## VALIDATED DETECTS EXCEEDING MCLs or HEALTH ADVISORY LIMITS 1997 THROUGH September 2008

LOCID/WELL ID	SAMPLE_ID	SAMPLED	AOC	METHOD	ANALYTE	CONC	FLAG	UNITS	BWTS	BWTE	DW LIMIT
MW-76M1	W76M1A	8/11/2004	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	59		UG/L	58	68	2
MW-76M1	W76M1A	8/11/2004	DEMO 1	E314.0	PERCHLORATE	47.3		UG/L	58	68	2
MW-76M1	W76M1A	4/14/2005	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	13		UG/L	58	68	2
MW-76M1	MW-76M1	4/20/2007	DEMO 1	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.9		UG/L	58	68	2
MW-76M2	W76M2A	1/24/2000	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	31		UG/L	38	48	2
MW-76M2	W76M2D	1/24/2000	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	29		UG/L	38	48	2
MW-76M2	W76M2A	5/2/2000	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	37	J	UG/L	38	48	2
MW-76M2	W76M2A	8/2/2000	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	31		UG/L	38	48	2
MW-76M2	W76M2A	12/6/2000	DEMO 1	E314.0	PERCHLORATE	11		UG/L	38	48	2
MW-76M2	W76M2A	12/7/2000	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	46		UG/L	38	48	2
MW-76M2	W76M2A	5/7/2001	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	56		UG/L	38	48	2
MW-76M2	W76M2A	5/7/2001	DEMO 1	E314.0	PERCHLORATE	17		UG/L	38	48	2
MW-76M2	W76M2A	8/13/2001	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	51		UG/L	38	48	2
MW-76M2	W76M2A	8/13/2001	DEMO 1	E314.0	PERCHLORATE	22.1		UG/L	38	48	2
MW-76M2	W76M2D	8/13/2001	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	48		UG/L	38	48	2
MW-76M2	W76M2D	8/13/2001	DEMO 1	E314.0	PERCHLORATE	22.5		UG/L	38	48	2
MW-76M2	W76M2A	1/7/2002	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	92		UG/L	38	48	2
MW-76M2	W76M2A	1/7/2002	DEMO 1	E314.0	PERCHLORATE	126		UG/L	38	48	2
MW-76M2	W76M2A	4/24/2002	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	130		UG/L	38	48	2
MW-76M2	W76M2A	4/24/2002	DEMO 1	E314.0	PERCHLORATE	174		UG/L	38	48	2
MW-76M2	W76M2A	8/19/2002	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	160	J	UG/L	38	48	2
MW-76M2	W76M2A	8/19/2002	DEMO 1	E314.0	PERCHLORATE	250		UG/L	38	48	2
MW-76M2	W76M2A	11/20/2002	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	160		UG/L	38	48	2
MW-76M2	W76M2A	11/20/2002	DEMO 1	E314.0	PERCHLORATE	290		UG/L	38	48	2
MW-76M2	W76M2A	3/26/2003	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	220		UG/L	38	48	2
MW-76M2	W76M2A	3/26/2003	DEMO 1	E314.0	PERCHLORATE	500	J	UG/L	38	48	2
MW-76M2	W76M2D	3/26/2003	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	220		UG/L	38	48	2
MW-76M2	W76M2D	3/26/2003	DEMO 1	E314.0	PERCHLORATE	500	J	UG/L	38	48	2
MW-76M2	W76M2A	12/3/2003	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	150		UG/L	38	48	2
MW-76M2	W76M2A	12/3/2003	DEMO 1	E314.0	PERCHLORATE	210		UG/L	38	48	2
MW-76M2	W76M2A	2/24/2004	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	160		UG/L	38	48	2
MW-76M2	W76M2A	2/24/2004	DEMO 1	E314.0	PERCHLORATE	115		UG/L	38	48	2
MW-76M2	W76M2A	4/22/2004	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	160		UG/L	38	48	2
MW-76M2	W76M2A	4/22/2004	DEMO 1	E314.0	PERCHLORATE	93.1		UG/L	38	48	2
MW-76M2	W76M2A	8/11/2004	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	140		UG/L	38	48	2
MW-76M2	W76M2A	8/11/2004	DEMO 1	E314.0	PERCHLORATE	57.2		UG/L	38	48	2
MW-76M2	W76M2A	4/13/2005	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	62	J	UG/L	38	48	2
MW-76M2	W76M2A	4/13/2005	DEMO 1	E314.0	PERCHLORATE	25	J	UG/L	38	48	2
MW-76M2	MW-76M2-	4/19/2006	DEMO 1	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	28		UG/L	38	48	2
MW-76M2	MW-76M2-	4/19/2006	DEMO 1	E314.0	PERCHLORATE	3.5		UG/L	38	48	2
MW-76M2	MW-76M2	4/23/2007	DEMO 1	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	22.6		UG/L	38	48	2
MW-76M2	1927	12/7/2007		SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	9.44		UG/L	105	115	2
MW-76M2	1978	4/24/2008	DEMO 1	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	22.9		UG/L	105	115	2
MW-76S	W76SSA	1/20/2000	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	11		UG/L	18	28	2
MW-76S	W76SSA	5/2/2000	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	7.5	J	UG/L	18	28	2
MW-76S	W76SSA	8/1/2000	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.1		UG/L	18	28	2
MW-76S	W76SSA	12/7/2000	DEMO 1	E314.0	PERCHLORATE	5		UG/L	18	28	2

AOC = Area of Concern

J = Estimated Result

BWTS = Depth Below Water Table Start (feet)

BWTE = Depth Below Water Table End (feet)

DW Limit = Either the MCL or Lowest Health Advisory Limit

TABLE 4

## VALIDATED DETECTS EXCEEDING MCLs or HEALTH ADVISORY LIMITS 1997 THROUGH September 2008

LOCID/WELL ID	SAMPLE_ID	SAMPLED	AOC	METHOD	ANALYTE	CONC	FLAG	UNITS	BWTS	BWTE	DW LIMIT
MW-76S	W76SSA	5/7/2001	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.1		UG/L	18	28	2
MW-76S	W76SSA	5/7/2001	DEMO 1	E314.0	PERCHLORATE	7		UG/L	18	28	2
MW-76S	W76SSA	8/10/2001	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.5		UG/L	18	28	2
MW-76S	W76SSA	8/10/2001	DEMO 1	E314.0	PERCHLORATE	13.3		UG/L	18	28	2
MW-76S	W76SSA	12/28/2001	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	9.9	J	UG/L	18	28	2
MW-76S	W76SSA	12/28/2001	DEMO 1	E314.0	PERCHLORATE	41.2		UG/L	18	28	2
MW-76S	W76SSA	4/24/2002	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	25		UG/L	18	28	2
MW-76S	W76SSA	4/24/2002	DEMO 1	E314.0	PERCHLORATE	175		UG/L	18	28	2
MW-76S	W76SSA	8/20/2002	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	31	J	UG/L	18	28	2
MW-76S	W76SSA	8/20/2002	DEMO 1	E314.0	PERCHLORATE	88		UG/L	18	28	2
MW-76S	W76SSA	11/18/2002	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	10		UG/L	18	28	2
MW-76S	W76SSA	11/18/2002	DEMO 1	E314.0	PERCHLORATE	26	J	UG/L	18	28	2
MW-76S	W76SSA	9/27/2003	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	18		UG/L	18	28	2
MW-76S	W76SSA	9/27/2003	DEMO 1	E314.0	PERCHLORATE	19		UG/L	18	28	2
MW-76S	W76SSA	2/24/2004	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	28		UG/L	18	28	2
MW-76S	W76SSA	2/24/2004	DEMO 1	E314.0	PERCHLORATE	19.1		UG/L	18	28	2
MW-76S	W76SSA	4/21/2004	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	14		UG/L	18	28	2
MW-76S	W76SSA	4/21/2004	DEMO 1	E314.0	PERCHLORATE	11.3		UG/L	18	28	2
MW-76S	W76SSA	8/11/2004	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.5		UG/L	18	28	2
MW-76S	W76SSA	8/11/2004	DEMO 1	E314.0	PERCHLORATE	2.11		UG/L	18	28	2
MW-76S	W76SSA	4/13/2005	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.9	J	UG/L	18	28	2
MW-76S	W76SSA	4/13/2005	DEMO 1	E314.0	PERCHLORATE	3.2	J	UG/L	18	28	2
MW-76S	MW-76S-	4/19/2006	DEMO 1	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.8		UG/L	18	28	2
MW-76S	MW-76S	4/23/2007	DEMO 1	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	7.88		UG/L	18	28	2
MW-76S	MW-76S	4/23/2007	DEMO 1	E314.0	PERCHLORATE	2.58		UG/L	18	28	2
MW-77M2	W77M2A	1/25/2000	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	150		UG/L	38	48	2
MW-77M2	W77M2A	5/2/2000	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	100	J	UG/L	38	48	2
MW-77M2	W77M2A	8/1/2000	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	97	J	UG/L	38	48	2
MW-77M2	W77M2A	12/6/2000	DEMO 1	E314.0	PERCHLORATE	28		UG/L	38	48	2
MW-77M2	W77M2A	12/7/2000	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	93		UG/L	38	48	2
MW-77M2	W77M2A	5/10/2001	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	39		UG/L	38	48	2
MW-77M2	W77M2A	5/10/2001	DEMO 1	E314.0	PERCHLORATE	16	J	UG/L	38	48	2
MW-77M2	W77M2A	8/10/2001	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	29		UG/L	38	48	2
MW-77M2	W77M2A	8/10/2001	DEMO 1	E314.0	PERCHLORATE	13.9		UG/L	38	48	2
MW-77M2	W77M2A	12/26/2001	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	26		UG/L	38	48	2
MW-77M2	W77M2A	12/26/2001	DEMO 1	E314.0	PERCHLORATE	12.3		UG/L	38	48	2
MW-77M2	W77M2A	4/24/2002	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5.4		UG/L	38	48	2
MW-77M2	W77M2A	4/24/2002	DEMO 1	E314.0	PERCHLORATE	8.01		UG/L	38	48	2
MW-77M2	W77M2A	8/7/2002	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5		UG/L	38	48	2
MW-77M2	W77M2A	8/7/2002	DEMO 1	E314.0	PERCHLORATE	7.2	J	UG/L	38	48	2
MW-77M2	W77M2A	11/19/2002	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	8		UG/L	38	48	2
MW-77M2	W77M2A	11/19/2002	DEMO 1	E314.0	PERCHLORATE	7.2		UG/L	38	48	2
MW-77M2	W77M2A	3/26/2003	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	10		UG/L	38	48	2
MW-77M2	W77M2A	3/26/2003	DEMO 1	E314.0	PERCHLORATE	5.4	J	UG/L	38	48	2
MW-77M2	W77M2A	9/27/2003	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	14		UG/L	38	48	2
MW-77M2	W77M2A	9/27/2003	DEMO 1	E314.0	PERCHLORATE	9.1		UG/L	38	48	2
MW-77M2	W77M2A	2/12/2004	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	12		UG/L	38	48	2

AOC = Area of Concern

J = Estimated Result

BWTS = Depth Below Water Table Start (feet)

BWTE = Depth Below Water Table End (feet)

DW Limit = Either the MCL or Lowest Health Advisory Limit

TABLE 4

## VALIDATED DETECTS EXCEEDING MCLs or HEALTH ADVISORY LIMITS 1997 THROUGH September 2008

LOCID/WELL ID	SAMPLE_ID	SAMPLED	AOC	METHOD	ANALYTE	CONC	FLAG	UNITS	BWTS	BWTE	DW LIMIT
MW-77M2	W77M2A	2/12/2004	DEMO 1	E314.0	PERCHLORATE	5.32		UG/L	38	48	2
MW-77M2	W77M2A	4/5/2004	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	14		UG/L	38	48	2
MW-77M2	W77M2A	4/5/2004	DEMO 1	E314.0	PERCHLORATE	5.7	J	UG/L	38	48	2
MW-77M2	W77M2A	7/28/2004	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	11		UG/L	38	48	2
MW-77M2	W77M2A	7/28/2004	DEMO 1	E314.0	PERCHLORATE	5.1		UG/L	38	48	2
MW-77M2	W77M2D	7/28/2004	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	12		UG/L	38	48	2
MW-77M2	W77M2D	7/28/2004	DEMO 1	E314.0	PERCHLORATE	5.1		UG/L	38	48	2
MW-77M2	W77M2A	4/20/2005	DEMO 1	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	48		UG/L	38	48	2
MW-77M2	W77M2A	4/20/2005	DEMO 1	E314.0	PERCHLORATE	7		UG/L	38	48	2
MW-77M2	MW-77M2-	4/20/2006	DEMO 1	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	94		UG/L	38	48	2
MW-77M2	MW-77M2-	4/20/2006	DEMO 1	E314.0	PERCHLORATE	7.08		UG/L	38	48	2
MW-77M2	MW-77M2	4/23/2007	DEMO 1	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	37.4		UG/L	38	48	2
MW-77M2	MW-77M2	4/23/2007	DEMO 1	E314.0	PERCHLORATE	2.64		UG/L	38	48	2
MW-77M2	1928	12/6/2007		SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	54.8		UG/L	120	130	2
MW-77M2	1928	12/6/2007	DEMO 1	E314.0	PERCHLORATE	3.64		UG/L	38	48	2
MW-77M2	1981	4/25/2008	DEMO 1	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	37.4		UG/L	120	130	2
MW-77M2	1981	4/25/2008	DEMO 1	E314.0	PERCHLORATE	2.28		UG/L	38	48	2
MW-78	W78M2A	12/6/2000	DEMO 1	E314.0	PERCHLORATE	19		UG/L	38	48	2
MW-78	W78M2A	5/10/2001	DEMO 1	E314.0	PERCHLORATE	9	J	UG/L	38	48	2
MW-78	W78M2A	8/15/2001	DEMO 1	E314.0	PERCHLORATE	11.4		UG/L	38	48	2
MW-78	W78M2A	12/28/2001	DEMO 1	E314.0	PERCHLORATE	4.43		UG/L	38	48	2
MW-78	W78M1A	4/25/2002	DEMO 1	E314.0	PERCHLORATE	2.07		UG/L	58	68	2
MW-78	W78M2A	4/25/2002	DEMO 1	E314.0	PERCHLORATE	4.75		UG/L	38	48	2
MW-78	W78M1A	8/20/2002	DEMO 1	E314.0	PERCHLORATE	4.6	J	UG/L	58	68	2
MW-78	W78M1D	8/20/2002	DEMO 1	E314.0	PERCHLORATE	3	J	UG/L	58	68	2
MW-78	W78M2A	8/20/2002	DEMO 1	E314.0	PERCHLORATE	6.3	J	UG/L	38	48	2
MW-78	W78M1A	11/20/2002	DEMO 1	E314.0	PERCHLORATE	4.1		UG/L	58	68	2
MW-78	W78M2A	11/20/2002	DEMO 1	E314.0	PERCHLORATE	8.7		UG/L	38	48	2
MW-78	W78M1A	3/26/2003	DEMO 1	E314.0	PERCHLORATE	4.9	J	UG/L	58	68	2
MW-78	W78M2A	3/27/2003	DEMO 1	E314.0	PERCHLORATE	4.7	J	UG/L	38	48	2
MW-78	W78M1A	12/4/2003	DEMO 1	E314.0	PERCHLORATE	5.3		UG/L	58	68	2
MW-78	W78M2A	12/4/2003	DEMO 1	E314.0	PERCHLORATE	11		UG/L	38	48	2
MW-78	W78M1A	2/23/2004	DEMO 1	E314.0	PERCHLORATE	4.83		UG/L	58	68	2
MW-78	W78M2A	2/24/2004	DEMO 1	E314.0	PERCHLORATE	8.34		UG/L	38	48	2
MW-78	W78M2D	2/24/2004	DEMO 1	E314.0	PERCHLORATE	8.18	J	UG/L	38	48	2
MW-78	W78M1A	4/6/2004	DEMO 1	E314.0	PERCHLORATE	4.37		UG/L	58	68	2
MW-78	W78M2A	4/6/2004	DEMO 1	E314.0	PERCHLORATE	8.2		UG/L	38	48	2
MW-78	W78M1A	8/11/2004	DEMO 1	E314.0	PERCHLORATE	2.84		UG/L	58	68	2
MW-78	W78M2A	8/12/2004	DEMO 1	E314.0	PERCHLORATE	6.48		UG/L	38	48	2
MW-78	W78M1A	4/20/2005	DEMO 1	E314.0	PERCHLORATE	2.1		UG/L	58	68	2
MW-78	W78M2A	4/20/2005	DEMO 1	E314.0	PERCHLORATE	3.5		UG/L	38	48	2
MW-80	W80M1A	4/4/2002	WESTERN BOUNDARY	E314.0	PERCHLORATE	2.26	J	UG/L	86	96	2
MW-82	W82DDA	8/22/2001	WESTERN BOUNDARY	SW8270	BIS(2-ETHYLHEXYL) PHTHALATE	24		UG/L	97	107	6
MW-83	W83SSA	1/13/2000	WESTERN BOUNDARY	IM40MB	THALLIUM	3.6	J	UG/L	0	10	2
MW-84	W84SSA	10/21/1999	WESTERN BOUNDARY	IM40MB	THALLIUM	3.2	J	UG/L	17	27	2
MW-84	W84DDA	3/3/2000	WESTERN BOUNDARY	OC21B	BIS(2-ETHYLHEXYL) PHTHALATE	30		UG/L	153	163	6
MW-84	W84DDA	8/23/2001	WESTERN BOUNDARY	IM40MB	THALLIUM	4	J	UG/L	153	163	2

AOC = Area of Concern  
J = Estimated Result

BWTS = Depth Below Water Table Start (feet)

BWTE = Depth Below Water Table End (feet)

DW Limit = Either the MCL or Lowest Health Advisory Limit

TABLE 4

## VALIDATED DETECTS EXCEEDING MCLs or HEALTH ADVISORY LIMITS 1997 THROUGH September 2008

LOCID/WELL ID	SAMPLE_ID	SAMPLED	AOC	METHOD	ANALYTE	CONC	FLAG	UNITS	BWTS	BWTE	DW LIMIT
MW-84	W84M3A	8/27/2001	WESTERN BOUNDARY	IM40MB	THALLIUM	5	J	UG/L	42	52	2
MW-85	W85M1A	5/22/2000	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	29		UG/L	22	32	2
MW-85	W85M1A	2/10/2001	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	24		UG/L	22	32	2
MW-85	W85M1A	6/16/2001	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	27		UG/L	22	32	2
MW-85	W85M1A	9/26/2001	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	13		UG/L	22	32	2
MW-85	W85M1A	12/15/2001	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	19		UG/L	22	32	2
MW-85	W85M1A	5/22/2002	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	7		UG/L	22	32	2
MW-85	W85M1A	9/12/2002	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.2		UG/L	22	32	2
MW-85	W85M1A	4/1/2003	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	8		UG/L	22	32	2
MW-85	W85M1A	3/2/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.2		UG/L	22	32	2
MW-85	W85M1D	3/2/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.1		UG/L	22	32	2
MW-86	W86SSA	4/28/2000	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.5	J	UG/L	1	11	2
MW-86	W86M2A	9/27/2001	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3		UG/L	16	26	2
MW-86	W86M2A	11/30/2001	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.7		UG/L	16	26	2
MW-86	W86M2A	5/16/2002	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.1		UG/L	16	26	2
MW-86	W86SSA	8/16/2002	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.7	J	UG/L	1	11	2
MW-86	W86SSA	7/12/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.7		UG/L	1	11	2
MW-86	W86SSA	9/29/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.4		UG/L	1	11	2
MW-86	W86SSA	12/15/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.6		UG/L	1	11	2
MW-86	W86SSA	3/31/2005	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.1		UG/L	1	11	2
MW-87M1	W87M1A	4/28/2000	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	6.5	J	UG/L	62	72	2
MW-87M1	W87M1A	9/14/2000	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5		UG/L	62	72	2
MW-87M1	W87M1A	1/10/2001	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.6		UG/L	62	72	2
MW-87M1	W87M1A	9/27/2001	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5		UG/L	62	72	2
MW-87M1	W87M1A	12/3/2001	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5.2		UG/L	62	72	2
MW-87M1	W87M1A	5/17/2002	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5.2		UG/L	62	72	2
MW-87M1	W87M1A	10/4/2002	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.4		UG/L	62	72	2
MW-87M1	W87M1A	1/15/2003	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.4		UG/L	62	72	2
MW-87M1	W87M1A	4/7/2003	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.1		UG/L	62	72	2
MW-87M1	W87M1A	10/17/2003	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.1		UG/L	62	72	2
MW-87M1	W87M1A	8/18/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2		UG/L	62	72	2
MW-87M1	W87M1A	5/3/2005	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.1	J	UG/L	62	72	2
MW-87M1	W87M1A	10/28/2005	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2		UG/L	62	72	2
MW-87M1	MW-87M1	10/23/2007	CIA	E314.0	PERCHLORATE	2.8		ug/L	62	72	2
MW-87M1	MW-87M1_SPR08	5/29/2008	CIA [108]	SW6850	PERCHLORATE	3.7		UG/L	194	204	2
MW-87M1	MW-87M1_SPR08D	5/29/2008	CIA [108]	SW6850	PERCHLORATE	3.8		UG/L	194	204	2
MW-88M2	W88M2A	5/24/2000	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	7		UG/L	72	82	2
MW-88M2	W88M2A	9/21/2000	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	7.7		UG/L	72	82	2
MW-88M2	W88M2A	1/10/2001	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	6.8		UG/L	72	82	2
MW-88M2	W88M2A	9/28/2001	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	6.4		UG/L	72	82	2
MW-88M2	W88M2A	12/4/2001	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	6.5		UG/L	72	82	2
MW-88M2	W88M2A	5/17/2002	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	6.1		UG/L	72	82	2
MW-88M2	W88M2A	10/4/2002	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5.6		UG/L	72	82	2
MW-88M2	W88M2A	1/16/2003	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5.1		UG/L	72	82	2
MW-88M2	W88M2A	4/2/2003	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.5		UG/L	72	82	2
MW-88M2	W88M2A	10/16/2003	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.4		UG/L	72	82	2
MW-88M2	W88M2A	1/22/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.1		UG/L	72	82	2

AOC = Area of Concern  
J = Estimated Result

BWTS = Depth Below Water Table Start (feet)

BWTE = Depth Below Water Table End (feet)

DW Limit = Either the MCL or Lowest Health Advisory Limit

TABLE 4

## VALIDATED DETECTS EXCEEDING MCLs or HEALTH ADVISORY LIMITS 1997 THROUGH September 2008

LOCID/WELL ID	SAMPLE_ID	SAMPLED	AOC	METHOD	ANALYTE	CONC	FLAG	UNITS	BWTS	BWTE	DW LIMIT
MW-88M2	W88M2A	4/27/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.7		UG/L	72	82	2
MW-88M2	W88M2D	4/27/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.7		UG/L	72	82	2
MW-88M2	W88M2A	8/20/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.6		UG/L	72	82	2
MW-88M2	W88M2A	12/29/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.4		UG/L	72	82	2
MW-88M2	W88M2D	12/29/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.4		UG/L	72	82	2
MW-88M2	W88M2A	4/28/2005	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.3		UG/L	72	82	2
MW-88M2	W88M2A	9/20/2005	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.2	J	UG/L	72	82	2
MW-88M2	W88M2A	12/6/2005	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.1		UG/L	72	82	2
MW-88M2	W88M2A	10/16/2006	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3		UG/L	72	82	2
MW-88M2	MW-88M2	10/19/2007	CIA	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.8		ug/L	72	82	2
MW-88M2	MW-88M2	10/19/2007	CIA	E314.0	PERCHLORATE	2.5		ug/L	72	82	2
MW-88M2	MW-88M2_FD	10/19/2007	CIA	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.8		ug/L	72	82	2
MW-88M2	MW-88M2_FD	10/19/2007	CIA	E314.0	PERCHLORATE	2.6		ug/L	72	82	2
MW-88M2	MW-88M2_SPR08	6/2/2008	CIA [108]	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.5		UG/L	213	223	2
MW-88M2	MW-88M2_SPR08	6/2/2008	CIA [108]	SW6850	PERCHLORATE	3.1		UG/L	213	223	2
MW-89M1	W89M1A	9/28/2001	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.1		UG/L	92	102	2
MW-89M1	W89M1A	12/4/2001	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.4		UG/L	92	102	2
MW-89M1	W89M1A	5/17/2002	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.3		UG/L	92	102	2
MW-89M1	W89M1A	10/10/2003	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.7		UG/L	92	102	2
MW-89M1	W89M1A	12/20/2005	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.3		UG/L	92	102	2
MW-89M2	W89M2A	5/26/2000	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	8.3		UG/L	72	82	2
MW-89M2	W89M2A	9/21/2000	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	8.3		UG/L	72	82	2
MW-89M2	W89M2A	1/11/2001	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	7.5		UG/L	72	82	2
MW-89M2	W89M2A	10/3/2001	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	6.8		UG/L	72	82	2
MW-89M2	W89M2D	10/3/2001	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	6.9		UG/L	72	82	2
MW-89M2	W89M2A	12/3/2001	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	6.9		UG/L	72	82	2
MW-89M2	W89M2A	5/17/2002	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	6		UG/L	72	82	2
MW-89M2	W89M2A	10/4/2002	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5.6		UG/L	72	82	2
MW-89M2	W89M2A	1/16/2003	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5.6		UG/L	72	82	2
MW-89M2	W89M2A	4/17/2003	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5.7		UG/L	72	82	2
MW-89M2	W89M2A	10/10/2003	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	6.2		UG/L	72	82	2
MW-89M2	W89M2A	1/23/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	6.8		UG/L	72	82	2
MW-89M2	W89M2A	4/27/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	6.9		UG/L	72	82	2
MW-89M2	W89M2A	10/5/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	9.2		UG/L	72	82	2
MW-89M2	W89M2A	11/22/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	9.9		UG/L	72	82	2
MW-89M2	W89M2A	3/28/2005	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	10		UG/L	72	82	2
MW-89M2	W89M2A	9/13/2005	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	13	J	UG/L	72	82	2
MW-89M2	W89M2A	9/13/2005	CIA	E314.0	PERCHLORATE	2.2		UG/L	72	82	2
MW-89M2	W89M2A	12/20/2005	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	12		UG/L	72	82	2
MW-89M2	W89M2A	4/18/2006	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	12		UG/L	72	82	2
MW-89M2	W89M2D	4/18/2006	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	12		UG/L	72	82	2
MW-89M2	W89M2A	11/2/2006	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	14		UG/L	72	82	2
MW-89M2	W89M2A	11/2/2006	CIA	E314.0	PERCHLORATE	4.4		UG/L	72	82	2
MW-89M2	MW-89M2	10/23/2007	CIA	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	18		ug/L	72	82	2
MW-89M2	MW-89M2	10/23/2007	CIA	E314.0	PERCHLORATE	5.5		ug/L	72	82	2
MW-89M2	MW-89M2_SPR08	6/3/2008	CIA [108]	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	19		UG/L	214	224	2
MW-89M2	MW-89M2_SPR08	6/3/2008	CIA [108]	SW6850	PERCHLORATE	6.5		UG/L	214	224	2

AOC = Area of Concern  
J = Estimated Result

BWTS = Depth Below Water Table Start (feet)  
BWTE = Depth Below Water Table End (feet)  
DW Limit = Either the MCL or Lowest Health Advisory Limit

TABLE 4

## VALIDATED DETECTS EXCEEDING MCLs or HEALTH ADVISORY LIMITS 1997 THROUGH September 2008

LOCID/WELL ID	SAMPLE_ID	SAMPLED	AOC	METHOD	ANALYTE	CONC	FLAG	UNITS	BWTS	BWTE	DW LIMIT
MW-89M2	MW-89M2_SPR08D	6/3/2008	CIA [108]	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	19		UG/L	214	224	2
MW-89M2	MW-89M2_SPR08D	6/3/2008	CIA [108]	SW6850	PERCHLORATE	6.6		UG/L	214	224	2
MW-90	W90SSA	5/19/2000	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.4	J	UG/L	0	10	2
MW-90	W90M1A	10/11/2000	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.4		UG/L	27	37	2
MW-90	W90SSA	1/23/2003	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.6		UG/L	0	10	2
MW-91M1	W91M1A	5/22/2000	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	18		UG/L	45	55	2
MW-91M1	W91M1A	11/7/2000	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	11		UG/L	45	55	2
MW-91M1	W91M1D	11/7/2000	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	11		UG/L	45	55	2
MW-91M1	W91M1A	1/20/2001	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	12		UG/L	45	55	2
MW-91M1	W91M1A	10/3/2001	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	13	J	UG/L	45	55	2
MW-91M1	W91M1A	11/29/2001	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	10	J	UG/L	45	55	2
MW-91M1	W91M1A	5/20/2002	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5.3		UG/L	45	55	2
MW-91M1	W91M1D	5/20/2002	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5.5		UG/L	45	55	2
MW-91M1	W91M1A	9/27/2002	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.6		UG/L	45	55	2
MW-91M1	W91M1A	1/31/2003	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.6		UG/L	45	55	2
MW-91M1	W91M1A	5/19/2003	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.3		UG/L	45	55	2
MW-91M1	W91M1A	11/14/2003	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5.7		UG/L	45	55	2
MW-91M1	W91M1A	2/20/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	6		UG/L	45	55	2
MW-91M1	W91M1D	2/20/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	6.1		UG/L	45	55	2
MW-91M1	W91M1A	5/5/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5.6		UG/L	45	55	2
MW-91M1	W91M1A	9/28/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.5		UG/L	45	55	2
MW-91M1	W91M1A	11/10/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.5		UG/L	45	55	2
MW-91M1	W91M1A	4/29/2005	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4		UG/L	45	55	2
MW-91M1	W91M1A	11/10/2005	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5		UG/L	45	55	2
MW-91M1	W91M1A	1/24/2006	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	6.2		UG/L	45	55	2
MW-91M1	W91M1D	1/24/2006	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	6.1		UG/L	45	55	2
MW-91M1	W91M1A	4/19/2006	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	6.7		UG/L	45	55	2
MW-91M1	W91M1A	11/15/2006	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	10		UG/L	45	55	2
MW-91M1	W91M1	11/19/2007	CIA	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	11		ug/L	170	180	2
MW-91M1	MW-91M1_SPR08	6/6/2008	CIA [108]	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	13		UG/L	170	180	2
MW-91S	W91SSA	5/19/2000	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	12		UG/L	0	10	2
MW-91S	W91SSA	11/7/2000	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	13		UG/L	0	10	2
MW-91S	W91SSA	1/20/2001	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	12		UG/L	0	10	2
MW-91S	W91SSA	1/20/2001	CIA	E314.0	PERCHLORATE	5	J	UG/L	0	10	2
MW-91S	W91SSA	10/9/2001	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	14		UG/L	0	10	2
MW-91S	W91SSA	10/9/2001	CIA	E314.0	PERCHLORATE	3.22	J	UG/L	0	10	2
MW-91S	W91SSA	12/20/2001	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	20		UG/L	0	10	2
MW-91S	W91SSA	12/20/2001	CIA	E314.0	PERCHLORATE	3.83	J	UG/L	0	10	2
MW-91S	W91SSA	5/20/2002	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	17		UG/L	0	10	2
MW-91S	W91SSA	5/20/2002	CIA	E314.0	PERCHLORATE	4		UG/L	0	10	2
MW-91S	W91SSA	1/31/2003	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	17		UG/L	0	10	2
MW-91S	W91SSA	1/31/2003	CIA	E314.0	PERCHLORATE	2.8	J	UG/L	0	10	2
MW-91S	W91SSA	5/21/2003	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	12		UG/L	0	10	2
MW-91S	W91SSA	5/21/2003	CIA	E314.0	PERCHLORATE	2.9		UG/L	0	10	2
MW-91S	W91SSA	11/14/2003	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	16		UG/L	0	10	2
MW-91S	W91SSA	2/20/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	13		UG/L	0	10	2
MW-91S	W91SSA	2/20/2004	CIA	E314.0	PERCHLORATE	2	J	UG/L	0	10	2

AOC = Area of Concern  
J = Estimated Result

BWTS = Depth Below Water Table Start (feet)

BWTE = Depth Below Water Table End (feet)

DW Limit = Either the MCL or Lowest Health Advisory Limit

TABLE 4

## VALIDATED DETECTS EXCEEDING MCLs or HEALTH ADVISORY LIMITS 1997 THROUGH September 2008

LOCID/WELL ID	SAMPLE_ID	SAMPLED	AOC	METHOD	ANALYTE	CONC	FLAG	UNITS	BWTS	BWTE	DW LIMIT
MW-91S	W91SSA	5/5/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	10		UG/L	0	10	2
MW-91S	W91SSA	9/28/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	12		UG/L	0	10	2
MW-91S	W91SSA	11/12/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	11		UG/L	0	10	2
MW-91S	W91SSA	4/29/2005	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	12		UG/L	0	10	2
MW-91S	W91SSA	11/15/2005	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	16	J	UG/L	0	10	2
MW-91S	W91SSA	1/24/2006	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	24		UG/L	0	10	2
MW-91S	W91SSA	4/19/2006	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	24		UG/L	0	10	2
MW-91S	MW-91S_SPR08	6/6/2008	CIA [108]	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.8		UG/L	124	134	2
MW-91S	MW-91S_SPR08D	6/6/2008	CIA [108]	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5		UG/L	124	134	2
MW-93	W93M1A	5/26/2000	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.2	J	UG/L	56	66	2
MW-93	W93M2A	5/26/2000	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5.2		UG/L	16	26	2
MW-93	W93M1A	11/7/2000	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.5		UG/L	56	66	2
MW-93	W93M2A	11/7/2000	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.2		UG/L	16	26	2
MW-93	W93M1A	1/20/2001	CIA	E314.0	PERCHLORATE	3	J	UG/L	56	66	2
MW-93	W93M1D	1/20/2001	CIA	E314.0	PERCHLORATE	2	J	UG/L	56	66	2
MW-93	W93M2A	1/20/2001	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.1	J	UG/L	16	26	2
MW-93	W93M2A	1/20/2001	CIA	E314.0	PERCHLORATE	2	J	UG/L	16	26	2
MW-93	W93M1A	1/22/2001	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.4	J	UG/L	56	66	2
MW-93	W93M1D	1/22/2001	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.4		UG/L	56	66	2
MW-93	W93M1A	10/3/2001	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.2		UG/L	56	66	2
MW-93	W93M2A	10/3/2001	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	9.9		UG/L	16	26	2
MW-93	W93M1A	11/28/2001	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.8		UG/L	56	66	2
MW-93	W93M2A	11/28/2001	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	12		UG/L	16	26	2
MW-93	W93M1A	5/20/2002	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.6		UG/L	56	66	2
MW-93	W93M2A	5/20/2002	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	8.7		UG/L	16	26	2
MW-93	W93M1A	9/24/2002	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.9		UG/L	56	66	2
MW-93	W93M2A	9/27/2002	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.5	J	UG/L	16	26	2
MW-93	W93M1A	2/3/2003	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5.7		UG/L	56	66	2
MW-93	W93M2A	2/3/2003	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.7		UG/L	16	26	2
MW-93	W93M2D	2/3/2003	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.7		UG/L	16	26	2
MW-93	W93M2A	3/28/2003	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.2		UG/L	16	26	2
MW-93	W93M1A	3/31/2003	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5.8		UG/L	56	66	2
MW-93	W93M1A	10/22/2003	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.2		UG/L	56	66	2
MW-93	W93M2A	10/23/2003	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2		UG/L	16	26	2
MW-93	W93M1A	2/9/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.2		UG/L	56	66	2
MW-93	W93M2A	4/30/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.4		UG/L	16	26	2
MW-93	W93M1A	7/15/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.6		UG/L	56	66	2
MW-93	W93M1D	7/15/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.5		UG/L	56	66	2
MW-93	W93M2A	9/28/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3		UG/L	16	26	2
MW-93	W93M2A	11/12/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.7		UG/L	16	26	2
MW-93	W93M2A	4/28/2005	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.9		UG/L	16	26	2
MW-93	W93M2A	1/19/2006	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2		UG/L	16	26	2
MW-93	W93M2D	1/19/2006	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2		UG/L	16	26	2
MW-94	W94M2A	1/11/2001	CIA	IM40MB	THALLIUM	2	J	UG/L	16	26	2
MW-94	W94M2A	10/2/2001	CIA	IM40MB	THALLIUM	2.3	J	UG/L	16	26	2
MW-95M1	W95M1A	5/25/2000	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.2		UG/L	78	88	2
MW-95M1	W95M1A	10/1/2001	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.2		UG/L	78	88	2

AOC = Area of Concern

J = Estimated Result

BWTS = Depth Below Water Table Start (feet)

BWTE = Depth Below Water Table End (feet)

DW Limit = Either the MCL or Lowest Health Advisory Limit

TABLE 4

## VALIDATED DETECTS EXCEEDING MCLs or HEALTH ADVISORY LIMITS 1997 THROUGH September 2008

LOCID/WELL ID	SAMPLE_ID	SAMPLED	AOC	METHOD	ANALYTE	CONC	FLAG	UNITS	BWTS	BWTE	DW LIMIT
MW-95M1	W95M1A	12/15/2001	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.2		UG/L	78	88	2
MW-95M1	W95M1A	5/20/2002	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	6.1		UG/L	78	88	2
MW-95M1	W95M1D	5/20/2002	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	6.2		UG/L	78	88	2
MW-95M1	W95M1A	9/27/2002	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5.4		UG/L	78	88	2
MW-95M1	W95M1A	2/4/2003	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.1		UG/L	78	88	2
MW-95M1	W95M1A	4/11/2003	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.5		UG/L	78	88	2
MW-95M1	W95M1D	4/11/2003	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.6		UG/L	78	88	2
MW-95M1	W95M1A	10/15/2003	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5.5		UG/L	78	88	2
MW-95M1	W95M1A	2/20/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5.1		UG/L	78	88	2
MW-95M1	W95M1A	4/30/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5.5		UG/L	78	88	2
MW-95M1	W95M1A	8/27/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5.1		UG/L	78	88	2
MW-95M1	W95M1A	12/30/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5.2		UG/L	78	88	2
MW-95M1	W95M1A	5/5/2005	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5.3		UG/L	78	88	2
MW-95M1	W95M1A	8/31/2005	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.9		UG/L	78	88	2
MW-95M1	W95M1A	12/6/2005	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.9		UG/L	78	88	2
MW-95M1	W95M1D	12/6/2005	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.9		UG/L	78	88	2
MW-95M1	W95M1A	4/18/2006	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.5		UG/L	78	88	2
MW-95M1	W95M1A	10/17/2006	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3		UG/L	78	88	2
MW-95M1	MW-95M1	10/23/2007	CIA	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.5		ug/L	78	88	2
MW-95M1	MW-95M1_SPR08	6/2/2008	CIA [108]	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.9		UG/L	202	212	2
MW-98	W98M1A	5/25/2000	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.1		UG/L	26	36	2
MW-99	W99M1A	5/25/2000	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	6.9		UG/L	60	70	2
MW-99	W99M1D	5/25/2000	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	6.9		UG/L	60	70	2
MW-99	W99M1A	9/29/2000	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5		UG/L	60	70	2
MW-99	W99M1A	1/13/2001	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.2		UG/L	60	70	2
MW-99	W99M1A	6/2/2003	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.4		UG/L	60	70	2
MW-99	W99M1A	10/2/2003	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.2		UG/L	60	70	2
OW-1	WOW-1A	11/15/2001	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.3		UG/L	0	10	2
OW-1	WOW-1A	11/15/2001	CIA	E314.0	PERCHLORATE	2.92		UG/L	0	10	2
OW-1	WOW-1A	5/21/2002	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.2		UG/L	0	10	2
OW-1	WOW-1A	5/21/2002	CIA	E314.0	PERCHLORATE	2.07	J	UG/L	0	10	2
OW-1	WOW-1D	5/21/2002	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.5		UG/L	0	10	2
OW-1	WOW-1D	5/21/2002	CIA	E314.0	PERCHLORATE	2.15	J	UG/L	0	10	2
OW-1	OW-1-A	9/4/2002	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4		UG/L	0	10	2
OW-1	OW-1-A	1/16/2003	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.2		UG/L	0	10	2
OW-1	OW-1-A	1/16/2003	CIA	E314.0	PERCHLORATE	3.2		UG/L	0	10	2
OW-1	OW-1-A	11/13/2003	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3		UG/L	0	10	2
OW-1	OW-1-A	3/2/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.6		UG/L	0	10	2
OW-1	OW-1-A	9/28/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.3		UG/L	0	10	2
OW-2	WOW-2A	11/14/2001	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3		UG/L	48.78	58.78	2
OW-2	WOW-2A	5/21/2002	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	8.2		UG/L	48.78	58.78	2
OW-2	OW-2-A	8/30/2002	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	14		UG/L	48.78	58.78	2
OW-2	OW-2-A	1/23/2003	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	8.6		UG/L	48.78	58.78	2
OW-2	OW-2-A	11/13/2003	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	14		UG/L	48.78	58.78	2
OW-2	OW-2-A	3/2/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	16		UG/L	48.78	58.78	2
OW-2	OW-2-A	9/28/2004	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	10		UG/L	48.78	58.78	2
OW-2	OW-2-A	11/21/2005	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4		UG/L	48.78	58.78	2

AOC = Area of Concern  
J = Estimated Result

BWTS = Depth Below Water Table Start (feet)

BWTE = Depth Below Water Table End (feet)

DW Limit = Either the MCL or Lowest Health Advisory Limit

TABLE 4

## VALIDATED DETECTS EXCEEDING MCLs or HEALTH ADVISORY LIMITS 1997 THROUGH September 2008

LOCID/WELL ID	SAMPLE_ID	SAMPLED	AOC	METHOD	ANALYTE	CONC	FLAG	UNITS	BWTS	BWTE	DW LIMIT
OW-2	OW-2-A	11/16/2006	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.4		UG/L	48.78	58.78	2
OW-2	OW-2-D	11/16/2006	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.4		UG/L	48.78	58.78	2
OW-2	OW-2	5/23/2007	CIA	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5		UG/L	48.78	58.78	2
OW-2	OW-2	11/30/2007	CIA	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.3		ug/L	48.78	58.78	2
OW-2	OW-2_SPR08	5/30/2008	CIA [108]	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	4.3		UG/L	175	185	2
OW-6	WOW-6A	11/14/2001	CIA	8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	2.3		UG/L	46.8	56.8	2
PPAWSMW-1	PPAWSMW-1	6/22/1999	OTHER	OL21P	DIELDRIN	3		UG/L	0	10	0.5
PPAWSMW-1	PPAWSMW-1	6/22/1999	OTHER	IM40MB	THALLIUM	3.1	J	UG/L	0	10	2
PPAWSMW-3	PPAWSMW-3	8/12/1999	OTHER	IM40MB	ANTIMONY	6	J	UG/L	0	10	6
RS003P	RS003P-A	2/22/2005	J-2 RANGE	E314.0	PERCHLORATE	2.1		UG/L			2
RSNW03	RSNW03-A	7/7/2004	NW CORNER	E314.0	PERCHLORATE	2.01	J	UG/L			2
RSNW03	RSNW03-A	9/9/2004	NW CORNER	E314.0	PERCHLORATE	2.07		UG/L			2
RW-1	WRW1XA	2/18/1998	OTHER	OC21B	BIS(2-ETHYLHEXYL) PHTHALATE	59		UG/L	0	9	6
RW-1	WRW1XD	10/6/1999	OTHER	OC21B	BIS(2-ETHYLHEXYL) PHTHALATE	11	J	UG/L	0	9	6
SDW261160	WG160L	1/7/1998	OTHER	IM40MB	SODIUM	20600		UG/L	10	20	20000
SDW261160	WG160A	1/13/1999	OTHER	IM40MB	SODIUM	27200		UG/L	10	20	20000
SDW261160	WG160L	1/13/1999	OTHER	IM40MB	SODIUM	28200		UG/L	10	20	20000
SMR-2	WSMR2A	3/25/1999	J-2 RANGE	IM40MB	THALLIUM	2	J	UG/L	19	29	2
XX95-14	W9514A	9/28/1999	WESTERN BOUNDARY	OC21B	BIS(2-ETHYLHEXYL) PHTHALATE	22		UG/L	90	100	6
XX95-14	W9514A	9/28/1999	WESTERN BOUNDARY	IM40MB	ZINC	2430		UG/L	90	100	2000

AOC = Area of Concern  
J = Estimated Result

BWTS = Depth Below Water Table Start (feet)

BWTE = Depth Below Water Table End (feet)

DW Limit = Either the MCL or Lowest Health Advisory Limit

**TABLE 5**  
**VALIDATED EXPLOSIVE AND PERCHLORATE RESULTS**  
Data Received September 2008

Location	Field Sample Id	Logdate	Area of Concern	Method	Analyte	Result Value	EPA Flags	Units	MDL	RL	Top Depth	Bot. Depth	DW LIMIT	> DW LIMIT
MW-250M2	MW-250M2_FAL08	8/7/2008	J3 [150]	E314.0	PERCHLORATE	7.83		UG/L	0.35	1	145	155	2	X
MW-142M2	MW-142M2_FAL08	8/8/2008	J3 [150]	E314.0	PERCHLORATE	12.5		UG/L	0.35	1	140	150	2	X
MW-142M2	MW-142M2_FAL08	8/8/2008	J3 [150]	SW8330	OCTAHYDRO-1,3,5,7-TETRANITRO-1,3,5,7-TETRAZOCINE	3.65		UG/L	0.083	0.208	140	150	400	
90PZ0211	90PZ0211_FAL08	8/11/2008	J3 [150]	E314.0	PERCHLORATE	0.528	J	UG/L	0.35	1	83	103		
90PZ0211	90PZ0211_FAL08D	8/11/2008	J3 [150]	E314.0	PERCHLORATE	0.706	J	UG/L	0.35	1	83	103		
MW-163S	MW-163S_FAL08	8/11/2008	J3 [150]	E314.0	PERCHLORATE	2.73		UG/L	0.35	1	38	48	2	X
MW-163S	MW-163S_FAL08D	8/11/2008	J3 [150]	E314.0	PERCHLORATE	2.74		UG/L	0.35	1	38	48	2	X
90PZ0211	90PZ0211_FAL08	8/11/2008	J3 [150]	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	1.4		UG/L	0.095	0.215	83	103	2	
90PZ0211	90PZ0211_FAL08D	8/11/2008	J3 [150]	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	1.37		UG/L	0.094	0.213	83	103	2	
MW-163S	MW-163S_FAL08	8/11/2008	J3 [150]	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.57		UG/L	0.093	0.21	38	48	2	X
MW-163S	MW-163S_FAL08	8/11/2008	J3 [150]	SW8330	OCTAHYDRO-1,3,5,7-TETRANITRO-1,3,5,7-TETRAZOCINE	1.05		UG/L	0.084	0.21	38	48	400	
MW-163S	MW-163S_FAL08D	8/11/2008	J3 [150]	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.79		UG/L	0.092	0.208	38	48	2	X
MW-163S	MW-163S_FAL08D	8/11/2008	J3 [150]	SW8330	OCTAHYDRO-1,3,5,7-TETRANITRO-1,3,5,7-TETRAZOCINE	1.08		UG/L	0.083	0.208	38	48	400	
MW-143M1	MW-143M1_FAL08	8/13/2008	J3 [150]	E314.0	PERCHLORATE	0.528	J	UG/L	0.35	1	144	154		
MW-143M2	MW-143M2_FAL08	8/13/2008	J3 [150]	E314.0	PERCHLORATE	1.08		UG/L	0.35	1	117	122		
MW-143M2	MW-143M2_FAL08D	8/13/2008	J3 [150]	E314.0	PERCHLORATE	1.18		UG/L	0.35	1	117	122		
MW-143M3	MW-143M3_FAL08	8/13/2008	J3 [150]	E314.0	PERCHLORATE	15.7		UG/L	0.35	1	107	112	2	X
MW-359M2	MW-359M2_FAL08	8/13/2008	J3 [150]	E314.0	PERCHLORATE	0.552	J	UG/L	0.35	1	150	160		
MW-143M2	MW-143M2_FAL08	8/13/2008	J3 [150]	SW8330	OCTAHYDRO-1,3,5,7-TETRANITRO-1,3,5,7-TETRAZOCINE	3.63		UG/L	0.086	0.215	117	122	400	
MW-143M2	MW-143M2_FAL08D	8/13/2008	J3 [150]	SW8330	OCTAHYDRO-1,3,5,7-TETRANITRO-1,3,5,7-TETRAZOCINE	3.65		UG/L	0.085	0.213	117	122	400	
MW-143M3	MW-143M3_FAL08	8/13/2008	J3 [150]	SW8330	OCTAHYDRO-1,3,5,7-TETRANITRO-1,3,5,7-TETRAZOCINE	2.67		UG/L	0.086	0.215	107	112	400	
MW-329M1	MW-329M1_FAL08	8/14/2008	J3 [150]	E314.0	PERCHLORATE	0.68	J	UG/L	0.35	1	180	190		
MW-329M2	MW-329M2_FAL08	8/14/2008	J3 [150]	E314.0	PERCHLORATE	0.847	J	UG/L	0.35	1	150	160		
MW-329M2	MW-329M2_FAL08D	8/14/2008	J3 [150]	E314.0	PERCHLORATE	0.799	J	UG/L	0.35	1	150	160		
90MW0022	90MW0022_FAL08	8/19/2008	J3 [150]	E314.0	PERCHLORATE	11.1		UG/L	0.35	1	112	117	2	X
90MW0022	90MW0022_FAL08D	8/19/2008	J3 [150]	E314.0	PERCHLORATE	11.3		UG/L	0.35	1	112	117	2	X
MW-198M2	MW-198M2_FAL08	8/19/2008	J3 [150]	E314.0	PERCHLORATE	194		UG/L	7	20	120	125	2	X
MW-198M2	MW-198M2_FAL08D	8/19/2008	J3 [150]	E314.0	PERCHLORATE	197		UG/L	7	20	120	125	2	X
90MW0022	90MW0022_FAL08	8/19/2008	J3 [150]	SW8330	OCTAHYDRO-1,3,5,7-TETRANITRO-1,3,5,7-TETRAZOCINE	4.66		UG/L	0.088	0.22	112	117	400	
90MW0022	90MW0022_FAL08D	8/19/2008	J3 [150]	SW8330	OCTAHYDRO-1,3,5,7-TETRANITRO-1,3,5,7-TETRAZOCINE	4.53		UG/L	0.090	0.225	112	117	400	
MW-193S	MW-193S_FAL08	8/19/2008	J3 [150]	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	1.33		UG/L	0.096	0.217	31	36	2	
MW-198M2	MW-198M2_FAL08	8/19/2008	J3 [150]	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.03		UG/L	0.094	0.213	120	125	2	X
MW-198M2	MW-198M2_FAL08	8/19/2008	J3 [150]	SW8330	OCTAHYDRO-1,3,5,7-TETRANITRO-1,3,5,7-TETRAZOCINE	4.21		UG/L	0.096	0.217	120	125	400	
MW-198M2	MW-198M2_FAL08D	8/19/2008	J3 [150]	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.3		UG/L	0.094	0.213	120	125	2	X
MW-198M2	MW-198M2_FAL08D	8/19/2008	J3 [150]	SW8330	OCTAHYDRO-1,3,5,7-TETRANITRO-1,3,5,7-TETRAZOCINE	4.51		UG/L	0.096	0.217	120	125	400	
MW-198M3	MW-198M3_FAL08	8/20/2008	J3 [150]	E314.0	PERCHLORATE	120		UG/L	0.094	0.213	100	105	2	X
MW-198M4	MW-198M4_FAL08	8/20/2008	J3 [150]	E314.0	PERCHLORATE	53		UG/L	7	20	70	75	2	X
MW-197M2	MW-197M2_FAL08	8/20/2008	J3 [150]	SW8330	OCTAHYDRO-1,3,5,7-TETRANITRO-1,3,5,7-TETRAZOCINE	0.575	J	UG/L	0.096	0.217	80	85	400	
MW-198M3	MW-198M3_FAL08	8/20/2008	J3 [150]	SW8330	OCTAHYDRO-1,3,5,7-TETRANITRO-1,3,5,7-TETRAZOCINE	0.797		UG/L	0.094	0.213	100	105	400	
MW-198M4	MW-198M4_FAL08	8/20/2008	J3 [150]	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	0.413		UG/L	0.085	0.213	70	75	2	
MW-198M4	MW-198M4_FAL08	8/20/2008	J3 [150]	SW8330	OCTAHYDRO-1,3,5,7-TETRANITRO-1,3,5,7-TETRAZOCINE	1.52		UG/L	0.095	0.215	70	75	400	
MW-218M3	MW-218M3_FAL08	8/22/2008	J3 [150]	SW8330	OCTAHYDRO-1,3,5,7-TETRANITRO-1,3,5,7-TETRAZOCINE	0.768		UG/L	0.086	0.215	78	83	400	
MW-217M2	MW-217M2_FAL08	8/26/2008	J3 [150]	E314.0	PERCHLORATE	1.93		UG/L	0.35	1	138	143		
DP-499	DP-499-08	8/28/2008	J1S [189]	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.5		UG/L	0.056	0.25	150	155	2	X
DP-499	DP-499-09	8/29/2008	J1S [189]	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5.3		UG/L	0.056	0.25	160	165	2	X
DP-499	DP-499-09D	8/29/2008	J1S [189]	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	5.3		UG/L	0.056	0.25	160	165	2	X

MDL = Method Detection Limit

RL = Reporting Limit

Page 1 of 2

DW Limit = Either the MCL or the lowest Health Advisory Limit

**TABLE 5**  
**VALIDATED EXPLOSIVE AND PERCHLORATE RESULTS**  
Data Received September 2008

Location	Field Sample Id	Logdate	Area of Concern	Method	Analyte	Result Value	EPA Flags	Units	MDL	RL	Top Depth	Bot. Depth	DW LIMIT	> DW LIMIT
DP-499	DP-499-10	8/29/2008	J1S [189]	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	3.4		UG/L	0.056	0.25	170	175	2	X
MW-258M1	MW-258M1_FAL08	9/3/2008	DA1 [110]	E314.0	PERCHLORATE	0.52	J	UG/L	0.35	1	109	119		
MW-258M1	MW-258M1_FAL08D	9/3/2008	DA1 [110]	E314.0	PERCHLORATE	0.506	J	UG/L	0.35	1	109	119		
MW-300M2	MW-300M2_F08	9/9/2008	J2N [149]	E314.0	PERCHLORATE	3.48		UG/L	0.35	1	197.23	207.23	2	X
MW-300M2	MW-300M2_F08D	9/9/2008	J2N [149]	E314.0	PERCHLORATE	3.28		UG/L	0.35	1	197.23	207.23	2	X
J2EW0001	J2EW0001_F08	9/10/2008	J2N [149]	E314.0	PERCHLORATE	16.7		UG/L	1.75	5	179	234	2	X
J2EW0001	J2EW0001_F08D	9/10/2008	J2N [149]	E314.0	PERCHLORATE	15.1		UG/L	1.75	5	179	234	2	X
J2EW0002	J2EW0002_F08	9/10/2008	J2N [149]	E314.0	PERCHLORATE	3.07		UG/L	0.35	1	198	233	2	X
J2EW0003	J2EW0003_F08	9/10/2008	J2N [149]	E314.0	PERCHLORATE	1.03		UG/L	0.35	1	202	232		
MW-322M1	MW-322M1_F08	9/11/2008	J2N [149]	E314.0	PERCHLORATE	2.5		UG/L	0.35	1	245	255	2	X
DP-503	DP-503-07	9/11/2008	J1S [189]	SW8330	HEXAHYDRO-1,3,5-TRINITRO-1,3,5-TRIAZINE	0.77		UG/L	0.056	0.25	150	155	2	

MDL = Method Detection Limit

RL = Reporting Limit